

NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

December 11, 1980

Director, Office of Management
Information & Program Control
c/o Distribution Services Branch, DDC, ADM
U S Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir:

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket No. 50-282 License No. DPR-42
50-306 DPR-60

Monthly Operating Report
November, 1980

Attached are two copies of the Monthly Operating Report for
November, 1980 for the Prairie Island Nuclear Generating Plant.

Yours very truly,

L.O. Mayer

L O Mayer, PE
Manager of Nuclear Support Services

LOM/bd

cc: Director, IE-III, USNRC (1)
Director, IE, USNRC (c/o DSB) (10)
NRC Resident Inspector
MPCA
Attn: J W Ferman

8012160453

R

Acc 5/1

NARRATIVE SUMMARY OF OPERATING EXPERIENCE

DOCKET NO. 50- 282
UNIT Prairie Island No. 1
DATE 801201
COMPLETED BY A. A. Hunstad
TELEPHONE 612-388- 1121

MONTH November 1980

PINGP 353, Rev. 0

The unit was in Load Follow operation this month. At 0928 on 11-11 an error in performing a safeguards logic test resulted in a spurious safety injection and unit trip. The unit was returned to service at 1733 the same day.