



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION II  
101 MARIETTA ST., N.W., SUITE 3100  
ATLANTA, GEORGIA 30303

OCT 31 1980

In Reply Refer To:  
RII:JPO  
50-395

South Carolina Electric and Gas Company  
ATTN: T. C. Nichols, Jr., Vice President  
Power Production and Systems Operations  
P. O. Box 764  
Columbia, SC 29218

IS NRC  
DISTRIBUTION SERVICES  
BRANCH

1980 NOV 12 AM 9 09


RECEIVED DISTRIBUTION  
SERVICES UNIT

Gentlemen:

Enclosed is IE Circular No. 80-23 which requires consideration by you with regard to your nuclear power facility.

Should you have any questions regarding this circular or the actions recommended therein, please contact this office.

Sincerely,

  
James P. O'Reilly  
Director

Enclosures:

1. IE Circular No. 80-23 w/enclosure
2. List of Recently Issued IE Circulars

cc w/encl:

A. A. Smith, Site QA Coordinator  
J. B. Knotts, Jr.  
O. S. Bradham, Manager  
Nuclear Operations

8012230072

Q

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D. C. 20555

October 31, 1980

IE Circular No. 80-23 : POTENTIAL DEFECTS IN BELOIT POWER SYSTEMS EMERGENCY GENERATORS

BACKGROUND

This circular addresses a potential deficiency involving the field leads of generators manufactured by Beloit Power Systems. It is known that the subject generators have been coupled with Fairbanks Morse diesel engines for use in nuclear power facilities; however, it is not known whether they have been coupled with other diesel engines for such use. Accordingly, the intent of this circular is to notify all nuclear power facilities of the potential defect and to assure that appropriate remedial actions are taken, if needed.

The Nuclear Regulatory Commission was first informed of the potential defect by a phone call from Mr. R. H. Beadle of the Fairbanks Morse Engine Division of Colt Industries to Mr. D. W. Hayes of Region III on September 19, 1980. On September 20, 1980, a conference call was held between the NRC Duty Officer, personnel from Prairie Island Nuclear Power Station, Mr. Beadle of Fairbanks Morse and Mr. C. Evenson of Beloit Power Systems, the principal spokesman. The purpose of this call was to describe an inspection method which Prairie Island personnel could use to examine the field lead assemblies of their generators for the potential defect. (We have since been informed by the Resident Inspector that the field lead assemblies of the Prairie Island generators did not have the suspected defects.)

In order to disseminate this information on a timely basis, the NRC Duty Officer at Bethesda called those operating facilities which he knew were using the suspect generators on September 20 and 21, 1980. The information conveyed included a description of the potential defect and a description of the aforementioned inspection method. The operating facilities called were:

FACILITY	NO. OF UNITS
Calvert Cliffs 1 and 2	3
Crystal River 3	2
Hatch 1 and 2	5
Duane Arnold	2
North Anna 1 and 2	4
Millstone 1 and 2	3
Robinson 2	2
Prairie Island	2
Vermont Yankee	2
Peach Bottom 2 and 3	4
Arkansas Nuclear One, Unit 2	2

Dupe 8008220243