



Carolina Power & Light Company

POOR ORIGINAL

December 31, 1979

FILE: WG-3514 (B)

SERIAL: GD-79-3305

Mr. D. G. Eisenhut, Acting Director  
Division of Operating Reactors  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

H. B. ROBINSON STEAM ELECTRIC PLANT UNIT NO. 2  
DOCKET NO. 50-261  
LICENSE NO. DPR-23  
UPGRADED SITE EMERGENCY PLAN

Dear Mr. Eisenhut:

In your letter of October 10, 1979, you requested that an upgraded emergency plan for the H. B. Robinson Plant be submitted for NRR review prior to the Emergency Planning Review Team site visit, which is scheduled for early February 1980. In response to your request, Carolina Power & Light Company hereby submits the attached copy of our Carolina Power & Light Company, H. B. Robinson Steam Electric Plant Unit No. 2 Emergency Plan, Revision Number 15 (December 27, 1979).

Areas where Revision Number 15 of our plan does not fully meet the latest emergency planning guidance are:

1) Technical Support Center.

At the present time, we have designated an area for Technical Support that meets present criteria; as defined in Mr. H. R. Denton's letter of October 30, 1979, for NUREG-0578 Item 2.2.2.b, except for instrumentation. A closed circuit television camera that can scan and focus onto pertinent control room instrumentation is being investigated to ascertain its feasibility. It will be installed during 1980 if it is feasible.

2) Disseminating Evacuation Information To The Public.

At this time, we are planning to meet with the local Civil Preparedness Officials to obtain their concurrence with the most efficient and effective methods for accomplishing this task. This information will be incorporated in a subsequent revision to this plan once concurrence is reached.

1685 144