

Commonwealth Edison
Dresden Nuclear Power Station
R.R. #1
Morris, Illinois 60450
Telephone 815/942-2920

*Central
Miles*

December 10, 1976

33 Ltr. #868-76

Mr. James G. Keppler, Regional Director
Directorate of Regulatory Operations-Region III
U.S. Nuclear Regulatory Commission
709 Roosevelt Road
Glen Ellyn, Illinois 60137

SUBJECT: Response to I.E. Circular No. 76-06 (October 8, 1976) -
Hydraulic Shock and Sway Suppressors Valve Calibration
Problems. Docket Nos. 50-10, 50-237, 50-249.

Re: Re: Re:

The enclosed letter from ITT Grinnell is forwarded to
you in response to I.E. Circular No. 76-05. This letter is
documentation that all shock and sway suppressors in use at the
Dresden Nuclear Power Station (Unit No. 1, 2 & 3) have been verified
not being any of those suppressors specified in I.E. Circular
No. 76-05. Therefore, no corrective action, as specified in
I.E. Circular No. 76-05, need be taken by Commonwealth Edison.

Sincerely,

B. B. Stephenson
B. B. Stephenson
Station Superintendent

:JK:gt

File/NRC

Enclosure

9

A02

DEC 27 1976

POOR ORIGINAL

8103060687



December 3, 1976

ITT Grinnell Corporation

Executive Offices

260 West Exchange Street

Providence, Rhode Island 02901

Telephone (401) 831-7000

Pipe Hanger Division

Commonwealth Edison Co.
Dresden Nuclear Power Station
Route 1
Morris, Illinois 60450

Attn: J. Kotowski

RE: NRC I.E. Circular 76-05
Hydraulic Snubbers

Gentlemen:

This is a revision to my letter to you, dated November 17, 1976, regarding valve calibration problems. These problems are not applicable to the below revised list of hydraulic snubbers shipped to Dresden Power Station.

Unit #1

Grinnell Serial No.

16441
16442
16459
16486
5644
6646
5643
6495
5436
6496
6497

Unit #2

Grinnell Serial No.

2448
2449
3082
3083
3084
3085
3086
3087
3088
3089

TO Commonwealth Edison Co.
Attn: J. Kotowski


Unit #3

Grinnell Serial No.

2573
2584
2585
3163
3161
3162
3164
3165
3166
3167
3168

Very truly yours,

ITT GRINNELL CORP.


D. P. BROWN, Mgr.
Snubber Section
Hanger RD & E

DPB/jm

cc: M. Plunkett - Prov.
B. Kelly - Prov.