



General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 788-0550

September 25, 1975

Mr James G. Keppler
US Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

DOCKETS 50-155 & 50-255, LICENSES DPR-6 & DPR-20
BIG ROCK POINT & PALISADES PLANTS

The purpose of this letter is to update previous responses to IE Bulletins 75-04 and 75-04A for the Big Rock Point and Palisades Plants.

All but three of the deficient floor and wall penetration seals have been corrected at the Palisades Plant. Ventilation problems have precluded the completion of these three penetration seals. These three will be completed when the plant is in a shutdown condition, such that it is possible to shut off ventilation.

As stated previously, we plan to use a silicone RTV foam type material for the Big Rock Point penetrations. This work will be performed during the outage presently scheduled to commence January 9, 1976.

We are procuring five additional dry chemical fire extinguishers and two additional CO₂ fire extinguishers to supplement existing fire fighting equipment at the Palisades Plant. A delivery schedule has not yet been established.

At the Big Rock Point Plant, a contract is being negotiated with W. E. Healey and Associates, Inc to install smoke detection equipment in the cable penetration areas both inside and outside of containment and in the electrical equipment room and a water sprinkler system in the cable penetration room outside of containment. Drawings and procedures are presently being generated for Consumers Power Company's review and approval. It is anticipated that this work may be completed during the fall of 1975. In any event, it will be completed no later than during the outage presently scheduled to commence January 9, 1976.

8103060759

In view of the fact that all corrective action has been defined and that this action is either completed, in progress or scheduled, we plan no further monthly updates to our responses to IE Bulletins 75-04 and 75-04A. We will inform you when the actions have been completed at both plants.

Ralph B. Sewell

Ralph B. Sewell
Nuclear Licensing Administrator

CC: File

MEMO ROUTE SLIP Form ERDA-93 (1-75) ERDAM U240		See me about this. Note and return.	For concurrence. For signature.	For action. For information.
TO (Name and unit) IE Chief, FS&EB IE:HQ(4) Licensing(4) DR Central Files J. Rizzo, OMIPC		INITIALS	REMARKS Consumers Power Company	
		DATE	Big Rock Point 50-155	
			Palisades Plant 50-255	
TO (Name and unit) A/D for Info. Processing Region I Region II PDR Local PDR		INITIALS	REMARKS	
		DATE		
TO (Name and unit) R. Callen M. Cherry		INITIALS	REMARKS	
		DATE		
FROM (Name and unit) G. Fiorelli IE:III		REMARKS Attached is a copy of licensee's reply dated September 25, 1975, to IE Bulletin 75-04 and 75-04A.		
PHONE NO.	DATE 09-29-75			

USE OTHER SIDE FOR ADDITIONAL REMARKS

GPO : 1975 O-577-347

pu

PO-2

POOR ORIGINAL