

Appendix A

NOTICE OF VIOLATION

Consumers Power Company

Docket No. 50-155

As a result of the inspection conducted on January 10 through February 9, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified:

Facility Technical Specification 6.8.3 states: "Temporary changes to procedures...may be made, provided"

- a) "...The intent of the original procedure is not altered."
- b) "The change is approved by two members...of the PRC, at least one of whom holds a Senior Reactor Operator's License."
- c) "The change is documented, reviewed by the PRC at the next regularly scheduled meeting and approved by the Plant Superintendent."

Contrary to the above, a change to surveillance procedure TR 19 "Startup Channels Operational Check" was made on November 26, 1980 without the required approvals, documentation and subsequent PRC review.

This is a Severity Level V violation (Supplement 1.E).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within twenty-five days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

MAF : _____
Date

RFWarnick Sr
R. F. Heishman, Acting Director
Division of Resident and Project
Inspection

8104070 229