

TIC

Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

USNRC REGION II
ATLANTA, GEORGIA

20 SEP 17 AIO: 17



Vogtle Project

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011

September 16, 1980

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, GA 30303

REFERENCE:
RII: JPO
50-424
50-425

Attention: Mr. James P. O'Reilly


File: X7BC24
Log: GM-693

Gentlemen:

The following is submitted in response to your letter dated July 31, 1980 concerning I.E. Bulletin 80-20.

Georgia Power Company does not use Westinghouse type W-2 control switches with spring return to neutral for safety related applications at Plant Vogtle.

It is estimated that 25 hours were used for the review of design and preparation of this report. No manpower will be required for corrective actions.

Very truly yours

Doug Dutton
Project General Manager

CWH:tp

xc: U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, DC

M. D. Hunt - USNRC, Region II

8009300110

OFFICIAL COPY

Mr. James P. O'Reilly
RII: J70/50-424, 50-425
September 16, 1980
Page 2

xc: J. H. Miller, Jr.
W. E. Ehrensperger
F. G. Mitchell, Jr.
C. F. Whitmer
R. J. Kelly
R. E. Conway
R. W. Staffa
J. T. Beckham
K. M. Gillespie
C. W. Hayes
E. D. Groover
D. L. McCrary
R. A. Thomas
M. Z. Jeric
J. L. Vota