

**The Light  
company**

Houston Lighting & Power P.O. Box 1700 Houston, Texas 77001 (713) 228-9211

September 9, 1980  
ST-HL-AE-529  
SFN: V-0540

Mr. Karl Seyfrit  
Director, Region IV  
Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76012

Dear Mr. Seyfrit:


South Texas Project  
Units 1&2  
Docket Nos. STN 50-498, STN 50-499  
IE Bulletin No. 80-20

Bulletin No. 80-20, received August 6, 1980, has been reviewed by Houston Lighting & Power Company. As required by the Bulletin, South Texas Project systems have been reviewed to determine whether Westinghouse Type W-2 control switches with spring-return-to-neutral-position are used in safety-related applications at STP. As a result of this review, HL&P has determined that STP equipment does not include this type of switch. Therefore, this Bulletin does not affect the South Texas Project.

Manpower expenditures in responding to this Bulletin were approximately 4 man-hours.

If you have any questions, please contact Mr. L.R. Jacobi at (713) 481-7217.

Very truly yours,

  
G.W. Oprea, Jr.  
Executive Vice President

PLW/ngb

8009300536

cc: Director, Division of Reactor Operations Inspection  
Office of Inspection and Enforcement  
Nuclear Regulatory Commission  
M. D. Schwarz (Baker & Botts)  
R. Gordon Gooch (Baker & Botts)  
J. R. Newman (Lowenstein, Newman, Reis, Axelrad & Toll)  
D. G. Barker  
A. J. Granger  
R. A. Frazar  
G. B. Painter  
R. L. Waldrop  
H. R. Dean  
C. L. McNeese

POOR ORIGINAL