

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 0 8 2 8 8 0 8 0 9 2 4 8 0 9

DOCKET NUMBER 60 61 EVENT DATE 68 69 REPORT DATE 74 75

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal plant operation, the following alarms were received concerning the No. 1

0 3 Diesel Generator: "Diesel Generator Not Available," "Diesel Generator Tripped,"

0 4 "Differential Over Current Trip," and "Diesel Generator No. 1 to Bus El Tripped." In

0 5 addition, the No. 1 Diesel Generator "Low Lube Oil Pressure," "Low Jacket Water Pres-

0 6 sure," and "Generator Overcurrent" alarms were received locally. No. 1 Diesel Genera-

0 7 tor was declared inoperable. This event did not affect the health or safety of the

0 8 public. Technical Specifications 3.8.1.1, 6.9.1.9b

SYSTEM CODE E E (11) CAUSE CODE X (12) CAUSE SUBCODE Z (13) COMPONENT CODE G E N E R A (14) COMP. SUBCODE D (15) VALVE SUBCODE Z (16)

LER/RO REPORT NUMBER (17) 8 0 (21) 0 7 0 (24) 0 3 (28) L (30) 0 (32)

ACTION TAKEN X (18) FUTURE ACTION X (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0 0 0 0 (22) ATTACHMENT SUBMITTED N (23) NPSR-4 FORM SUB. Y (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER G 0 8 0 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 An extensive investigation failed to determine a cause for this event. All the alarm

1 1 relays were reset and the diesel generator was tested and returned to satisfactory

1 2 operation. In addition, Diesel Generators Nos. 2, 3, and 4 were checked for similar

1 3 symptoms and none were found. Periodic monitoring of all Diesel Generators will con-

1 4 tinue and a followup report will be submitted if an exact cause can be determined.

FACILITY STATUS E (28) % POWER 0 4 2 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION Operator Surveillance (32)

ACTIVITY CONTENT RELEASED OF RELEASE Z (33) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)

PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION NA (39)

PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION NA (41)

LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43)

PUBLICITY ISSUED N (44) DESCRIPTION 8000300 568 (45) NRC USE ONLY

NAME OF PREPARED A. C. Tollison, Jr. PHONE 919-457-9521