

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

⑦ ⑧ ⑨ | 1 | L | Q | A | D | 1 | ② | 0 | 0 | 0 | - | 0 | 0 | 0 | - | 0 | 0 | 0 | ③ | 4 | 1 | 1 | 1 | 1 | ④ | _____ | ⑤

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CON'T
⑦ ⑧ ⑨ | R | P | O | R | T | S | O | U | R | C | E | L | ⑥ | 0 | 5 | 0 | 0 | 0 | 2 | 5 | 4 | ⑦ | 0 | 9 | 0 | 4 | 8 | 0 | ⑧ | 0 | 9 | 2 | 2 | 8 | 0 | ⑨

REPORT SOURCE 80 81 DOCKET NUMBER 88 89 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

⑦ ⑧ ⑨ | 0 | 2 | While performing Local Leak Rate Testing, the Containment Purge Volume bounded by
⑦ ⑧ ⑨ | 0 | 3 | valves A0 1-1601-21, 22, 55 and 56 was found to have a leak rate of 435.21 scfh.
⑦ ⑧ ⑨ | 0 | 4 | This is in excess of 18.36 scfh allowable limit for any one valve specified by
⑦ ⑧ ⑨ | 0 | 5 | Technical Specification 4.7.A.2.i. The Containment Purge Valves will be repaired and
⑦ ⑧ ⑨ | 0 | 6 | tested before unit startup.
⑦ ⑧ ⑨ | 0 | 7 | _____
⑦ ⑧ ⑨ | 0 | 8 | _____

⑦ ⑧ ⑨ | 0 | 9 |

SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP SUBCODE | VALVE SUBCODE

S | A | ⑪ | E | ⑫ | B | ⑬ | V | A | L | V | E | X | ⑭ | B | ⑮ | D | ⑯

LER/RD REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.

⑰ | 8 | 0 | ⑱ | 0 | 2 | 1 | ⑳ | 0 | 3 | ㉑ | L | ㉒ | 0

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER

B | ⑲ | Z | ⑳ | Z | ㉑ | 0 | 0 | 0 | ㉒ | N | ㉓ | Y | ㉔ | N | ㉕ | C | 6 | 6 | 5 | ㉖

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ⑳

⑦ ⑧ ⑨ | 1 | 0 | Valve A0 1-1601-21 is suspected to be leaking excessively. The valve has not been
⑦ ⑧ ⑨ | 1 | 1 | repaired at this date. A supplemental report will be sent upon completion of all
⑦ ⑧ ⑨ | 1 | 2 | testing and when all corrective actions have been completed.
⑦ ⑧ ⑨ | 1 | 3 | _____
⑦ ⑧ ⑨ | 1 | 4 | _____

⑦ ⑧ ⑨ | 1 | 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION

H | ㉘ | 0 | 0 | 0 | ㉙ | NA | ㉚ | B | ㉛ | Local Leak Rate Test | ㉜

⑦ ⑧ ⑨ | 1 | 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY | LOCATION OF RELEASE

Z | ㉝ | Z | ㉞ | NA | ㉟ | NA | ㊱

⑦ ⑧ ⑨ | 1 | 7 | PERSONNEL EXPOSURES | DESCRIPTION

0 | 0 | 0 | ㉡ | Z | ㉢ | NA | ㉣

⑦ ⑧ ⑨ | 1 | 8 | PERSONNEL INJURIES | DESCRIPTION

0 | 0 | 0 | ㉤ | NA | ㉥

⑦ ⑧ ⑨ | 1 | 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION

Z | ㉦ | NA | ㉧

⑦ ⑧ ⑨ | 2 | 0 | PUBLICITY ISSUED | DESCRIPTION

N | ㉨ | NA | ㉩

8010160375 Dave Hannum PHONE 309-654-2241, ext. 177