

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

JOHN S. DYSON
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

FREDERICK R. CLARK



October 10, 1980
JPN-80-44

GEORGE T. BERRY
PRESIDENT & CHIEF
OPERATING OFFICER

JOHN W. BOSTON
EXECUTIVE VICE
PRESIDENT & DIRECTOR
OF POWER OPERATIONS

JOSEPH R. SCHMIEDER
EXECUTIVE VICE
PRESIDENT & CHIEF
ENGINEER

LEROY W. SINCLAIR
SENIOR VICE PRESIDENT
& CHIEF FINANCIAL
OFFICER

THOMAS R. FREY
SENIOR VICE PRESIDENT
& GENERAL COUNSEL

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Thomas A. Ippolito, Chief
Operating Reactors Branch No. 2
Division of Licensing

Subject: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Proposed Changes Related to NUREG-0578
TMI-2 Lessons Learned Category "A" Items

Reference: Letter, D. G. Eisenhut (NRC) to all Boiling
Water Reactor Licensees dated July 2, 1980

Dear Sir:

Enclosed for filing are three (3) signed originals and
nineteen (19) copies of a document entitled, "Application
for Amendment to Operating License," together with forty (40)
copies of Attachments I, II and III, thereto.

This application seeks to incorporate new license conditions
related to a System Integrity Measurements Program and Improved
Iodine Measurements capability into Facility Operating License
DPR-59. This application also seeks to amend Sections 3.2, 4.2,
6.2 and 6.3 of Appendix A to incorporate limiting conditions for
operation and surveillance requirements for the Safety/Relief
Valve position indication system and to reflect the addition of
a Shift Technical Advisor to the plant staff. These changes were
requested in the above referenced document.

The requirements of the referenced letter pertaining to water
level instrumentation are presently met by Sections 3.2 (Table 3.2-6)
and 4.2 (Table 4.2-6) of Appendix A. The requirements pertaining
to containment isolation are presently met by Section 3.2
(Table 3.2-1), 4.2 (Table 4.2-1) and 3.7 (Table 3.7-1) of Appendix A.


8010160489

10

App
5/3
w/check
\$14,000.00

The Authority has classified this application for amendment to the operating license as Class III, as it involves the single safety issue of modifying the operating license and Technical Specifications to incorporate the requirements of the NUREG-0578 TMI-2 Lessons Learned Category "A" items. Enclosed is a check in the amount of \$4,000 as the filing fee per 10CFR §170.22, which the Authority pays under protest pending a final determination of the legality of the fee schedule.

Very truly yours,

A handwritten signature in black ink, appearing to read "J. P. Bayne", with a long horizontal flourish extending to the right.

J. P. Bayne
Senior Vice President
Nuclear Generation