

LONG ISLAND LIGHTING COMPANY

SHOREHAM NUCLEAR POWER STATION
P.O. BOX 618, NORTH COUNTRY ROAD • WADING RIVER, N.Y. 11792

December 21, 1980

SNRC-522

Mr. Harold R. Denton, Director Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, D.C. 20555

Environmental Qualification of Safety-Related Equipment NRC Information Request, Dated 10/1/80 Shoreham Nuclear Power Station - Unit 1 Docket No. 50-322

Dear Mr. Denton:

Attached is the information which was requested regarding environmental qualification tests which have been authorized by LILCO for equipment to be used in safety-related applications at the Shoreham plant. We trust that this information will be of assistance to your long range planning and scheduling goals. If additional information is required, please do not hesitate to contact this office.

Very truly yours,

J. P. Novarro, Project Manager

Shoreham Nuclear Power Station

RH/cc

Attachment

cc: Mr. B. Grier, Director
Office of Inspection and Enforcement

Mr. J. Higgins

2001

SHOREHAM NUCLEAR POWER STATION - UNIT 1 ENVIRONMENTAL SAFETY-RELATED EQUIPMENT QUALIFICATION TEST INFORMATION

December 21, 1980 Page 1

COGNIZANT LICENSING REPRESENTATIVE: Dr. Joan F. Etzweiler

Dr. Joan F. Etzweiler
Long Island Lighting Company
175 East Old Country Road
Hicksville, N. Y. 11801
(516) 733-4784

CURRENT EQUIPMENT QUALIFICATION TESTING

A. ASCO PRESSURE AND TEMPERATURE SWITCHES

1. Manufacturer

Automatic Switch Company (ASCO) 50-56 Hanover Road Florham Park, New Jersey 07932

2. Equipment Description

ASCO Tri-Point Series SB11, SB21, and SB31 pressure and temperature switch assemblies (fixed deadband type) with associated pressure and temperature transducer assemblies.

3. Systems

These pressure and temperature switches are used in the following Shoreham Unit 1 systems:

System Serviced - (M50) - RBSVS + Control Rm. AC Chilled Water

(P41) - RHR + Station Service Water

(P42) - Reactor Building Closed Loop Cooling Water

(C71) - Reactor Protection

(N21) - Condensate + Feedwater

(R43) - Diesel Emergency Power

(Z91) - Spares

4. Test Location and Schedule

The test will be conducted at the manufacturer's facility (above) with the following anticipated completion dates:

DESCRIPTION

ESTIMATED DATE

Seismic Baseline Testing January 30
Thermal Aging April 3 April 10 Radiation Aging Wear Aging April 15 Vibration Aging April 22 Seismic Event Simulation May 27 Accident Radiation Simulation June 3 Accident Steam Line Break Simulation July 8 July 13 Final Inspection

B. ASCO AUTOMATIC TRANSFER SWITCHES

1. Manufacturer

Automatic Switch Company (ASCO) 50-56 Hanover Road Florham Park, New Jersey 07932

2. Equipment Description

Automatic Transfer Switches catalog numbers 307A66AC and 307A66BC.

3. System

This equipment is used in safety-related motor control centers (R24).

4. Test Location and Schedule

Thermal testing of the devices is complete. Testing of irradiated samples will resume shortly, though a definitive schedule has not been developed at this time. The test location is:

Acton Environmental Test Corporation 533 Main Street Acton, Massachusetts 01720

C. AC AND DC DISTRIBUTION PANEL BOARDS

Manufacturer

Systems Control P. O. Box 738 Iron Mountain, MI. 49801

C. AC AND DC DISTRIBUTION PANEL BOARDS (Cont.)

2. Equipment Description

These distribution boards are "engineered items", and accordingly, the manufacturer does not provide model numbers.

3. Systems

These panel boards are used in the 125v DC Battery Power (R42) and the AC Instrument Power (R35) systems.

4. Test Location and Schedule

The environmental testing schedule and requirements are currently being developed. Acton Environmental Test Corporation has been selected for the test facility.