



Metropolitan Edison Company  
Post Office Box 480  
Middletown, Pennsylvania 17057

Writer's Direct Dial Number

March 12, 1981  
L1L 067

Office of Inspection and Enforcement  
Attn: B. H. Grier, Director  
Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
LER 81-003/03L-0

Enclosed please find Licensee Event Report 81-003/03L-0 concerning a fire wall penetration seal which was breached when core boring a new penetration. This event is reportable as a violation of Technical Specification 3.18.7 and reportable under Technical Specification 6.9.2.B(2). This planned core boring was discussed in a telephone conversation between L. W. Harding (GPUNC) and D. Haverkamp (NRC) on January 30, 1981 who agreed on the need for this report in order to proceed with the modification.

Sincerely,

Signed H.D. Hukill

H. D. Hukill  
Director, TMI-1

HDH:LWH:lma

Attachments

cc: L. Barrett  
D. DiIanni  
~~H. Grier~~  
V. Stello  
R. W. Reid



A002  
S/L

8103170568

5