LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-00000-00 (3) | 41111 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000327 (7) | 031381 (8) | 040881 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Unit 1 in mode 2. During a routine inspection, water was discovered in safety
03 | injection pump 1A-A oil reservoir. This event required entry into LCO 3.5.2.
04 | There was no effect upon public health or safety. Previous occurrences - none.
05 |
06 |
07 |
08 |
7 8 9 80

09 | SYSTEM CODE CJ (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE PUMPXX (14) | COMP. SUBCODE B (15) | VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 81 | — | SEQUENTIAL REPORT NO. 033 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER P026
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The water contamination of the oil was caused by condensation buildup over a period of
11 | time. The oil was changed within approximately 4 hours. A preventive maintenance
12 | program will be established to inspect and sample the oil in the safety injection pumps
13 | monthly to determine the rate of water buildup, verify the cause, and to change the
14 | oil when necessary.
7 8 9 80

15 | FACILITY STATUS C (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Operations personnel observation
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 60

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA
7 8 9 10 80

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 68 69

8104140523

Name of Preparer M. R. Harding/G. B. Kirk Phone (615) 842-8317