

Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060

RECORDED
APR 2 1981



Vogle Project

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011

April 1, 1981

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, GA 30303

Reference:
IE: II: BRC
50-424/81-04
50-425/81-04

Attention: Mr. R. C. Lewis

File: X7BG10
Log: GN-124

Gentlemen:


The Georgia Power Company wishes to submit the following information concerning the violation discussed in your inspection report 50-424/81-04 and 50-425/81-04.

We concur with the finding identified concerning failure to follow procedure for controlling nonconforming items. The reason for the finding was due to an oversight on our part.

An NCR was written and the material was placed on "Hold" by letter dated February 20, 1981. To avoid further similar violations the person designated as responsible for providing corrective action to QA audit finding reports shall also review the findings to determine if an NCR needs to also be generated.

Full compliance was achieved on February 20, 1981.

Neither the inspection report nor this reply contain any proprietary information and may be placed in the NRC's Public Document Room.

Very truly yours,

Doug Dutton
Project General Manager

CWH:tp

xc: (see Page 2)

8104240 269


Mr. R. C. Lewis
United States Nuclear Regulatory Commission
April 1, 1981
Page 2

STATE OF GEORGIA

COUNTY OF FULTON


Doug Dutton states that he is Project General Manager of Georgia Power Company's Vogtle Project and is authorized to execute this oath on behalf of Georgia Power Company and that to the best of his knowledge and belief the facts set forth in this letter are true.

GPC:



Doug Dutton

Sworn to and subscribed before me this 1st day of April, 1981.



Notary Public, Georgia, State at Large
My Commission Expires March 21, 1985

Mr. R. C. Lewis
United States Nuclear Regulatory Commission
April 1, 1981
Page 3

bxc: U. S. Nuclear Regulatory Commission
Attn: Victor J. Stello, Jr., Director
Office of Inspection and Enforcement
Washington, DC 20555

J. H. Miller, Jr.
W. E. Ehrensperger
F. G. Mitchell, Jr.
R. J. Kelly
C. F. Whitmer
R. E. Conway
D. E. Dutton
H. C. Nix
R. W. Staffa
K. M. Gillespie
L. T. Gucwa
C. R. Miles, Jr.
E. D. Groover
D. L. McCrary
R. A. Thomas
O. Batum
J. A. Bailey
M. Z. Jeric
B. L. Lex



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303
MAR 13 1981

Georgia Power Company
ATTN: J. H. Miller, Jr.
Executive Vice President
270 Peachtree Street
Atlanta, GA 30303

Gentlemen:

Subject: Report Nos. 50-424/81-04 and 50-425/81-04

This refers to the routine safety inspection conducted by B. R. Crowley of this office on February 18-20, 1981, of activities authorized by NRC Construction Permit Nos. CPPR-108 and CPPR-109 for the Vogtle facility. Our preliminary findings were discussed with K. M. Gillespie at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector.

During the inspection, it was found that certain activities under your license appear to violate NRC requirements. This item and references to pertinent requirements are listed in the Notice of Violation enclosed herewith as Appendix A. Elements to be included in your response are delineated in Appendix A.

We have examined actions you have taken with regard to previously reported unresolved items. The status of these items is discussed in the enclosed report.

In accordance with Section 2.790 of the NRC "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room. If this report contains any information that you believe to be proprietary, it is necessary that you make a written application within 20 days to this office to withhold such information from public disclosure. Any such application must include the basis for claiming that the information is proprietary and the proprietary information should be contained in a separate part of the document. If we do not hear from you in this regard within the specified period, the report will be placed in the Public Document Room.

dup 8103270132


MAR 13 1981

Georgia Power Company

2

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely



R. G. Lewis, Acting Director
Division of Resident and
Reactor Project Inspection

Enclosures:

1. Appendix A, Notice of Violation
2. Inspection Report Nos. 50-424/81-04
and 50-425/81-04

cc w/encl:

K. M. Gillespie, Construction
Project Manager
E. D. Groover, QA Site Supervisor
D. E. Dutton, Project General Manager

APPENDIX A

NOTICE OF VIOLATION

Georgia Power Company
Vogle

Docket Nos. 50-424 & 50-425
License Nos. CPPR-108 & CPPR-109

As a result of the inspection conducted on February 18-20, 1981, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violation was identified.

10 CFR 50, Appendix B, Criterion V, implemented by paragraph 17.1.5 of the PSAR, requires in part that, activities affecting quality shall be prescribed by documented instructions, procedures, and drawings and shall be accomplished in accordance with these instructions, procedures and drawings. Paragraphs VIII.A and VIII.E.3.b of procedure GD-T-01, the procedure for controlling nonconforming items, require that a nonconforming report be issued and the nonconforming item be placed on hold when incorrect or deficient documentation is identified.

Contrary to the above, a significant documentation deficiency, was identified by QA with the material test report for Heat 97401 E70S-2 welding wire and a nonconformance report was not issued and the material was not placed on hold.

This is a Severity Level V Violation (Supplement II.F.).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within twenty-five days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

MAR 13 1981

Date: _____

duye 8103270145



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

Report Nos. 50-424/81-04 and 50-425/81-04

Licensee: Georgia Power Company
270 Peachtree Street
Atlanta, GA 30303

Facility Name: Vogtle

Docket Nos. 50-424 and 50-425

License Nos. CPPR-108 and CPPR-109

Inspection at: Vogtle site near Waynesboro, GA

Inspector: *B. R. Crowley*

3/5/81
Date Signed

Approved by: *A. R. Herdt*
A. R. Herdt, Section Chief, EI Branch

3/5/81
Date Signed

SUMMARY

Inspected on February 18-20, 1981

Areas Inspected

This routine unannounced inspection involved 25 inspector-hours on site in the areas of welding of steel structures and supports (Units 1 and 2), welding or safety-related piping (Units 1 and 2), previous inspection findings (Units 1 and 2), and general construction activities (Units 1 and 2).

Results

Of the three areas inspected, no violations or deviations were identified in two areas; one item of noncompliance was found in one area (Violation - Failure to follow procedure for controlling nonconforming items, paragraph 8.c).

DUPLICATE DOCUMENT

Entire document previously
entered into system under:

ANO 8103270158

No. of pages: 9