LICENSEE EVENT REPORT

•	CONTROL BLOCK:
01	P A B V S 1 2 0 0 - 0 0 0 - 0 0 3 4 1 1 1 1 1 6 57 CAT 58 5
CONT	REPORT L 6 0 5 0 0 0 0 3 3 4 7 0 4 1 6 8 1 3 0 5 1 5 8 1 9 SOURCE 50 61 DOCKET NUMBER 58 69 EVENT DATE 74 75 REPORT DATE 80
0 2	EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) At 0315 hours, the Refueling Water Storage Tank (RWST) Channel C level indicator was
	found reading high. It was declared inoperable and power operation continued as per
0 3	Technical Specification 3.3.2.1. The public health and safety was not jeopardized.
0 4	Three operable channels remained for the 2/4 RWST low level logic signal for
0 5	automatic safety injection transfer. Train A automatic quench spray flow reduction
0 6	valve [MOV-QS-103A] would be disabled on RWST low level but its actuation is checked]
0 7	in applicable emergency procedures and closing is possible using its control switch.
7 8	9 SYSTEM CAUSE CAUSE COMPONENT CODE SUBCODE SUBCODE
0 9	S F 10 E 12 E 13 I N S T R U 14 T 15 7 16
	17 REPORT 8 1 0 3 6 27 0 3 0 31 0 32 0
	TAKEN ACTION ON PLANT METHOD TAKEN ACTION ON PLANT METHOD FORM SUB. SUBMITTED FORM SUB
110	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The cause for the faulty indication was traced to the level transmitter. It was
	replaced and the channel was returned to service at 1035 hours.
1 2	
1 3	1
7 8	9 FACILITY SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 STATUS SPOWER OTHER STATUS 30 DISCOVERY DESCRIPTION 32
1 5	F (28) (0 5 8 (29) N/A B (31) Surveillance log reading 30
16	ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 N/A N/A 80
	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 1 0 1 0 1 0 1 37 Z (38) N/A
7 3	9 20000001 10000000
1 8	NUMBER DESCRIPTION 41) N/A N/A
	LOSS OF OR DAMAGE TO FACILITY 43
, 3	NRC USE ONLY
2 0	N/A 58 59 50.5
, ,	NAME OF PREPARER W. S. Lacey PHONE: 412-643-8525

Attachment To LER 81-36/03L Beaver Valley Power Station Duquesne Light Company Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.