

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER · DALLAS, TEXAS 75201

Log # TXX-3321
File # 904.4

May 19, 1981

[REDACTED]
U.S. Nuclear Regulatory Commission
Licensing Project Manager
Light Water Reactors Branch No. 2
Division of Project Management
Office of Nuclear Reactor Regulation
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
LOOSE PARTS MONITORING SYSTEM

Dear Mr. Burwell:

The following information concerning the CPSES Loose Parts Monitoring System is provided as per a telephone conversation with Joe Holonich on May 15, 1981.

1. The system sensitivity is 0.5 ft-lbs measured three feet from the sensor
2. The alarm set point is 0.5 ft-lbs plus-or-minus 0.25 ft-lbs
3. The system is designed to operate in the normal containment environment
4. The system is designed in accordance with NRC Reg. Guide 1.133.

J. S. Marshall

BSD:t's

cc: Ed Alarson
Richard Calder
Suresh Gupta

Boo's/0

A
8105260 321