

GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 713 838-3843

April 10, 1981

RBG - 10,091
File Nos. G9.5
G15.4.1

Mr. G. L. Madsen, Chief
Reactor Projects Branch
U.S. Nuclear Regulatory Commission
Region IV Office of Inspection & Enforcement
611 Ryan Plaza, Suite 1000
Arlington, Tx. 76011

Dear Mr. Madsen:

River Bend Station-Unit I
Refer To: RIV
Docket No. 50-458/Report 80-13

With regard to Gulf States Utilities Company's (GSU) letter dated March 2, 1981, concerning Inspection Report 80-13, GSU has made the following correction.


In Enclosure 1 under "Corrective Steps Which Have Been Taken and Results Achieved", number 3 should read:

"3. E&DCR No. C-1966 has been issued to limit discharge of concrete to 90 minutes after batching or 300 revolutions of the truck mixers."

This correction is due to a typographical error which originally stated 50 minutes instead of the 90 minutes allowed for discharge of concrete after batching.

This report completes our response to Inspection Report 80-13.

Sincerely,



E. L. Draper
Vice President
Nuclear Technology

ELD/RJK/sj

8105260688