

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

March 13, 1981



Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

SEQUOYAH NUCLEAR PLANT UNIT 1 - 50-327 - NRC-OIE BULLETIN 81-01

The subject bulletin dated January 27, 1981, regarding surveillance on mechanical snubbers, requires a response for Sequoyah Nuclear Plant unit 1.

Sequoyah unit 1 has no accessible or inaccessible International Nuclear Safeguards Corporation hydraulic snubbers installed or in storage for use on safety-related systems. Therefore, no action is required for Sequoyah unit 1 under items 1 and 2 of the bulletin. We expect to provide you with the information required by item 3 of the bulletin in accordance with the required schedule.

If you have any questions, please get in touch with D. L. Lambert at FTS 857-2581.

To the best of my knowledge, I declare the statements contained herein are complete and true.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Regulation and Safety

cc: Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8103240607

Q