

DSB



March 17, 1981

L81-140
FILE: RR 2 (NP-33-80-115)

Docket No. 50-346
License No. NPF-3

Mr. James G. Keppler
Regional Director, Region III
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

Attached are three copies of Page 3 to the Supplemental Information for Licensee Event Report 80-090, which has been corrected. There has been no change to the LER form or Pages 1 and 2 of the Supplemental Information.

Please remove and destroy your previous copies of this page and replace with the attached corrected pages.

Yours truly,

Terry D. Murray
Station Superintendent
Davis-Besse Nuclear Power Station


TDM/ljk

Enclosure

cc: Mr. Victor Stello, Jr., Director
Office of Inspection and Enforcement
Encl: 30 copies

Mr. Norman Haller, Director
Office of Management Program Analysis
Encl: 3 copies

Mr. Luis Reyes
NRC Resident Inspector
Encl: 1 copy




MAR 25 1981

A002
S 1/1

8103310 627

CONTAINMENT PRESSURE BA 309 (After 120 VAC Removed)

	<u>Pressure (psia)</u>	<u>Volts (1)</u>
Full Range	60	2.00
As Found	38.55	1.428
Allowable Value (TS)	≤ 38.52	1.427
Trip Setpoint	≤ 38.4	1.425
Trip Setpoint	≥ 37.65	1.404
Zero	0	0.4




Worst case drift 1.5%

$$(1) V = \left(\frac{\text{psia} \times 1.6}{60} \right) + 0.4$$

BWST LEVEL (BA 312) (With 120 VAC on Common)

	<u>Level (inches)</u>	<u>Volts (1)</u>
Full Range	600	2.00
As Found	57	0.552
Allowable Value (TS)	≤ 56.7	0.551
Trip Setpoint	≤ 55.0	0.547
Trip Setpoint	≥ 49.5	0.532
Allowable Value (TS)	≥ 48.3	0.529
Zero	0	0.4



Worst case drift 1.25% of full scale

$$(1) V = \left(\frac{\text{level (in)} \times 1.6}{600} \right) + 0.4$$

Correction - 3/17/81

