LER SUPPLEMENTAL INFORMATION

Technical Specification involved 3.5.A.2
Lacrol Under Technical Specification 6.7.2.b(2)
Fine of Occurrence 1920 Unit 2
CS System I flow indicator 2-FI-75-21 failed to indicate flow during surveillence testing.
Unit 1 at 98% power
Unit 2 at 100% power.
Unit 3 at 99% power.
Action specified in the Technical Specification Surveillance Requirements met has a monograble equipment. Describe.
Required surveillance testing performed.
Transmitter failed.
There was no danger to the health or safety of the public, no release of activity, no damage to plant or equipment and no resulting significant chain of events.
Corrective aution:
Replaced the transmitter. No recurrence control action planned.
Paris re Data: None
*R tention: Period - Lifetime; Responsibility - Administrative Supervisor