

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

May 14, 1981

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555



Dear Mr. Schwencer:

In the Matter of the Application of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

At the request of the NRC Environmental Branch Reviewer, TVA will conduct a verification review of the purge valve configuration differences between unit 1 and unit 2. TVA will report on the results of our onsite review of the unit 2 purge valve configuration by June 1, 1981.

By review of plant design drawings and valve specifications, TVA considers that there are no differences between the purge systems for unit 1 and unit 2 which could significantly affect the conclusions of TVA's review of purge valve operability/reliability to close in a LOCA environment. The purge valve configuration for unit 1 was verified (see my letter to you dated January 8, 1981). If our onsite review of unit 2 defines any significant differences, this matter would be promptly analyzed and appropriately reported.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

M. R. Wisenburg
M. R. Wisenburg
Nuclear Engineer

Sworn to and subscribed before me
this 14th day of May 1981

Bryant M. Lowery
Notary Public
My Commission Expires 4/4/82