POOR ORIGINAL

N/A

N/A

N/A

	DOCKET	No. 50-267	50 - 267 810601		
	24	NTE 810601			
	COMPLETED	3Y J. W. Ga	ıhm		
	TELEPHO	ONE (303) 78	35-2224		
ATING STATUS	TXC	OTES			
Unit Name: Fort St. Vrain					
Reporting Period: 810501 through	810531				
Licensed Thermal Power (Wt):	842				
Nameplace Rating (Gross WWe):					
Design Electrical Rating (Net MWe):	330				
Maximum Dependable Capacity (Gross MWe):	342				
Maximum Dependable Capacity (Net Me):	330				
	None				
Power Level To Which Restricted, If Any (N	let MWe): 231				
Reasons for Restrictions, If Any: Nucl	lear Regulatory Comm	nission restric	tion 70% pendin		
resolution of temperature flu	ectuations.				
	This Month ?	ear to late	Cumulative		
Hours in Reporting Period			16,824		
Hours in Reporting Period Number of Hours Reactor Was Gritical	744	: 623	16,824		
	744	2,665.5	16,824		
Number of Hours Reactor Was Critical	744	2,665.5	16,824 11,800.7		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours	744 301.8 0.0	2,665.5	16,824 11,800.7 0.0 7,824.8		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line	744 301.8 0.0 285.9 0.0	2,665.5 0.0 2,131.5	16,824 11,800.7 0.0 7,824.8 0.0		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours	744 301.8 0.0 285.9 0.0	2,663.5 0.0 2,131.5 0.0	16,824 11,800.7 0.0 7,824.8 0.0		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH)	744 301.8 0.0 285.9 0.0 170.909.3	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH)	744 301.8 0.0 285.9 0.0 170.909.3 64.706	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH)	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46.5%		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) unit Service Factor	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092 38.4%	2,663.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305 58.8%	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46,5% 46,5%		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) unit Service Factor Unit As ilability Factor	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092 38.4% 38.4%	2,663.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305 58.8% 58.8%	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46.5% 46.5% 21,0%		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) unit Service Factor Unit As Hability Factor Unit Capacity Factor (Using MDC Net)	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092 38.4% 38.4% 24.1%	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305 58.8% 58.8% 30.9%	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46,5% 46,5% 21,0%		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) Unit Service Factor Unit As ilability Factor Unit Capacity Factor (Using MDC Net) Unit Capacity Factor (Using DER Net)	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092 38.4% 38.4% 24.1% 24.1% 35.0%	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305 58.8% 58.8% 30.9% 30.9% 35.8%	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46.5% 46.5% 21.0% 37.0%		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) unit Service Factor Unit As ilability Factor Unit Capacity Factor (Using MDC Net) Unit Capacity Factor (Using DER Net) Unit Forced Outage Rate	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092 38.4% 38.4% 24.1% 24.1% 35.0% Sype, Date, and Duration of	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305 58.8% 58.8% 30.9% 30.9% 30.9% 35.8%	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46.5% 46.5% 21.0% 37.0%		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) unit Service Factor Unit Antilability Factor Unit Capacity Factor (Using MDC Net) Unit Capacity Factor (Using DER Net) Unit Forced Outage Rate Shutdowns Scheduled Over Next 6 Months (T	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092 38.4% 38.4% 24.1% 24.1% 35.0% Sting four months.	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305 58.8% 58.8% 30.9% 30.9% 30.9% 30.9% 35.8%	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46.5% 21,0% 21,0% 37.0% pance/modificat		
Number of Hours Reactor Was Critical Reactor Reserve Shutdown Hours Hours Generator On-Line Unit Reserve Shutdown Hours Gross Thermal Energy Generated (MWH) Gross Electrical Energy Generated (MWH) Net Electrical Energy Generated (MWH) unit Service Factor Unit As ilability Factor Unit Capacity Factor (Using MDC Net) Unit Capacity Factor (Using DER Net) Unit Forced Outage Rate Shutdowns Scheduled Over Next 6 Months (Tabutdown September 1, 1981 lass	744 301.8 0.0 285.9 0.0 170.909.3 64.706 59.092 38.4% 38.4% 24.1% 24.1% 24.1% 35.0% Speed Date, and Duration of Startup:	2,665.5 0.0 2,131.5 0.0 1.102.586.8 400.445 369.305 58.8% 30.9% 30.9% 30.9% 30.9% 30.9% 31.8% Each): Mainte	16,824 11,800.7 0.0 7,824.8 0.0 3,810,679.6 1,272,239 1,168,606 46.5% 21,0% 21,0% 37.0% pance/modificat		

810617009 INITIAL ELECTRICITY

COMMERCIAL OPERATION

AVERAGE DAILY UNIT POWER LEVEL

			Docket No	50-267
			Unit _	Fort St. Vrain
			Date _	810601
		C	completed By _	J. W. Gahm
			Telephone _	(303) 785-2224
Month	May, 1981			
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY		Y POWER LEVEL
1	215.8	17	0.	.0
2	215.4	18	0.	.0
3	214.6	19	0	.0
4	143.3	20	0.	.0
5	109.2	21	0	.0
6	213.9	22		.0
7	217.3	23	0	.0
8	218.3	24	0	.0
9	217.8	25	0	.0
10	217.8	26	0	.0
11	217.8	27	0	.0
12	218.4	28	0	.0
13	124.7	29	0	.0
14	0.0	30	0	.0
15	0.0	31	0	.0
16	0.0			

^{*}Generator on line but no net generation.

UNIT SHUTDOWNS AND POWER REDUCTORS

DOCKET NO. 50-267

UNIT NAME FORE St. Vrain

DATE 810601

COMPLETED BY J. W. Cahm

TELEPHONE (303) 785-2224

REPORT MONTH May, 1981

NO.	DATE	TYPE	DORATION	REASON	METHOD OF SHUTTING DOWN REACTOR	LER #	SYSTEM CODE	COMPONENT	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
81-16	810504	S	15.7	н	N/A	N/A	18	INSTRU	Power reduced and turbine taken off line to modify the turbine runback circuitry in an attempt to avoid un- necessary hot reheat steam temperature scrams.
81-17	810513	F	154.4	A	3	N/A	нв	GENERA	Turbine trip on high vibration fol lowed by a reactor scram.
	810520	S	288.0	С	N/A	N/A	N/A	N/A	Started refueling outage,

Summary: Refueling to continue during June.

REFUELING INFORMATION

1.	Name of Facility.	Fort St. Vrain Unit No. 1
2.	2 Valued date for next refueling	May 20, 1981
3.	Scheduled date for restart following refueling.	July 20, 1981
4.	Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?	No
	If answer is yes, what, in general, will these be?	
	If answer is no, has the reload fuel design and core configuration been reviewed by your Plant Safety Review Committee to determine whether any unreviewed safety questions are associated with the core reload (Reference 10CFR Section 50.59)?	Yes
	If no such review has taken place, when is it scheduled?	
5.	Scheduled date(s) for submitting proposed licensing action and supporting information.	
ó.	Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures.	Peripheral fuel elements changed from thin thorium buffer to thick thorium buffer.
7.	The number of fuel assemblies (a) is the core and (b) in the spent fuel storage pool.	a) 1482 HTGR fuel elements. b) 10 spent HTGR fuel elements
3.	The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned, in number of fuel assemblies.	Capacity is limited in size to about one- third of core (approximately 500 HTGR elements). No change is planned.

REFUELING INFORMATION (CONTINUED)

 The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity.

1986 under the Three Party Agreement (Contract AT (04-3)-633) between DOE, Public Service Company of Colorado (PSCo), and General Atomic Company.*

*The 1986 date is based on the understanding that spent fuel discharged during the term of the Three Party Agreement will be shipped to the Idaho National Engineering Laboratory for storage by DOE at the Idaho Chemical Processing Plant (ICPP). The storage capacity has evidently been sized to accommodate fuel which is expected to be discharged during the eight year period covered by the Three Party Agreement.