

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower II

October 2, 1980

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/80148

The enclosed report provides details concerning the shield building
vent monitor (1-RE-90-100) which was declared inoperable due to loss
of sample air flow. This report is submitted in accordance with
Sequoyah unit 1 Technical Specification 6.9.1.13.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. R. Calhoun
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavalles
Nuclear Safety Analysis Center
Palo Alto, California 94303

Mr. W. T. Cottle, NRC Inspector, Sequoyah

POOR ORIGINAL

APR 2 5/11

8010080 385

S