

NOV 24 1980

TIC

**Florida Power**  
CORPORATION

November 19, 1980

File: 3-0-3-a-4  
#3-110-11

Mr. J. P. O'Reilly  
Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Suite 3100  
101 Marietta Street  
Atlanta, GA 30303

RECEIVED  
NOV 24 1980  
U.S. NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
SUITE 3100  
101 MARIETTA STREET  
ATLANTA, GEORGIA 30303

SUBJECT: Crystal River Unit 3  
Docket No. 50-302  
Operating License No. DPR-72  
IE Bulletin 80-23: FAILURES OF SOLENOID VALVES MANUFACTURED  
BY VALCOR ENGINEERING CORPORATION


Dear Mr. O'Reilly:

In response to the subject bulletin, we have determined that no Valcor Solenoid Valves having P/Ns V70900-21-1 or -3 are in use in safety-related applications at Crystal River Unit 3. Therefore, no additional information will be provided.

As you requested, the manhours expended on this bulletin in conduct of review and preparation of the report is 20 manhours.

Very truly yours,

FLOPIDA POWER CORPORATION



Patsy Y. Baynard  
Manager  
Nuclear Support Services

Lobo(W02)D-8-3

cc: Director  
Office of Inspection and Enforcement  
Division of Reactor Operations Inspection  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8012240 232 OFFICIAL COPY