

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK:

0	1	N	Y	J	A	F	1	2	0	0	-	0	0	0	0	-	0	0	0	3	4	1	1	1	1	4	5
LICENSEE CODE								LICENSE NUMBER												LICENSE TYPE				CAT 58			

CON'T	0	1	REPORT SOURCE	L	6	0	5	0	0	0	3	3	3	7	1	2	1	0	8	0	8	0	1	0	9	8	1	9
				DOCKET NUMBER										EVENT DATE						REPORT DATE								

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2	During normal operation a heat detector associated with the fire protection system																											
0	3	for reactor core isolation failed when required to be operable by TS 3.12.E. A																											
0	4	fire watch was immediately established as required by TS 3.12.E.1.b. No significant																											
0	5	hazard existed.																											
0	6																												
0	7																												
0	8																												

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE		REVISION NO.	
A	B	A	E	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	2		
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							
8	0	0	9	2	0	3	L	Z	Z	9	9	9					
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-1 FORM SUB.		DISCOVERY DESCRIPTION			
C	Z	Z	Z	Z	Z	0	0	0	0	N	N	Z	Z	Operator Observation			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	The heat detector failed due to an internal short believed to have been caused by																											
1	1	personnel working fire protection modifications in the area. Following replacement																											
1	2	of the detector the system was tested with satisfactory results on the following																											
1	3	day. No additional action is required.																											

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
E	1	0	0	NA	A	Operator Observation			
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
Z	Z	Z	NA	NA	NA				
PERSONNEL EXPOSURES		TYPE		DESCRIPTION					
0	0	0	Z	NA					
PERSONNEL INJURIES		TYPE		DESCRIPTION					
0	0	0	NA						
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
Z	Z	Z	NA						
PUBLCITY ISSUED		DESCRIPTION				NRC USE ONLY			
N	Z	Z	NA						

810120 310 W. Verne Childs (315) 342-3840 X207