

Tic
POOR ORIGINAL

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, Box 15830, Sacramento, California 95813; (916) 452-3211

December 3, 1980



Mr. R. H. Engelken, Director
Region V, Office of Inspection
and Enforcement
U.S. Nuclear Regulatory Commission
Suite 202, Walnut Creek Plaza
1990 North California Boulevard
Walnut Creek, California 94596

Docket 50-312
Rancho Seco Nuclear Generating
Station, Unit No. 1
IE Bulletin 79-03A
Longitudinal Weld Defects in
ASME-SA-312 Type 304 Stainless Steel Pipe

Dear Mr. Engelken:

The District's July 30, 1980, response to this bulletin said that no ASME-SA-312 type 304 pipe was used in safety related systems at Rancho Seco. In accordance with Item 2 of the bulletin, we would like to confirm that no SA-312 or A-312 Type 300 series fusion welded pipe has been used, or is planned for use in safety related systems at Rancho Seco.

Should you have any questions, please contact Larry Smith on (916) 452-3211.

Sincerely,

John J. Mattimoe

John J. Mattimoe
Assistant General Manager
and Chief Engineer

cc: NRC Office of Inspection
and Enforcement
Division of Construction
Inspection
Washington, D.C. 20555

810 1120561