

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

December 30, 1980

Docket Nos. 50-213

50-245

A00898

Director of Nuclear Reactor Regulation
Attn: Mr. Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

- References:
- (1) D. L. Ziemann letter to W. G. Council dated February 15, 1980.
 - (2) W. G. Council letter to D. L. Ziemann dated April 29, 1980.
 - (3) W. G. Council letter to D. G. Eisenhower dated October 31, 1980
(Docket No. 50-213).
 - (4) W. G. Council letter to D. G. Eisenhower dated October 31, 1980
(Docket No. 50-245).

Gentlemen:

Haddam Neck Plant
Millstone Nuclear Power Station, Unit No. 1
Environmental Qualification of Electrical Equipment

In Reference (1), the NRC Staff transmitted guidance for performing an evaluation of the environmental qualification of Class 1E electrical equipment. In Appendix A to Enclosure 1 of Reference (1), the Staff identified typical systems utilized to perform the necessary functions of emergency reactor shutdown, containment isolation, reactor core cooling, containment and reactor heat removal, and prevention of significant releases of radioactive material to the environment.

Connecticut Yankee Atomic Power Company's (CYAPCO's) and Northeast Nuclear Energy Company's (NNECO's) initial response to Appendix A was provided in Reference (2), wherein plant-specific equipment and functions necessary to achieve the above-identified objectives were identified.

As a result of numerous changes in interpretations of Staff guidance, which are documented in References (3) and (4), the Reference (2) information is hereby superseded by the revised lists provided as Attachments 1 and 2 for the Haddam Neck Plant and Millstone Unit No. 1, respectively. These attachments were not a part of the Staff's request for information by November 1, 1980, but they are being docketed to update Reference (2) and to more accurately reflect the content of References (3) and (4).

810 1130 138


P

Included as Attachment 3 to this submittal are revised pages to Reference (4). The majority of the changes are editorial in nature and do not substantively alter the information provided in Reference (4). In one instance additional qualification documentation is being provided rather than justification for its absence.

It is emphasized that the attached information is not vital to the development of the Staff's Safety Evaluation Report scheduled for February 1, 1981.

Very truly yours,

CONNECTICUT YANKEE ATOMIC POWER COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in dark ink, appearing to read "W. G. Council", is written over a horizontal line.

W. G. Council
Senior Vice President

ATTACHMENT 1

HADDAM NECK PLANT

ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT

December, 1980

RESPONSE TO APPENDIX A

Typical Equipment/Functions From Appendix A

Engineered Safeguards Actuation

Reactor Protection

Containment Isolation

Main Steamline Isolation

Main Feedwater Shutdown and
Isolation

Emergency Power

Plant Specific (CY) Equipment/Functions

Pressurizer pressure transmitters,
containment pressure switches
and associated 4A/4B lockout relays.

Reactor Protection System

CY has 39 automatic containment
isolation valves which are:

1. Air Operated Valves
2. Trip Valves
3. Flow Control Valves
4. Motor Operated Valves
5. Solenoid Operated Valves
6. Hand Indicating Control Valves

Main Steamline Isolation System

The main feedwater shutdown and
isolation is performed by:

1. Main Feedwater Regulation Valves
2. Back-up Motor Operated Valves

Diesel generators, 4160 V and 480 V
switchgear, 125 volt DC system,
120 V vital and semi-vital AC systems,
and their associated switchgear, raceway,
and cable.

Emergency Core Cooling

Emergency Core Cooling is performed by:

1. High Pressure Safety Injection
2. Low Pressure Safety Injection
3. Charging Pumps
4. Residual Heat Removal System
5. Heat Trace System

Containment Heat Removal

Containment heat removal consists of the following systems:

1. Air Recirculation System
2. Adams Filter
3. Spray System (Back-Up)

Containment Fission Product Removal

Filtration System

Containment Combustible Gas Control

Hydrogen Purge System (Manual System)

Auxiliary Feedwater

Auxiliary Feedwater System

Containment Ventilation

Air Recirculation System, Purge System

Containment Radiation Monitoring

Containment radiation monitoring consists of the following:

1. Reactor Containment Air Particulate Monitor
2. Reactor Containment Gas Monitor

Control Room Habitability System

The control room ventilation and smoke ejection systems.

Ventilation for Areas Containing
Safety Equipment

The heating and ventilation systems at
CY are not Category I. The environments
will be determined assuming its failure.

Component Cooling

Component Cooling System

Service Water

Service Water System

Emergency Shutdown

Emergency shutdown is achieved by:

1. Pressure Control System
2. Reactor Coolant System
3. Chemical & Volume Control System
4. Main Steam System
5. Primary Water Storage System
6. Auxiliary Feedwater System
7. Residual Heat Removal System
8. Component Cooling System
9. Service Water System

Post Accident Sampling & Monitoring

Sampling System

Radiation Monitoring

Radiation Monitoring System

Safety Related Display
Instrumentation

All instrumentation which displays
information used by operators for
essential decision making.

ATTACHMENT 2

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 1
ENVIRONMENTAL QUALIFICATION OF ELECTRICAL EQUIPMENT

December, 1980

RESPONSE TO APPENDIX A

| <u>Typical Equipment/Functions</u> <u>From Appendix A</u> | <u>Plant Specific (MP1)</u> <u>Equipment/Functions</u> |
|--|--|
| Engineered Safeguards Actuation | The following engineered safeguards systems are considered Category I and are actuated by independent Category I controls which are part of that system: <ol style="list-style-type: none">1. Emergency core cooling system2. Steam flow restrictors (passive system) |
| Reactor Protection | Reactor protection system |
| Containment Isolation | Primary containment isolation system |
| Steamline Isolation | Part of primary containment isolation system |
| Main Feedwater Shutdown and Isolation | MP1 utilizes Category I check valves to provide this function |
| Emergency Power | Gas turbine generator, Diesel generator, 4,160 and 480 volt switchgear, 120 volt vital and instrument AC systems, 125 volt DC system, and their associated switchgear, raceway and cable |
| Emergency Core Cooling | Core spray system Low pressure coolant injection/CTMT cooling system Automatic depressurization system Feedwater coolant injection system Isolation condenser system |
| Containment Heat Removal | LPCI/containment cooling system Emergency service water system |
| Containment Fission Product Removal | Atmospheric control system Standby gas treatment system |
| Containment Combustible Gas Control | Atmospheric control system (inerting of containment) |
| Auxiliary Feedwater | MP1 does not have an auxiliary feedwater system. The condensate storage and transfer system provides alternate water for the FWCI system |

Containment Ventilation

The containment ventilation system is not Category I at MP1. It is not required to mitigate the consequences of a LOCA or MSLB accident. (There is nothing in the drywell that requires ventilation for the above.)

Containment Radiation Monitoring

Process radiation monitoring system

Control Room Habitability

The control room heating and ventilation system.

Ventilation for Areas Containing Safety Equipment

The turbine building heating and ventilation system at MP1 is not Category I. The environments will be determined assuming its failure.

Component Cooling

Service water system

Service Water

Service water system

Emergency Shutdown

LPCI system

Isolation condenser system

Automatic depressurization system

Post Accident Sampling and Monitoring

Process radiation monitoring system.

The sample system is not Category I at MP1. It is isolated by the primary containment isolation system, which is Category I.

Radiation Monitoring

Process radiation monitoring system

Safety-Related Display Instrumentation

All instrumentation which displays information used by operators for essential decision making (as called out in the emergency operating procedures for the LOCA, LNP, and MSLB accidents; i.e., level, pressure, temperature, flow indication, valve and breaker position, etc.)

ATTACHMENT 3

MILLSTONE NUCLEAR POWER STATION, UNIT NO. 1
ELECTRICAL EQUIPMENT ENVIRONMENTAL QUALIFICATION
REVISED SYSTEM COMPONENT EVALUATION WORK SHEETS
SUMMARY SHEETS

December, 1980

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page I-1
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------------|------------------------|-----------------------|--------------------|-------|--------------|-------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: ADS Plant ID No.: 1-MS-3A (203-3A) Component: Solenoid Valve Manufacturer: Target Rock Model Number: 1/2 SMS-A-01 (SN #100) Function: Actuate relief valves Accuracy: NA Service: Pressure Relief of Rx Location: Drywell-R1 Flood Level Elev: 1'-8" Above Flood Level: Yes X No | Operating Time | 90 min. | 92 hrs. | S-3 | Q-3 | vendor data | |
| | Temperature (°F) | Profile 1 | 347°F | S-1 | Q-3 | vendor data | |
| | Pressure (PSIA) | Profile 2 | 65 psig | S-1 | Q-3 | vendor data | |
| | Relative Humidity(%) | 100% | 100% | S-1 | Q-3 | vendor data | |
| | Chemical Spray | Demin H ₂ O | NR | NR | NR | NR | |
| | Radiation | 4.3 x 10 ⁷ | 1.3 x 10 ⁷ | S-4 | Q-3 | vendor data | see sum. sht. I-1 |
| | Aging | 40 yrs. | 285°F 480 hrs. | life of plant | Q-3 | vendor data | |
| | Submergence | N/A | N/A | S-6 | N/A | N/A | |

M-H

*Documentation References:
See attached reference list.

Notes: 1-MS-3B,C,D,E & F

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page I-6
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|----------------------|------------------------|---------|--------------------|-------|--------------|-------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: PCI Plant ID No.: 1-SM-1 (220-44) Component: Solenoid Valve Manufacture: Aktomatic Model Number: 15-527 Function: Actuate Rx loop sample valve Accuracy: NA Service: CTMT Isolation Location: Drywell-R1 Flood Level Elev: 1'-8" Above Flood Level: Yes X No | Operating Time | 5.5 sec. | -- | S-5 | Q-3 | vendor data | see sum. sht. I-6 |
| | Temperature (°F) | Profile 1 | >300F | S-1 | Q-28 | vendor data | see sum. sht. I-6 |
| | Pressure (PSIA) | Profile 2 | 30 psig | S-1 | Q-28 | vendor data | |
| | Relative Humidity(%) | 100% | | S-1 | | | see sum. sht. I-6 |
| | Chemical Spray | Demin H ₂ O | NR | NR | NR | NR | |
| | Radiation | 1.1 x 10 ⁷ | | S-4 | | | see sum. sht. I-6 |
| | Aging | 40 yrs. | | life of plant | | | see sum. sht. I-6 |
| | Submergence | N/A | N/A | S-6 | N/A | N/A | |

M-H

*Documentation References:

See attached list.

Notes:

Facility: Millstone Nuclear Pr. Sta.

Unit: One

Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page I-7

Rev. 5

Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------|-----------------------|--------------------|---------------|--------------|-------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: PCI Plant ID No.: 1-SM-2 Component: (220-45) Solenoid valve Manufacturer: Atkomatic Model Number: 15-527 Function: Actuate Rx loop sample valve Accuracy: NA Service: CTMT Isolation Location: Rx Building - R17 | Operating Time | 5.5 sec. | -- | S-5 | | |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| Chemical Spray Radiation Aging | | | | | | |
| | | 1.3 X 10 ⁶ | | S-4 | | see sum. sht. I-7 |
| | | 40 yrs. | | life of plant | | see sum. sht. I-7 |
| Flood Level Elev: NA Above Flood Level: Yes No | Submergence | | | | | |

M-H

*Documentation References:

See attached list.

Notes:

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT: 1-SM-2 Solenoid Valves

MANUFACTURER: Atkomatic Model 15-527

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Primary containment isolation.
2. The valves are redundant to other safety related equipment which is not simultaneously exposed to a harsh environment.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page I-9
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|------------------------------|-----------------------|-------|--------------------|-------|--------------|----------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: ATMOS. Cont. Plant ID No.: 1-AC-11 (v12-11) Component: Solenoid Valve Manufacture: ASCO Model Number: LB831615 Function: Actuate cntl. vent valves Accuracy: NA Service: CTMT Isolation Location: Reactor building-R6,R8 | Operating Time | 11 sec. | | S-5 | | | see sum. sht. I-9 |
| | Temperature (°F) | | | | | | |
| | Pressure (PSIA) | | | | | | |
| | Relative Humidity (%) | | | | | | |
| | Chemical Spray | | | | | | |
| | Radiation | 1.3 x 10 ⁶ | | S-4 | | | see sum. sht. I-9 |
| | Aging | 40 yrs. | | life of plant | | | see sum. sht. I-9 |
| Flood Level Elev: NA Above Flood Level: Yes No | Submergence | | | | | | |

M-H

*Documentation References:
See attached list.

Notes:

1-AC-6
1-AC-5
1-AC-4
1-AC-10

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT: 1-CU-2A Solenoid Valves

MANUFACTURER: ASCO Model HT 8320

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Primary containment isolation.
2. The valves are redundant to other safety related equipment which is not simultaneously exposed to a harsh environment.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. The valve is normally closed and stay closed.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page II-3
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------|-----------------------|-------|--------------------|-------|--------------|----------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: FWCI Plant ID No.: 1-MW-96A (V7-143) Component: Motor Operator Manufacture: Teledyne Model Number: T-4-25 Function: Emergency condensate transfer pump discharge valve Accuracy: NA Service: Fdwtr. supply Location: Reactor Building R6 | Operating Time | Continuous | | S-3 | | | See Summ. Sheet II-3 |
| | Temperature (°F) | | | | | | |
| | Pressure (PSIA) | | | | | | |
| | Relative Humidity (%) | | | | | | |
| | Chemical Spray | | | | | | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | | See Summ. Sheet II-3 |
| | Aging | 40 Years | | Life of Plant | | | See Summ. Sheet II-3 |
| Flood Level Elev: NA Above Flood Level: Yes No | Submergence | | | | | | |

M-H

*Documentation References:
 See attached list

Notes:
 S.N. #11947

SUMMARY SHEET NO. II-6

SCEW SHEET NO. II-6

REV. 5 11-24-80

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-LP-15A & B M.O. Valve

MANUFACTURER: Teledyne Model T40-80

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION FOR CONTINUED OPERATION:

1. Primary Containment Cooling during LOCA, ONLY.
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-LP-16A & B M.O. Valve

MANUFACTURER: Teledyne Model T4-25

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Primary Containment Cooling during LOCA ONLY.
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious effects resulting from these parameters are time dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page II-9
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|----------------------|-------------------|-------|--------------------|-------|--------------|----------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Core Spray Plant ID No.: 1-CS-4A (V10-13A) Component: Motor operator Manufacture: Teledyne Model Number: T-10-40 Function: Core Spray Injection Valve Accuracy: N/A Service: Emergency Core Cooling Location: Rx Bldg. R17, R19 | Operating Time | 30 sec. | | S-3 | | | See Summ. Sheet II-9 |
| | Temperature (°F) | Profile 6,9 | | S-2 | | | See Summ. Sheet II-9 |
| | Pressure (PSIA) | Profile 10 | | S-2 | | | See Summ. Sheet II-9 |
| | Relative Humidity(%) | Profile 8 | | S-2 | | | See Summ. Sheet II-9 |
| | Chemical Spray | N/A | | | | | |
| | Radiation | 1.3×10^6 | | S-4 | | | See Summ. Sheet II-9 |
| | Aging | 40 Years | | Life of Plant | | | See Summ. Sheet II-9 |
| Flood Level Elev: 1'-8" Above Flood Level: Yes X No | Submergence | N/A | N/A | | | | |

M-H

*Documentation References:
 See attached list.

Notes:
 1-CS-4A

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page II-II
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|-----------------------------|-------------------|-------|--------------------|-------|--------------|--------------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Service Water Plant ID No.: I-SW-9 (V4-21) Component: Motor operator Manufacture: Limitorque Model Number: SMB-0 Function: Isolation Valve for Non-Essential Equip. Accuracy: NA Service: Emerg. water Location: Turbine Building-T5C Flood Level Elev: NA Above Flood Level: Yes No | Operating Time | < 30 sec. | | S-3 | | | See Summ. Sheet II-11 |
| | Temperature (°F) | Profile 12 | | S-2 | | | See Summ. Sheet II-11 |
| | Pressure (PSIA) | Profile 13 | | S-2 | | | See Summ. Sheet II-11 |
| | Relative Humidity(%) | Profile 14 | | S-2 | | | See Summ. Sheet II-11 |
| | Chemical Spray | N/A | N/A | N/A | N/A | N/A | |
| | Radiation | 2.8×10^4 | | S-4 | | | See Summ. Sheet II-11 |
| | Aging | 40 Years | | Life of Plant | | | See Summ. Sheet II-11 |
| | Submergence | N/A | N/A | N/A | N/A | N/A | |

*Documentation References:
See attached list.

Notes:

M-H

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page II-13

Rev. 5

Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|-----------------------------|-------------------------|-------|--------------------|-------|--------------|-----------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Isolation Cond. Plant ID No.: 1-IC-4 (VI6-4) Component: Valve Manufacture: Teledyne Model Number: T-10-60 Function: Isolation Valve Accuracy: N/A Service: Ctmt. Isolation Location: Drywell R1 | Operating Time | 21 sec. | | S-5 | | | See Summ. Sheet II-13 |
| | Temperature (°F) | Profile 1 | | S-1 | | | See Summ. Sheet II-13 |
| | Pressure (PSIA) | Profile 2 | | S-1 | | | See Summ. Sheet II-13 |
| | Relative Humidity(%) | 100% | | S-1 | | | See Summ. Sheet II-13 |
| | Chemical Spray | Demin. H ₂ O | N/A | N/A | N/A | N/A | |
| | Radiation | 1.1 x 10 ⁷ | | S-4 | | | See Summ. Sheet II-13 |
| | Aging | 40 Years | | Life of Plant | | | See Summ. Sheet II-13 |
| Flood Level Elev: 1'8" Above Flood Level: Yes X No | Submergence | N/A | N/A | S-6 | N/A | N/A | |

M-H

*Documentation References:

See attached list.

Notes:

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

1-MS-5 M.O. Valve

MANUFACTURER:

Limitorque Model SMB-000

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Primary Containment Isolation for a MSLB.
2. This valve is normally closed and stays closed. It is used to drain steam lines to the condenser only when less than 5% power (start-up and shut down).
3. This valve is redundant to other safety related equipment which is not simultaneously exposed to a harsh environment.
4. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page 11-15
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REP* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|-----------------------|-----------------------|--------------------|---------------|--------------|-----------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: PCI Plant ID No.: 1-CU-5 (VII-4) Component: Motor Operator Manufacturer: Teledyne Model Number: T-4-15 Function: Reactor Clean Up Pump Suction Valve Accuracy: NA Service: Cmt. Isolation Location: Reactor Building-R17 | Operating Time | 20 sec. | | S-5 | | See Summ. Sheet II-15 |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| | Chemical Spray | | | | | |
| Flood Level Elev: NA Above Flood Level: Yes | Radiation | 1.3 x 10 ⁶ | | S-4 | | See Summ. Sheet II-15 |
| | Aging | 40 Years | | Life of Plant | | See Summ. Sheet II-15 |
| | Submergence | | | | | |
| | | | | | | M-H |

Notes:

*Documentation References:
 See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

1-MS-6 M.O. Valve

MANUFACTURER:

Limitorque Model SMB-000

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Primary containment isolation for a MSLB.
2. This valve is normally closed and stays closed. It is used to drain steam lines to the condenser only when less than 5% power (start-up and shutdown).
3. This valve is redundant to other safety related equipment which is not simultaneously exposed to a harsh environment.
4. **This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.**
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-LP-14A & B M.O. Valves

MANUFACTURER: Teledyne Model T40-10

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Suppression Chamber (Torus) Cooling during LOCA, only.
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-LP-13A & B M.O. Valves

MANUFACTURER: Teledyne Model T40-10

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Suppression Chamber (Torus) Cooling during LOCA, only.
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-LP-43A & B M.O. Valve

MANUFACTURER: Teledyne Model T10-25

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Emergency Core Cooling Test Valve.
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious effects resulting from these parameters are time dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-LP-7A & B M.O. Valves

MANUFACTURER: Teledyne Model T10-60

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Emergency Core Cooling during LOCA.
2. The valves are in the heat exchanger by-pass line and any malfunction is inconsequential.
3. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-LP-44A & B M.O. Valve

MANUFACTURER: Teledyne Model T40-100

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Emergency Core Cooling Test Valve.
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT: 1-CS-21A & B M.O. Valve

MANUFACTURER: Teledyne Model T4-10

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Emergency Core Cooling Test Valve.
2. A normally closed and stays closed valve except during a 30 second surveillance operation.
3. Malfunction of these valves is only credible upon the coincident happenings of:
 - a. The Iso-Condenser Break
 - b. An LNP
 - c. Failure of the Diesel Generator
 - d. Surveillance Testing in progress
4. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page III-5
Rev. 4
Date 11-1-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEM |
|---|-----------------------|-----------------------|----------|--------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Various Plant ID No.: Component: Terminal block Manufacturer: G.E. Model Number: CR151 Function: Terminations Accuracy: NA Service: Various Location: Rx bldg. | Operating Time | Continuous | 8 days | S-3 | Q-11 | | |
| | Temperature (°F) | Profiles 6,9 | 340°F | S-1 | Q-11 | | |
| | Pressure (PSIA) | Profile 10 | 103 psig | S-1 | Q-11 | | |
| | Relative Humidity (%) | Profile 8 | 100% | S-1 | Q-11 | | |
| | Chemical Spray | NA | NA | NA | NA | | see sum. sht. III-5 |
| Flood Level Elev: NA Above Flood Level: Yes No | Radiation | 2.1 x 10 ⁶ | | S-4 | | | see sum. sht. III-5 |
| | Aging | 40 yrs. | | life of plant | | | |
| | Submergence | NA | NA | NA | NA | | M.H |

Notes: T. blocks located on instrument racks and misc. boxes.

*Documentation References:
See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

Cable

MANUFACTURER:

G. E. Vulkene

QUALIFICATION DISCREPANCY:

Lacks fully documented qualification test data for radiation.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Electric continuity.
2. In addition to the 4×10^7 rad exposure for which the samples were tested they were taken from a plant in service for 10 years. Thus the actual radiation exposure for 10 years of normal life should be included.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

Cable

MANUFACTURER:

G. E. Vulkene

QUALIFICATION DISCREPANCY:

Lacks fully documented qualification test data for radiation.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Electric continuity.
2. In addition to the 4×10^7 rad exposure for which the samples were tested they were taken from a plant in service for 10 years. Thus the actual radiation exposure for 10 years of normal life should be included.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page IV-10
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEM |
|---|-----------------------|-----------------------|-------|--------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Various Plant ID No.: K9-1 Component: Cable Manufacturer: G.E. | Operating Time | Continuous | | S-3 | | | see sum. sht. IV-10 |
| | Temperature (°F) | | | | | | |
| | Pressure (PSIA) | | | | | | |
| | Relative Humidity (%) | | | | | | |
| Model Number: Cu/Constantan Function: Elec. circuitry Accuracy: NA Service: Torus temp. | Chemical Spray | | NA | NA | NA | NA | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | | see sum. sht. IV-1C |
| | Aging | 40 yrs. | | Life of plant | | | see sum. sht. IV-10 |
| Flood Level Elev: Yes Above Flood Level: Yes | Submergence | NA | NA | S-6 | NA | NA | |

M-H

Notes: C1811T
 C1811U

*Documentation References:
 See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

Cable

MANUFACTURER:

GE

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Electric continuity.

Components are copper/constantan temperature elements which provide signals to a temperature recorder in control room.

This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in qualification documentation, concerns radiation and aging considerations. The detected affects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.

An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.

Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. Reference letter from Northeast Utilities to NRC Docket No. 50-245 dated June 20, 1980. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page IV-11
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|----------------------|------------------------|------------------------------------|--------------------|---------|-----------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: VARIOUS Plant ID No.: K1-16 Component: Cable Manufacture: G.E. Model Number: S1-58073 Function: Elec. circuitry Accuracy: NA Service: Ctmt. isolation Location: DRYWELL R1 Flood Level Elev: Above Flood Level: Yes No | Operating Time | Continuous | 96 hrs. | S-3 | Q-19,20 | test similarity | |
| | Temperature (°F) | Profile 1 | 340°F | S-1 | Q-19,20 | test similarity | |
| | Pressure (PSIA) | Profile 2 | 62 psig | S-1 | Q-19,20 | test similarity | |
| | Relative Humidity(%) | 100% | 100% | S-1 | Q-19,20 | test similarity | |
| | Chemical Spray | Demin H ₂ O | N/A | N/A | N/A | N/A | |
| | Radiation | 9.4 x 10 ⁷ | > 4 x 10 ⁷ | S-4 | Q-19,20 | test similarity | see sum. sht. IV-11 |
| | Aging | 40 yrs. | 268 ⁰ /54 days + 10 yr. | life of plant | Q-19,20 | test similarity | |
| | Submergence | N/A | N/A | N/A | N/A | N/A | |

M-H

*Documentation References:
See attached list.

Notes: K1-16=1/C #4(62 vulkene)
C1460
C1443

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

Cable

MANUFACTURER:

G. E. Vulkene

QUALIFICATION DISCREPANCY:

Lacks fully documented qualification test data for radiation.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Electric continuity.
2. In addition to the 4×10^7 rad exposure for which samples were tested, they were taken from a plant in service for 10 years. Thus the actual radiation exposure for 10 years of normal life should be included.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
5. Due to the desirability of long term operability OF THIS EQUIPMENT, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page IV-13
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEM: |
|--|-----------------------|-----------------------|-----------------------|--------------------|-------|-----------------|-------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Various Plant ID No.: K2-2 Component: Cable Manufacture: G.E. Model Number: SI-58081 Function: Elec. circuitry Accuracy: NA Service: Various Location: Steam tunnel R-4 Flood Level Elev: NA Above Flood Level: Yes No | Operating Time | Continuous | 500 hrs. | S-3 | Q-29 | similarity test | |
| | Temperature (°F) | Profile 3 | 90°C (202°F) | S-2 | Q-29 | similarity test | |
| | Pressure (PSIA) | Profile 4 | 40 psig | S-2 | Q-29 | similarity test | |
| | Relative Humidity (%) | Profile 5 | 100% | S-2 | Q-29 | similarity test | |
| | Chemical Spray | NA | NA | NA | NA | NA | |
| | Radiation | 2.9 x 10 ⁶ | 5.4 x 10 ⁷ | S-4 | Q-29 | similarity test | |
| | Aging | 40 yrs. | 40 yrs. | life of plant | Q-29 | similarity test | |
| | Submergence | NA | NA | NA | NA | NA | |

M-H

*Documentation References:
See attached list.

Notes: K2-3
K2-5
K2-21
See attached list.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page IV-20
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEM: |
|--|----------------------|-----------------------|-------------------------|--------------------|--------|--------------|-------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Various Plant ID No.: Various Component: Cable Manufacture: G.E. Model Number: SI-58145 Function: Elec. circuitry Accuracy: NA Service: Location: Rx Bldg. | Operating Time | Continuous | 96 hrs. | S-3 | Q19,20 | test | |
| | Temperature (°F) | Profiles 6,9 | 340°? | S-2 | Q19,20 | test | |
| | Pressure (PSIA) | Profile 10 | 62 psig | S-2 | Q19,20 | test | |
| | Relative Humidity(%) | Profile 8 | 100% | S-2 | Q19,20 | test | |
| | Chemical Spray | NA | NA | NA | NA | NA | |
| | Radiation | 2.8 x 10 ⁴ | > 4 x 10 ⁷ | S-4 | Q19,20 | test | |
| | Aging | 40 yrs. | 268°F/54 days + 10 yrs. | life of plant | Q19,20 | test | |
| Flood Level Elev: Above Flood Level: Yes No | Submergence | NA | NA | NA | NA | NA | |

M-H

*Documentation References:
 See attached list

Notes:

SI-58145=30 mil vulk./45 mil neop.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page IV-23
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEM: |
|--|-----------------------|-----------------------|-----------------------|--------------------|-------|-----------------|-------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Various Plant ID No.: Various Component: Cable Manufacture: G.E. Model Number: SI-58081 Function: Elec. Circuitry Accuracy: N/A Service: Various Location: T. bldg. Flood Level Elev: Above Flood Level: Yes No | Operating Time | Continuous | 500 hrs | S-3 | Q-29 | Similarity Test | |
| | Temperature (°F) | Profile 12 | 95°C | S-2 | Q-29 | Similarity Test | |
| | Pressure (PSIA) | Profile 13 | 40 PSIG | S-2 | Q-29 | Similarity Test | |
| | Relative Humidity (%) | Profile 14 | 100% | S-2 | Q-29 | Similarity Test | |
| | Chemical Spray | NA | NA | NA | NA | NA | |
| | Radiation | 2.8 x 10 ⁴ | 5.4 X 10 ⁷ | S-4 | Q-29 | Similarity Test | |
| | Aging | 40 yrs. | 40 yrs. | life of plant | Q-29 | Similarity Test | |
| | Submergence | NA | NA | NA | NA | NA | |

M-H

*Documentation References:

See attached list.

Notes:

SI-58081=30PE/15PVC/45PVC

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page V-4
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------------|-----------------------|-------|--------------------|-------|--------------|-----------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: ISO Cond. Plant ID No.: 1-IC-6 (1301-17) Component: Limit switch Manufacture: Micro Model Number: DTF2-2RN2-RN Function: Valve Position Accuracy: N/A Service: Containment Isolation Location: R14 Reactor Building Flood Level Elev: N/A Above Flood Level: Yes No | Operating Time | Continuous | | S-3 | | | See Sum. Sheet V-4 |
| | Temperature (°F) | Profile 6 & 9 | | S-2 | | | See Sum. Sheet V-4 |
| | Pressure (PSIA) | Profile 10 | | S-2 | | | See Sum. Sheet V-4 |
| | Relative Humidity(%) | Profile 8 | | S-2 | | | See Sum. Sheet V-4 |
| | Chemical Spray | N/A | N/A | N/A | N/A | N/A | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | | See Sum. Sheet V-4 |
| | Aging | 40 Years | | Life of Plant | | | |
| | Submergence | N/A | N/A | N/A | N/A | N/A | |

*Documentation References:
See attached list.

Notes:

1-IC-7 (1301-20)

M-H

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

1-SS-3, 4, 13 & 14 Limit Switches

MANUFACTURER:

Micro Switch #DTF2-2RN

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page V-12
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF. | | QUAL. METHOD | OUTSTANDING ITEM |
|--|-----------------------|-----------------------|-------|--------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Atmos. control Plant ID No.: 1-AC-5 Component: Limit switch Manufacturer: Micro | Operating Time | Continuous | | S-3 | | | See Sum. Sheet V-12 |
| | Temperature (°F) | | | | | | |
| | Pressure (PSIA) | | | | | | |
| | Relative Humidity (%) | | | | | | |
| Model Number: BAF1-2RN2 Function: Valve position Accuracy: NA Service: Crmt. isolation | Chemical Spray | | | | | | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | | See Sum. Sheet V-12 |
| | Aging | 40 Years | | Life of Plant | | | See Sum. Sheet V-12 |
| Flood Level Elev: NA Above Flood Level: Yes NO | Submergence | | | | | | M-H |

Notes:

*Documentation References:

See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

1-AC-5 Limit Switch

MANUFACTURER:

Micro Model BAF1-2RN2

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

1-AC-6 & 11 Limit Switches

MANUFACTURER:

Micro Model DTF2-2RN2

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

1-AC-7 & 8 Limit Switches

MANUFACTURER:

Micro Model DTF2-2RN2

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious effects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page V-15
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REF.* | | QUAL. METHOD | OUTSTANDING ITEM: |
|--|-----------------------|-----------------------|---------------------|---------------|--------------|------------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: Atmos. control Plant ID No.: 1-AC-9 (1601-24) Component: Limit switch | Operating Time | Continuous | | S-3 | | See Sum. Sheet V-15 |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| Model Number: 51MLT 6022 Function: Valve position Accuracy: NA Service: Cmt. isolation | Chemical Spray | | | | | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | See Sum. Sheet V-15 |
| | Aging | 40 yrs. | | Life of Plant | | See Sum. Sheet V-15 |
| Flood Level Elev: Above Flood Level: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | Submergence | | | | | |

M-H

Notes:

*Documentation References:

See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

1-AC-9 Limit Switch

MANUFACTURER:

Micro Model 51MLT-6022

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.

Unit: One

Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page V-16
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEM: |
|--|-----------------------|-----------------------|-------|---------------|--------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | Qual. | | |
| System: Atmos. control Plant ID No.: 1-AC-10(1601-28) Component: Limit switch | Operating Time | Continuous | | S-3 | | | | See Sum. Sheet V-16 |
| | Temperature (°F) | | | | | | | |
| | Pressure (PSIA) | | | | | | | |
| | Relative Humidity (%) | | | | | | | |
| Model Number: BAF1-2RN2 Function: Valve position Accuracy: NA Service: Ctmt. Isolation | Chemical Spray | | | | | | | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | | | See Sum. Sheet V-16 |
| | Aging | 40 yrs. | | Life of Plant | | | | See Sum. Sheet V-16 |
| Flood Level Elev: NA Above Flood Level: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> | Submergence | | | | | | | M-H |

Notes:

*Documentation References:

See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

1-AC-10 Limit Switch

MANUFACTURER:

Micro Model BAF1-2RN2

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious effects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page V-17
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|-----------------------|-----------------------|--------------------|---------------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: Atmos. Control Plant ID No.: 1-AC-12 Component: Unit Switch Manufacture: Micro | Operating Time | Continuous | | S-3 | | See Sum. Sheet V-17 |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| Model Number: 51ML76922 Function: Valve Position Accuracy: N/A Service: Containment Isolation Location: R6 Reactor Building | Chemical Spray | | | | | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | See Sum. Sheet V-17 |
| | Aging | 40 Years | | Life of Plant | | See Sum. Sheet V-17 |
| Flood Level Elev. Above Flood Level: Yes No | Submergence | | | | | |

M-H

Notes:

*Documentation References:

See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

1-AC-12 Limit Switch

MANUFACTURER:

Micro Model 51ML7-6922

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious effects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

SYSTEM COMPONENT EVALUATION WORK SHEET

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|-----------------------|-------------------|--------------------|---------------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: Atmos. Control Plant ID No.: 1-AC-17 (1601-6) Component: Limit Switch Manufacturer: Micro | Operating Time | Continuous | | S-3 | | See Sum. Sheet V-18 |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| Model Number: BAF1-2RN2 Function: Valve Position Accuracy: N/A Service: Containment Isolation Location: Rx Bldg. R8 | Chemical Spray | | | | | |
| | Radiation | 2.1×10^6 | | S-4 | | See Sum. Sheet V-18 |
| | Aging | 40 Years | | Life of Plant | | See Sum. Sheet V-18 |
| | Submergence | | | | | |
| Flood Level Elev: N/A Above Flood Level: Yes No | | | | | | M-H |

Notes:

*Documentation References:
See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

1-AC-17 Limit Switch

MANUFACTURER:

Micro Model BAF1-2RN2

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page V-19
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|-----------------------|-----------------------|--------------------|---------------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: Atmos. Control Plant ID No.: 1601-8A Component: Limit Switch Manufacturer: Micro Model Number: BAF1-2RN2 Function: Volve Position Accuracy: N/A Service: Containment Isolation Location: Rx Bldg. R10 | Operating Time | Continuous | | S-3 | | See Sum. Sheet V-19 |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| | Chemical Spray | | | | | |
| Flood Level Elev: Above Flood Level: Yes No | Radiation | 2.1 x 10 ⁶ | | S-4 | | See Sum. Sheet V-19 |
| | Aging | 40 Years | | Life of Plant | | See Sum. Sheet V-19 |
| | Submergence | | | | | |

M-H

Notes:

1601-8B

*Documentation References:

See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

1601-8A & B Limit Switches

MANUFACTURER:

Micro Model BAF1-2RN2

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious effects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page V-21
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------|-----------------------|--------------------|---------------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: Atmos. Control Plant ID No.: 1-AC-4 (1601-19) Component: Limit Switch Manufacture: Micro | Operating Time | Continuous | | S-3 | | See Sum. Sheet V-21 |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| Model Number: BAF1-2RN2 Function: Valve Position Accuracy: N/A Service: Containment Isolation Location: Rx Bldg. R8 | Chemical Spray | | | | | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | See Sum. Sheet V-21 |
| | Aging | 40 Years | | Life of Plant | | See Sum. Sheet V-21 |
| | Submergence | | | | | |
| Flood Level Elev: Above Flood Level: Yes No | | | | | | |

M-H

Notes:

*Documentation References:

See attached list.

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

1-AC-4 Limit Switch

MANUFACTURER:

Micro Model BAF1-2RN2

QUALIFICATION DISCREPANCY:

Lacks documented qualification Test Data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Valve Position Indication
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious affects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
4. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
5. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page VI-4
 Rev. 5
 Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|----------------------|-----------------------|-------|--------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: FWCI Plant ID No.: M7-28 Component: Pump Motor Manufacture: General Electric Model Number: 5K818841A134 Function: Emerg. Cond. Transf. Accuracy: N/A Service: Replenish Cond. H ₂ O Location: Rx Bldg. R6 Flood Level Elev: N/A Above Flood Level: Yes No | Operating Time | Continuous | | S-3 | | | See Summ. Sht. VI-4 |
| | Temperature (°F) | | | | | | |
| | Pressure (PSIA) | | | | | | |
| | Relative Humidity(%) | | | | | | |
| | Chemical Spray | | | | | | |
| | Radiation | 2.1 X 10 ⁶ | | S-2 | | | See Summ. Sht. VI-4 |
| | Aging | 40 yrs. | | life of Plant | | | |
| | Submergence | | | | | | |

*Documentation References:

See attached list.

Notes:

EQUIPMENT ENVIRONMENTAL QUALIFICATION

DISCREPANT EQUIPMENT SUMMARY

MILLSTONE UNIT 1

EQUIPMENT:

Emergency Condensate Transfer Pump M7-28

MANUFACTURER:

GE Model 5K818841A134

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data for radiation & aging.

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Emergency Core Cooling water supply during LOCA.
2. This equipment is not required to operate during a HELB outside containment. For a LOCA, the only deficiency in the qualification documentation concerns radiation and aging considerations. The deleterious effects resulting from these parameters are time-dependent phenomena which could not reasonably be expected to result in equipment failure in the short term.
3. An independent laboratory has been retained by NUSCO to provide radiation and time/temperature aging analysis for this equipment.
4. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page VI-6
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|--|------------------------------|-----------------------|---------|--------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: LPCI Plant ID No.: M8-75A (1502A) Component: Pump (Motor) 500 H.P. Manufacture: G.E. Model Number: 5K6329XC3A Function: Emer. Core/CTMT. Cooling pumps Accuracy: NA Service: Emerg. core cooling Location: Rx Bldg. R7 & R9 Flood Level Elev: NA Above Flood Level: Yes No | Operating Time | continuous | 12 hrs. | S-3 | Q-18 | Test | |
| | Temperature (°F) | Profiles 6,9 | 212°F | S-2 | Q-18 | Test | |
| | Pressure (PSIA) | Profile 10 | 0 psig | S-2 | Q-18 | Test | |
| | Relative Humidity (%) | Profile 8 | 100% | S-2 | Q-18 | Test | |
| | Chemical Spray | N/A | N/A | N/A | N/A | N/A | |
| | Radiation | 2.1 X 10 ⁶ | | S-4 | | | See Sum. Sheet VI-6 |
| | Aging | 40 Years | | Life of Plant | Q-18 | Test | See Sum. Sht. VI-6 |
| | Submergence | N/A | N/A | N/A | N/A | N/A | |

M-H

*Documentation References:

See attached list.

Notes:

M8-75B
M8-75C
M8-75D

SYSTEM COMPONENT EVALUATION WORK SHEET

Facility: Millstone Nuclear Pr. Sta.
 Unit: One
 Docket: 50-245

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF.* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------|-----------------------|---------|---------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: Core Spray Plant ID No.: 1401A Component: Pump (Motor) 700 H.P. Manufacturer: G.E. | Operating Time | continuous | 12 hrs. | S-3 | Q-18 | Test | |
| | Temperature (°F) | Profiles 6,9 | 212°F | S-2 | Q-18 | Test | |
| | Pressure (PSIA) | Profile 10 | 0 psig | S-2 | Q-18 | Test | |
| | Relative Humidity (%) | Profile 8 | 100% | S-2 | Q-18 | Test | |
| Model Number: 5K6338XC28A Function: Core spray cooling pump Accuracy: NA | Chemical Spray | N/A | N/A | N/A | N/A | N/A | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | | See Sum. Sheet VI-8 |
| | Aging | 40 Years | | Life of Plant | | | See Sum. Sheet VI-8 |
| Flood Level Elev: NA Above Flood Level: Yes | Submergence | N/A | N/A | N/A | N/A | N/A | |

N-H

Notes:
 1401B

*Documentation References:
 See attached list.

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

SYSTEM COMPONENT EVALUATION WORK SHEET

Page VIII-1
Rev. 5
Date 11-24-80

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------------|-----------------------|-------|--------------------|-------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | | |
| System: LPCI Plant ID No.: V10-5A Component: Relay Manufacture: Chromalox Model Number: D2936-25 Contactor Function: Actuate Cooling Water Accuracy: N/A Service: LPCI Pump Motors Location: Rx Bldg. R7 & R9 Flood Level Elev: N/A Above Flood Level: Yes No | Operating Time | < 30 sec. | | S-3 | | | See Sum. Sh. VIII-1 |
| | Temperature (°F) | Profile 6 & 9 | | S-2 | | | See Sum. Sh. VIII-1 |
| | Pressure (PSIA) | Profile 10 | | S-2 | | | See Sum. Sh. VIII-1 |
| | Relative Humidity(%) | Profile 8 | | S-2 | | | See Sum. Sh. VIII-1 |
| | Chemical Spray | N/A | N/A | N/A | N/A | N/A | N/A |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | | See Sum. Sh. VIII-1 |
| | Aging | 40 Years | | Life of Pl- at | | | See Sum. Sh. VIII-1 |
| | Submergence | N/A | N/A | N/A | N/A | N/A | N/A |

M-H

*Documentation References:
See attached list.

Notes:
V10-5B
V10-4A and B (Core Spray)

EQUIPMENT ENVIRONMENTAL QUALIFICATION
DISCREPANT EQUIPMENT SUMMARY
MILLSTONE UNIT 1

EQUIPMENT:

Relay

MANUFACTURER: Chromalox Model D2936-25 Contactor SN-K320FU

QUALIFICATION DISCREPANCY:

Lacks documented qualification test data

SAFETY FUNCTION AND JUSTIFICATION
FOR CONTINUED OPERATION:

1. Transfer LPCI and C.S.P.P.S. from space heaters to water cooling.
2. This equipment will have completed its safety function within the first 30 seconds of an incident. Based on our engineering evaluation, considering the equipment operating time and expected effects associated with the qualification discrepancy, it is concluded that this equipment would satisfactorily perform its design function.
3. Due to the desirability of long term operability of this equipment, they will be replaced with qualified equipment. This will be accomplished as soon as practicable, prior to June 30, 1982, assuming that procurement delays do not preclude replacement by that date.

SYSTEM COMPONENT EVALUATION WORK SHEET

Facility: Millstone Nuclear Pr. Sta.
Unit: One
Docket: 50-245

| EQUIPMENT DESCRIPTION | ENVIRONMENT | | DOCUMENTATION REF* | | QUAL. METHOD | OUTSTANDING ITEMS |
|---|-----------------------|-----------------------|--------------------|---------------|--------------|---------------------|
| | Parameter | Spec. | Qual. | Spec. | Qual. | |
| System: Atmos. Control Plant ID No.: 1601-36A Component: Temperature Element Manufacturer: Thermo-Electric | Operating Time | Continuous | | | | See Sum. Sheet IX-6 |
| | Temperature (°F) | | | | | |
| | Pressure (PSIA) | | | | | |
| | Relative Humidity (%) | | | | | |
| Model Number: Type "T" Function: Indication Accuracy: | Chemical Spray | | | | | |
| | Radiation | 2.1 x 10 ⁶ | | S-4 | | See Sum. Sheet IX-6 |
| | Aging | 40 Years | | Life of Plant | | See Sum. Sheet IX-6 |
| Flood Level Elev: Above Flood Level: Yes No | Submergence | | | | | |

M-H

Notes:
1601-36B
(See IV-10b for cable)

***Documentation References:**
See Attached List