

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 P A B V S 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

CON'T
01 REPORT SOURCE L 6 0 5 0 0 0 3 3 4 7 1 2 0 6 8 0 3 0 1 0 5 8 1 9
7 8 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0140 hours on 12/6/80 during power operation, the inner door of the containment
03 air lock failed its surveillance test (Technical Specification 3.6.1.3). The health
04 and safety of the public was not jeopardized since the containment remained under a
05 vacuum during this period since both the inner and outer doors did not fail
06 their leakage tests at the same time.

07
08
7 8 9

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
S A 11 E 12 B 13 P E N E T R 14 A 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER EVENT YEAR
8 0 1 0 6 0 3 L 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPROY FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
A 18 Z 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 Z 25 Z 9 9 9 9 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 After maintenance was performed on the inner and outer doors, they passed their
11 leakage tests and were declared operable at 1300 hours on 12/6/80. Cleaning and
12 greasing the O-rings and tightening a valve on the test line corrected the problem.

13
14
7 8 9

15 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)
C 28 0 7 5 29 N/A B 31 Surveillance test
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
Z 33 Z 34 N/A N/A
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
0 0 0 17 Z 38 N/A
7 8 9 10 11 12 13 80

18 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
0 0 0 40 N/A
7 8 9 10 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
Z 42 N/A
7 8 9 10 11 12 80

20 PUBLICITY ISSUED DESCRIPTION (45)
N 44 N/A
7 8 9 10 11 12 80

NAME OF PREPARER W. S. Lacey

PHONE: 412-643-8525

NRC USE ONLY

8101180428

Attachment To LER 80-106/03L
Beaver Valley Power Station
Duquesne Light Company
Docket No. 50-334

No further information is available or needed to satisfy the reporting requirement.