LICENSEE EVENT REPORT
CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 N C B E P 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 5 57 CAT 58 5
REPORT L 6 0 5 0 - 0 3 2 4 7 1 2 1 1 8 0 8 0 1 0 9 8 1 9  SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80  EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  During normal surveillance it was discovered that primary containment atmospheric con-
tral inarting inlet isolation valve, 2-CAC-V48, model no. 7301518, had dual open-close
position indication. The valve was then shut and disarmed to ensure the closed posi-
· ·
tion and was declared inoperable as required by technical specifications.
06
07
Technical Specifications 3.6.3, 6.9.1.9b  7 8 9  CAUSE  COMP. VALVE
SUBCODE SUBCODE COMPONENT CODE SUBCODE
TO REPORT VEAR REPORT NO.    1
Present operational conditions prevent an immediate investigation and determination of
the dual indication problem with the valve. The valve has been electrically and pneu-
matically deactivated to prevent stroking it until the plant is in an operational model
that allows a full investigation and fix of the problem, at which time a supplemental
report on this event will be issued.
FACILITY STATUS POWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32  NA A A A A A A A A A A A A A A A A A A
7 8 9 10 12 13 44 45 46  ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
7 8 9 10 11 44 45
1 7 0 0 0 37 Z 38 NA NA 80
PERSONNEL INJURIES NUMBER DESCRIPTION 41
1 8 0 0 0 0 40 NA 80
LOSS OF OR DAWAGE TO FACILITY 43  TYPE DESCRIPTION  NA  NA
7 8 9 10  NRC USE ONLY
2 0 N 44 80. 5
810113 NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521