

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | M | G | S | L | 2 | 0 | 0 | 1 | - | 1 | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ | 3

9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 20 27 CAT 28

0 1 | R | L | 5 | 0 | 5 | 1 | 0 | 0 | 1 | 0 | 3 | 6 | 1 | 9 | 7 | 0 | 1 | 3 | 1 | 0 | 1 | 3 | 0 | 2 | 1 | 3 | 8 | 1 | 1 | \_\_\_\_\_ | 9

7 REPORT SOURCE 50 51 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 1 | During fuel loading a periodic test to verify containment integrity was

0 3 | performed. Vent valve VX-41 and containment isolation valve VX-40 were

0 4 | discovered open to atmosphere. This was in violation of Technical Specifica-

0 5 | tion 4.9.4.1. The health and safety of the public were not affected.

0 6 | \_\_\_\_\_

0 7 | \_\_\_\_\_

0 8 | \_\_\_\_\_

0 9 | SYSTEM CODE: S I C (11) CAUSE CODE: D (12) CAUSE SUBCODE: Z (13) COMPONENT CODE: V A L V E X (14) COMP SUBCODE: D (15) VALVE SUBCODE: D (15)

10 | LER/RO REPORT NUMBER: 3 1 (17) EVENT YEAR: 8 1 (21) SEQUENTIAL REPORT NO.: 0 0 1 2 (24) OCCURRENCE CODE: 0 1 (23) REPORT TYPE: I (20) REVISION NO.: 0 (22)

11 | ACTION TAKEN: G (18) FUTURE ACTION: Z (19) EFFECT ON PLANT: Z (20) SHUTDOWN METHOD: Z (21) HOURS: 0 1 0 0 0 (22) ATTACHMENT SUBMITTED: Y (23) NRC-4 FORM SUB: N (24) PRIME COMP SUPPLIER: L (25) COMPONENT MANUFACTURER: I 2 1 0 1 7 (28)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 3 | Initial fuel loading did not contain a valve checklist and no periodic test

1 1 | existed to insure containment isolation valves necessary for Mode 6 be

1 2 | verified closed. The valves were closed and a periodic test procedure was

1 3 | written and performed to verify containment integrity.

1 4 | \_\_\_\_\_

1 5 | FACILITY STATUS: X (28) % POWER: 0 0 1 0 (29) OTHER STATUS: Initial Fuel (30) METHOD OF DISCOVERY: B (31) DISCOVERY DESCRIPTION: Periodic Test (32)

1 6 | ACTIVITY CONVENT: 1 0 (33) 1 2 Loading (34) AMOUNT OF ACTIVITY: NA (35) LOCATION OF RELEASE: NA (36)

1 7 | PERSONNEL EXPOSURES: NUMBER: 0 0 0 0 (37) TYPE: Z (38) DESCRIPTION: NA (39)

1 8 | PERSONNEL INJURIES: NUMBER: 0 0 0 0 (40) DESCRIPTION: NA (41)

1 9 | LOSS OF OR DAMAGE TO FACILITY: TYPE: Z (42) DESCRIPTION: NA (43)

2 0 | PUBLICITY ISSUED: N (44) DESCRIPTION: NA (45)

NRC USE ONLY

NAME OF PREPARER: R. W. Ouellette

PHONE: (704) 373-7530

8102200483