

TERA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 5, 1981

Docket No. 50-346

Mr. Richard P. Crouse
Vice President, Nuclear
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652



Dear Mr. Crouse:

We have reviewed your submittal of November 10, 1980, regarding isolation testing of the Reactor Protection System and the Safety Features Actuation System with respect to faults generated on non-Class IE circuits. The enclosure identifies additional information that we will need in order to complete our review. You are requested to respond within 45 days of receipt of this letter.

Sincerely,

Robert W. Reid, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosure:
Request for Additional
Information

cc: See next page

Q

8102240002

Toledo Edison Company

cc w/enclosure(s):

Mr. Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Leslie Henry, Esq.
Fuller, Seney, Henry and Hodge
300 Madison Avenue
Toledo, Ohio 43604

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

Ida Rupp Public Library
310 Madison Street
Port Clinton, Ohio 43452

President, Board of County
Commissioners of Ottawa County
Port Clinton, Ohio 43452

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43215

Harold Kahn, Staff Scientist
Power Siting Commission
361 East Broad Street
Columbus, Ohio 43216

Mr. Rick Jagger
Industrial Commission
State of Ohio
2323 West 5th Avenue
Columbus, Ohio 43216

Mr. Ted Myers
Manager, Nuclear Licensing
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
5503 N. State Route 2
Oak Harbor, Ohio 43449

Director, Criteria and Standards
Division
Office of Radiation Programs (ANR-460)
U. S. Environmental Protection Agency
Washington, D. C. 20460

U. S. Environmental Protection Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

Ohio Department of Health
ATTN: Director of Health
450 East Town Street
Columbus, Ohio 43216

REQUEST FOR ADDITIONAL INFORMATION
DAVIS BESSE
ISOLATION TESTING OF THE SFAS

Ref. 1: Toledo Edison Letter and Document No. ER 7054
Addendum A (R. P. Crouse) to NRC (R. W. Reid),
dated November 10, 1980.

1. Submit a copy of the test procedures used in Ref. 1, (Consolidated Controls Corporation Test Procedures KAM 7315).
2. Submit a copy of Bechtel Specification 7749-E-238 referred to in Ref. 1, Section 4.0.
3. Submit a wiring diagram for one channel of the SFAS (Diagram should show the components which were subjected to the tests). Also define the function of each of the components tested.
4. Clarify what is meant by a "P/S" (Ref. 1, Section 3.1.5).
5. Explain in detail the test results submitted in chart recording form [Ref. 1] as the charts are not adequately labeled or the test procedures defined.