



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

February 3, 1981

TERA

Docket Nos. 50-317  
and 50-318


Mr. A. E. Lundvall, Jr.  
Vice President - Supply  
Baltimore Gas & Electric Company  
P. O. Box 1475  
Baltimore, Maryland 21203



Dear Mr. Lundvall:

In the process of reviewing your letter dated October 8, 1979 on Adequacy of Station Electric Distribution System Voltages, we find that additional information as detailed in the enclosure is needed to complete our review. Please provide the additional information within 45 days of receipt of this letter.

Sincerely,

  
Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosure: As stated

cc: See next page

8102240 032

P

Baltimore Gas and Electric Company

CC:

James A. Biddison, Jr.  
General Counsel  
G and E Building  
Charles Center  
Baltimore, Maryland 21203

George F. Trowbridge, Esquire  
Shaw, Pittman, Potts and  
Trowbridge  
1800 M Street, N.W.  
Washington, D. C. 20036

Mr. R. C. L. Olson  
Baltimore Gas and Electric Company  
Room 922 - G and E Building  
Post Office Box 1475  
Baltimore, Maryland 21203

Mr. Leon B. Russell  
Plant Superintendent  
Calvert Cliffs Nuclear Power Plant  
Baltimore Gas & Electric Company  
Lusby, Maryland 20657

Bechtel Power Corporation  
ATTN: Mr. J. C. Judd  
Chief Nuclear Engineer  
15740 Shady Grove Road  
Gaithersburg, Maryland 20760

Combustion Engineering, Inc.  
ATTN: Mr. P. W. Kruse, Manager  
Engineering Services  
Post Office Box 500  
Windsor, Connecticut 06095

Calvert County Library  
Prince Frederick, Maryland 20678

Director, Department of State Planning  
301 West Preston Street  
Baltimore, Maryland 21201

Mr. R. M. Douglass, Manager  
Quality Assurance Department  
Room 923 Gas & Electric Building  
P. O. Box 1475  
Baltimore, Maryland 21203

Mr. Bernard Fowler  
President, Board of County  
Commissioners  
Prince Frederick, Maryland 20768

Director, Criteria and Standards Division  
Office of Radiation Programs (ANR-460)  
U.S. Environmental Protection Agency  
Washington, D.C. 20460

U. S. Environmental Protection Agency  
Region III Office  
ATTN: EIS COORDINATOR  
Curtis Building (Sixth Floor)  
Sixth and Walnut Streets  
Philadelphia, Pennsylvania 19106

Ralph E. Architzel  
Resident Reactor Inspector  
NRC Inspection and Enforcement  
P. O. Box 437  
Lusby, Maryland 20657

Mr. Charles B. Brinkman  
Manager - Washington Nuclear  
Operations  
C-E Power Systems  
Combustion Engineering, Inc.  
4853 Cordell Ave., Suite A-1  
Bethesda, Maryland 20014

Administrator, Power Plant Siting Program  
Energy and Coastal Zone Administration  
Department of Natural Resources  
Tawes State Office Building  
Annapolis, Maryland 21204

REQUEST FOR ADDITIONAL INFORMATION  
CALVERT CLIFFS NUCLEAR POWER PLANT  
Units 1 and 2  
DOCKET NO. 50-317 and 50-318

Reference 1: NRC letter (W. Gammill) to all Power Reactor Licensees, dated August 8, 1979.

Reference 2: Baltimore Gas and Electric Company letter (A. E. Lundvall) to the NRC (D.G. Eisenhut), dated October 8, 1979.

Reference 3: Baltimore Gas and Electric Company letter (A. E. Lundvall) to the NRC (D. L. Ziemann), dated September 15, 1976

1. The voltage analysis submitted in Ref. 2 was performed using both service transformers (P-13000-1 and P-13000-2) supplying the Class 1E buses. Ref. 1 requests that an analysis be completed for the worst case. Submit an analysis assuming only one service transformer is in service prior to an accident (Guideline 2, Ref. 1). After the transients of the emergency loading, calculations showing the effect of starting a large non-safety load should be made (Guideline 3, Ref. 1). Also, confirm that the second-level of undervoltage protection relays will not give a spurious trip for this condition.
2. Ref. 2 provided calculations and tests for 4160 volt buses and 480 volt buses. Submit calculated voltages for all low-voltage AC (less than 480 volts) Class 1E buses or distribution terminals or document that all low-voltage AC Class 1E equipment will be operating within their required voltage ratings for each case analyzed. Do these buses supply any instruments or control circuits required by GDC-13? If so, is all equipment capable of sustaining the analyzed voltages without blowing fuses, overheating, etc., and without affecting the equipment's ability to perform the required function.
3. Ref. 3, Enclosure 1, page 1 refers to "safety related" buses 4160-14, 480-14A, and 480-14B. Are these buses Class 1E supplying Class 1E equipment? If so, submit an analysis for these buses and equipment as submitted for buses 11, 11A, and 11B.