



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

January 8, 2020

LICENSEE: Vistra Operations Company LLC

FACILITY: Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF DECEMBER 3, 2019, TELECONFERENCE WITH VISTRA OPERATIONS COMPANY LLC TO DISCUSS A PROPOSED LICENSE AMENDMENT REQUEST TO CHANGE TECHNICAL SPECIFICATION 3.8.1, "AC SOURCES - OPERATING" FOR COMANCHE PEAK NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 (EPID L-2019-LRM-0072)

On December 3, 2019, a public teleconference was held between the U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Vistra Operations Company LLC (the licensee). The purpose of the teleconference was to discuss a proposed license amendment request (LAR) to change Technical Specification (TS) 3.8.1, "AC [Alternating Current] Sources - Operating," for Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2 (Comanche Peak). The meeting notice and agenda, dated November 18, 2019, are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML19322C032. A list of attendees is enclosed. A meeting summary for a prior teleconference on this topic, held on November 5, 2019, is available at ADAMS Accession No. ML19311C212.

The licensee presented informational slides at the meeting (ADAMS Accession No. ML19337A662). During the meeting, the licensee described (1) its AC sources, (2) the reason for TS change, and (3) the proposed change.

The NRC staff and the licensee discussed the above topics. The NRC staff recommended that the proposed LAR address the impact of the changes to the steady-state frequency limit in the proposed TSs for the emergency diesel generator on accident analyses in Chapter 15 of the Comanche Peak Final Safety Analysis Report. The NRC staff also recommended that the proposed LAR describe how the emergency diesel generator steady state operation is determined in the proposed revised surveillance requirements.

No members of the public called into the teleconference. No regulatory decisions or commitments were made at the meeting. No public meeting feedback forms were received.

Please direct any inquiries to me at 301-415-6256, or at [Dennis.Galvin@nrc.gov](mailto:Dennis.Galvin@nrc.gov).

*/RA/*

Dennis J. Galvin, Project Manager  
Plant Licensing Branch 4  
Division of Operator Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure:  
List of Attendees

cc: Listserv

LIST OF ATTENDEES

DECEMBER 5, 2019, PRE-SUBMITTAL TELECONFERENCE REGARDING

PROPOSED LICENSE AMENDMENT REQUEST TO CHANGE

TECHNICAL SPECIFICATION 3.8.1, "AC SOURCES - OPERATING"

VISTRA OPERATIONS COMPANY, LLC

COMANCHE PEAK NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2

U.S. Nuclear Regulatory Commission

J. Cintron-Rivera

D. Galvin

V. Goel

P. Snyder

S. Sun

Vistra Operations Company, LLC \*

I. Ahmad

D. Goodwin

J. Hicks

C. McBeth

S. Sewell

G. Struble

K. Vehstedt

\* participated by phone

SUBJECT: SUMMARY OF DECEMBER 3, 2019, TELECONFERENCE WITH VISTRA OPERATIONS COMPANY LLC TO DISCUSS A PROPOSED LICENSE AMENDMENT REQUEST TO CHANGE TECHNICAL SPECIFICATION 3.8.1, "AC SOURCES - OPERATING" FOR COMANCHE PEAK NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 (EPID L-2019-LRM-0072) DATED JANUARY 8, 2020

**DISTRIBUTION:**

PUBLIC	RidsNrrPMComanchePeak Resource
PM File Copy	RidsRgn4MailCenter Resource
RidsACRS_MailCTR Resource	VGoel, NRR
RidsNrrDexEeob Resource	PSnyder, NRR
RidsNrrDexEmib Resource	SSun, NRR
RidsNrrDorlLpl4 Resource	JCintron-Rivera, NRR
RidsNrrDssSnsb Resource	LBetancourt, NRR
RidsNrrDssStsb Resource	MMcCoppin, OEDO, NRR
RidsNrrLAPBlechman Resource	JQuichocho, OEDO, NRR

**ADAMS Accession No.: ML19352E317**

**\*by e-mail**

OFFICE	NRR/DORL/LPL4/PM	NRR/DORL/LPL4/LA	NRR/DEX/EEOB/BC*
NAME	DGalvin	PBlechman	BTitus
DATE	01/06/2020	12/18/2019	12/18/2019
OFFICE	NRR/DSS/STSB/BC*	NRR/DSS/SNSB/BC(A)*	NRR/DORL/LPL4/BC
NAME	VCusumano	JBorromeo	JDixon-Herrity
DATE	12/18/2019	12/19/2019	01/07/2020
OFFICE	NRR/DORL/LPL4/PM		
NAME	DGalvin		
DATE	01/08/2020		

**OFFICIAL RECORD COPY**