LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-000-00 (3) | 4111 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05 00 03 27 (7) | 120180 (8) | 120180 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 1005 (c) on 12/1/80, with unit 1 in mode 1 at 70% RTP, circuit breaker #7 on
03 | 120V vital instrument power board 1-II tripped. This rendered radiation monitors
04 | 1-RE-90-112/134/141 inoperable resulting in entering action statement 32 of
05 | LCO 3.3.3.9.b. SI-414 was initiated to obtain grab samples. There was no effect
06 | on public health or safety. Previous occurrences - 1. (Reference SQRO-50-327/80083).
07 |
08 |

09 | SYSTEM CODE MC (11) | CAUSE CODE E (12) | CAUSE SUBCODE A (13) | COMPONENT CODE MOTORX (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 194 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER X (25) | COMPONENT MANUFACTURER G063

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | Investigation revealed that the motor on 0-RE-90-134 had failed causing the breaker
11 | on the vital instrument power board to trip. The motor was replaced and the
12 | radiation monitors were declared operable on 12/2/80 at 0035 (c).
13 |
14 |

15 | FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS NA (30) | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION NA (32)

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY NA (35) | LOCATION OF RELEASE NA (36)

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION NA (39)

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION NA (41)

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA (43)

20 | PUBLICITY ISSUED N (44) | DESCRIPTION NA (45) | NRC USE ONLY

W. T. Cottle/A. M. Wilkey 615-842-8261

8101070 377