

DUKE POWER COMPANY
NUCLEAR PRODUCTION DEPARTMENT
P.O. BOX 33189, 422 SOUTH CHURCH STREET
CHARLOTTE, N.C. 28242
(704) 373-4041

December 7, 1989

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555


Subject: McGuire Nuclear Station
Docket Nos. 50-369 and 50-370
Catawba Nuclear Station
Docket Nos. 50-413 and 50-414
Oconee Nuclear Station
Docket Nos. 50-269, 50-270 and 50-287
Crisis Management Implementing Procedures

Gentlemen:

Attached for NRC use and review is Revision 6 dated November 30, 1989 to the Duke Power Company Crisis Management Implementing Procedure CMIP-11 (Classification of Emergency for McGuire Nuclear Station).

By copy of this letter two revisions are being provided to NRC, Region II, Atlanta.

Very truly yours,



Hal B. Tucker, Vice President
Nuclear Production

KLC:klc

attachment

TABLE OF CONTENTS

Volume 2

<u>Tab</u>	<u>Procedure Description</u>
CMIP-8	Oconee Crisis Phone Directory (Rev. 25)
CMIP-9	McGuire/Catawba Crisis Phone Directory (Rev. 31)
CMIP-10	Emergency Classification - Catawba (Rev. 2)
CMIP-11	Emergency Classification - McGuire (Rev. 6)
CMIP-12	Emergency Classification - Oconee (Rev. 5)
CMIP-13	Notifications to States and Counties from the Crisis Management Center (Rev. 19)
CMIP-14	Crisis Management Data Transmittal System Access for Offsite Agencies - (Rev. 0)
CMIP-15	NRC Notification Requirements (Rev. 3)
CMIP-16	Crisis Management Data Transmittal System Access from the Crisis Management Center - (Rev. 9)
CMIP-17	Public Alerting on Lake Norman (Rev. 6)
CMIP-18	Maintaining Emergency Preparedness (Rev. 3)
CMIP-19	Communications Test for McGuire/Catawba CMC (Rev. 16)
CMIP-20	Communications Test for Oconee CMC (Rev. 10)
CMIP-21	Quarterly Inventory Equipment Check (Rev. 29)
CMIP-22	Telephone Number Updates (Rev. 1)

December 1, 1989

CRISIS MANAGEMENT IMPLEMENTING PROCEDURE

CMIP-11

Classification of Emergency for
McGuire Nuclear Station

Rev. 6
November 30, 1989

RE Harris
Approved By

12/5/89
Date

CMIP-11
CLASSIFICATION OF EMERGENCY FOR
McGUIRE NUCLEAR STATION

1.0 SYMPTOMS

1.1 Notification of Unusual Event

- 1.1.1 Events are in progress or have occurred which indicate a potential degradation of the level of safety of the plant.
- 1.1.2 No releases of radioactive material requiring offsite response or monitoring are expected unless further degradation of safety occurs.

1.2 Alert

- 1.2.1 Events are in progress or have occurred which involve an actual or potential substantial degradation of the level of safety of the plant.
- 1.2.2 Any releases are expected to be limited to small fractions of the EPA Protective Action Guideline exposure levels.

1.3 Site Area Emergency

- 1.3.1 Events are in process or have occurred which involve actual or likely major failures of plant functions needed for protection of the public.
- 1.3.2 Any releases are not expected to exceed EPA Protection Action Guideline exposure levels except near the site boundary.

1.4 General Emergency

- 1.4.1 Events are in process or have occurred which involve actual or imminent substantial core degradation or melting with potential for loss of containment integrity.
- 1.4.2 Releases can be reasonably expected to exceed EPA Protective Action Guideline exposure levels offsite for more than the immediate site area.

2.0 IMMEDIATE ACTIONS

- 2.1 Compare actual plant conditions to the Emergency Action Level(s) listed in Enclosure 4.1 then declare the appropriate Emergency Class as indicated.

If a change in the emergency class is made, perform steps 2.2, 2.3, and 2.4 below.

- 2.2 Instruct the State/County Communicator to notify the state(s) and counties per CMIP-13 of any change in the emergency class. If the emergency class is SITE AREA EMERGENCY or GENERAL EMERGENCY, determine protective action recommendations per CMIP-1 and transmit these recommendations.

NOTE: Notifications to the state(s) and counties must be made within 15 minutes whenever there is a change in the emergency classification.

- 2.3 Announce the change in the emergency class to all CMC personnel and to the Emergency Coordinator at the TSC.
- 2.4 Instruct the NRC Communicator in the CMC Plant Assessment Group to notify NRC immediately and within one hour per CMIP-15.

3.0 SUBSEQUENT ACTIONS

- 3.1 To de-escalate or close out the Emergency, compare plant conditions to the Initiating Conditions of Enclosure 4.1.

Notify state(s), counties, and NRC by verbal summary of any reduction or termination in the emergency class followed by a written summary within eight (8) hours.

4.0 ENCLOSURES

4.1 Emergency Event List for Emergency Classes

<u>Event No.</u>	<u>Page(s)</u>
4.1.1 Primary Coolant Leak	1-3
4.1.2 Fuel Damage	4-5
4.1.3 Steam System Failure	6-7
4.1.4 High Radiation/Radiological Effluents	8
4.1.5 Loss of Shutdown Function	9-12
4.1.6 Loss of Power	13
4.1.7 Fires and Security Actions	14
4.1.8 Spent Fuel Damage	15
4.1.9 Natural Disasters and Other Hazards	16-18
4.1.10 Other Abnormal Plant Conditions	19-23

4.2 Engineered Safety Features

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.1 PRIMARY COOLANT LEAK

CMIP 11
ENCLOSURE 4.1
PAGE 1 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

1. Any NC system leakage greater than Tech Spec limits in Modes 1-4.

- ◆ Greater than 1 gpm unidentified NC system leakage in modes 1-4

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.6.2.

- ◆ Greater than 10 gpm identified NC system leakage

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.6.2.

- ◆ Greater than 500 gpd tube leakage in any S/G in modes 1-4

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.6.2.

1. Any NC system leakage greater than 50 gpm in Modes 1-4.

- ◆ NC system leakage greater than 50 gpm in modes 1-4

AND

NC subcooling greater than 0 Deg. F.

AND

Leak cannot be isolated within 15 minutes.

2. S/G tube leak with loss of offsite power

- ◆ S/G tube leak greater than 10 gpm

AND

NC subcooling greater than 0 Deg. F.

Both Unit related main bus lines de-energized.

1. Any NC system leakage greater than available ECCS capacity.

- ◆ Safety Injection activated or required

AND

Existing NV, NI and ND flow cannot maintain NC subcooling greater than 0 Deg. F.

2. S/G tube leak with an unisolable steam line break outside containment and indication of fuel damage.

- ◆ S/G tube leak greater than 50 gpm

AND

Unisolable steam line break on the affected S/G outside containment

AND

Fuel damage as determined by Event Category 4.1.2.

END

1. Any LOCA with failure of ECCS

- ◆ LOCA with failure of both trains of ECCS injection

AND

NC subcooling cannot be maintained greater than 0 Deg. F.

- ◆ LOCA with failure of both trains of ECCS recirculation

AND

NC subcooling cannot be maintained greater than 0 Deg. F.

- ◆ LOCA

AND

Plant conditions require entry in EP/1 or 2/A/5000/12.1 (Response to Inadequate Core Cooling)

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.1 PRIMARY COOLANT LEAK

ENCLOSURE 4.1
PAGE 2 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

- ◆ Greater than 1 gpm total tube leakage in all S/G's.

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.6.2.

- ◆ Any NC system pressure boundary leakage in modes 1-4.

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.6.2.

- ◆ Greater than 1 gpm leakage from any NC pressure isolation valve at 2235 psig in modes 1-4

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.6.2.

- 3. S/G tube leak with an unisolable steam line break outside containment.

- ◆ S/G tube leak greater than 10 gpm

AND

NC subcooling greater than 0 Deg F

AND

Unisolable steam line break outside containment

- ◆ Unisolable steam line break outside containment

AND

Field monitoring teams detect activity at the protected area fence at greater than or equal to 2 mRem/hr whole body.

END

- 2. LOCA with initially successful ECCS followed by failure of ECCS heat sink and failure of containment heat removal.

- ◆ LOCA

AND

Loss of recirculation heat sink

AND

Loss of containment spray heat sink

END

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.1 PRIMARY COOLANT LEAK

CMIP
ENCLOSURE 4.1
PAGE 3 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

- ◆ Greater than 40 gpm controlled NC system leakage at 2235 psig in modes 1-4.

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.6.2.

2. Any unisolable NC system leakage greater than 50 gpm in Modes 5 and 6.
3. Failure of an unisolable PZR PORV or safety valve to close following a reduction of NC pressure.

END

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

1. NC system activity
greater than Tech Spec
limits in Modes 1-5.

- ◆ Greater than 1.0 microcurie per gram dose equivalent I-131 for greater than 48 hrs. continuous per chemistry analysis in modes 1-5.

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.8.

- ◆ Dose equivalent I-131 in excess of Tech Spec Figure 3.4-1 per Chemistry analysis in modes 1-5.

AND

Load reduction or plant cooldown initiated pursuant to Tech Spec 3.4.8.

1. Severe loss of fuel
cladding in Modes 1-5.

- ◆ Valid increase of 1000 times background set-points of any containment radiation monitor in modes 1-5.
- ◆ Valid increase of 1000 times background set-point of reactor coolant system process monitor (EMF-48) in modes 1-5.
- ◆ Chemistry analysis indicates greater than or equal to 5% total fuel clad failure or increase of 1% fuel failures within 30 minutes in modes 1-5.

END

1. Degraded core with
possible loss of
coolable geometry.

- ◆ Average of five highest core exit T/C's indicates greater than or equal to 700 Deg. F.
- ◆ Lower Range RVLIS less than 43% level during a LOCA event.
- ◆ RVLIS D/P setpoint at value which requires entry into Degraded Core Cooling section of Emergency Procedures.
- ◆ Containment hydrogen concentration greater than or equal to 1% and increasing greater than or equal to 0.1% per hour.
- ◆ Containment EMF's (51a or 51b) valid reading of 179 R/hr.

END

1. Loss of 2 of 3 fission
product barriers with
potential for loss of
3rd barrier.

NOTE: Satisfy 'A' and 'B'

A. Loss of clad or NC
system barrier

- ◆ Total fuel clad failure greater than 20% per Chemistry analysis.
- ◆ Containment EMF's (51a or 51b) valid reading of 1100 R/hr (1 Rem WB or 5 Rem thyroid at site boundary)
- ◆ Plant conditions require entry into EP/1 or 2/A/5000/12.1 (Response to Inadequate Core Cooling).
- ◆ Containment atmosphere H² concentration greater than or equal to 9%.
- ◆ Containment pressure greater than or equal to 60 psig.

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

- ◆ Specific activity greater than 100/E microcuries per gram per Chemistry analysis.

AND

Load reduction or plant
cooldown initiated
pursuant to Tech Spec
3.4.8

END

B. Loss of or threat to
barrier

- ◆ Incomplete containment integrity
- ◆ Known containment leakage in excess of Tech Specs.
- ◆ Containment atmosphere H² concentration greater than or equal to 9%.
- ◆ Containment pressure greater than or equal to 60 psig.

END

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.3 STEAM SYSTEM FAILURE

CMIP-11
ENCLOSURE 4.1
PAGE 6 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

1. Steam line break which results in rapid depressurization of the secondary side.

- ◆ Steam line depressurization resulting in safety injection or main steam isolation

END

1. Unisolable steam line break outside containment with a S/G tube leak.

- ◆ Unisolable steam line break outside containment.

AND

NC subcooling greater than or equal to 0 degree F.

AND

S/G tube leak greater than 10 gpm.

- ◆ Unisolable steam line break outside containment.

AND

Field monitoring teams detect activity at the protected area fence at greater than or equal to 2 mRem/hr whole body.

1. Unisolable steam line break outside containment with a S/G tube leak and indication of fuel damage.

- ◆ Unisolable steam line break on the affected S/G outside containment.

AND

S/G tube leak greater than 50 gpm.

AND

Fuel damage as determined by Event 4.1.2.

END

N/A

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.3 STEAM SYSTEM FAILURE

CMIP-11
ENCLOSURE 4.1
PAGE 7 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

2. Steam line break with
failure of ECCS or
ESF.

- ◆ Steam line
depressurization
resulting in safety
injection signal.

AND

Failure of both trains
of ECCS injection.

- ◆ Steam line depres-
surization resulting
in Main Steam Isola-
tion signal.

AND

Failure of two or more
Main Steam Isolation
Valves to close.

END

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.4 HIGH RADIATION/RADIOLOGICAL EFFLUENTS

CVL 11
ENCLOSURE 4.1
PAGE 8 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

1. Liquid or gaseous radiological effluents exceed Tech. Spec. Limits as determined by RP or Chemistry Procedures.

END

1. High radiation levels or high airborne contamination

- ◆ Any valid EMF reading greater than or equal to 1000 times trip I setpoint

2. Liquid or gaseous radiological effluents exceed 10 times Tech Spec limits as determined by RP or Chemistry procedures.

END

1. Accidental releases of gases

- ◆ EMF-37 Trip II alarm.

AND

EMF-36L reading greater than 6.3E5 cpm.

AND

Calculations verify that dose rates at the site boundary are greater than or equal to:

50 mRem/hr WB or 250 mRem/hr thyroid for 30 minutes

- ◆ Calculations determine dose rates or Field Monitoring Teams measure activity at the Site Boundary greater than or equal to:

50 mRem/hr WB or 250 mRem/hr thyroid for 30 minutes.

END

1. Accidental releases of gases

- ◆ EMF-37 Trip II alarm.

AND

EMF-36H reading greater than 1.4E3 cpm.

AND

2 Hr dose calculation verifies dose rates at the site boundary are greater than or equal to:

1 Rem WB

OR

5 Rem thyroid

- ◆ Dose calculations or field monitoring team measurements result in a 2 hour projection at the site boundary of:

1 Rem WB

OR

5 Rem thyroid

END

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.5 LOSS OF SHUTDOWN FUNCTIONS

01-11
ENCLOSURE 4.1
PAGE 9 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

N/A

1. Complete loss of any function needed to maintain core cooling in modes 5 and 6.

- ◆ Failure of heat sink results in the loss of NC System subcooling.

2. Transient with failure of the Reactor Protection System to automatically initiate and complete a Rx trip which brings the Reactor Subcritical (ATWS Event)

END

1. Complete loss of any function needed for hot shutdown conditions

- ◆ Failure of heat sink results in the inability to maintain hot shutdown.

AND

NC subcooling cannot be maintained greater than 0 Deg. F.

- ◆ Inability to feed S/G's from any source in Mode 1-3.

AND

NC subcooling cannot be maintained greater than 0 Deg. F.

1. Transient initiated by loss of CF and CM systems followed by failure of heat removal capability for an extended period.

- ◆ Loss of CM/CF feedwater flow capability.

AND

CA flow cannot be established within 30 minutes.

AND

NC system feed and bleed cannot be established or maintained.

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.5 LOSS OF SHUTDOWN FUNCTIONS

CG 11
ENCLOSURE 4.1
PAGE 10 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

2. Transient requiring operation of shutdown systems with failure to trip (power generation continues).

◆ Transient with failure of the reactor protection system to automatically initiate and complete a Rx trip which brings the reactor subcritical (ATWS event).

AND

Manual Rx trip from the control room fails to bring the reactor subcritical.

AND

Chemistry analysis indicates greater than or equal to 5% total fuel clad failure or increase of 1% fuel failures within 30 minutes.

2. Transient requiring a Rx trip with failure to trip and failure of core cooling.

◆ Transient with failure of the reactor protection system to automatically initiate and complete a Rx trip which brings the reactor subcritical (ATWS event).

AND

Manual Rx trip from the control room fails to bring the reactor subcritical.

AND

Chemistry analysis indicates greater than or equal to 5% total fuel clad failure or increase of 1% fuel failures with 30 minutes.

AND

Plant conditions require entry into EP/1or2/A/5000/12.1 (Response to Inadequate Core Cooling).

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.5 LOSS OF SHUTDOWN FUNCTIONS

CA-11
ENCLOSURE 4.1
PAGE 11 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

3. Inability to maintain cold shutdown with loss of reactor vessel coolant inventory in Modes 5 and 6.

- ◆ Failure of heat sink causes loss of cold shutdown conditions in modes 5 and 6.

AND

Lower Range RVLIS level decreasing after initiation of NC System Makeup.

- ◆ Failure of heat sink causes loss of cold shutdown conditions in modes 5 and 6.

AND

NC System narrow range level less than 14 inches and decreasing after initiation of NC System Makeup.

- ◆ Failure of heat sink causes loss of Cold Shutdown conditions in modes 5 and 6.

AND

3. Loss of heat sink with subsequent core uncover in Modes 5 and 6.

- ◆ Failure of heat sink causes loss of cold shutdown conditions in modes 5 and 6.

AND

Lower Range RVLIS level indicates core remains substantially uncovered (less than 43% level).

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.5 LOSS OF SHUTDOWN FUNCTIONS

C-11
ENCLOSURE 4.1
PAGE 12 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

Either Train ultrasonic level indication less than 14 inches and decreasing after initiation of NC System makeup.

- ◆ Failure of heat sink causes loss of cold shutdown conditions in modes 5 and 6.

AND

Reliable NC System level indication unavailable due to NC System pressurization.

AND

Core exit T/C's or AP/1 or 2/A/5500/19 (Loss of Residual Heat Removal) data indicate boiling in the core.

AND

Available make-up rate (as indicated by flow rate instrumentation or rate of FWST level decrease) less than applicable data book curve.

END

- ◆ Failure of heat sink causes loss of cold shutdown conditions in modes 5 and 6.

AND

Core Exit T/Cs indicate superheat at the core exit.

AND

Available make-up rate (as indicated by Flow Rate Instrumentation or rate of FWST Level decrease) less than applicable data book curve.

- ◆ Failure of heat sink causes loss of cold shutdown conditions in modes 5 and 6.

AND

Available make-up rate (as indicated by Flow Rate Instrumentation or rate of FWST Level decrease) less than applicable data book curve.

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.5 LOSS OF SHUTDOWN FUNCTIONS

CM-11
ENCLOSURE 4.1
PAGE 13 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

AND

NC System level below
bottom range of avail-
able level indication.

AND

Emergency Coordinator
judgement that core
uncovery is imminent.

END

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.6 LOSS OF POWER

011
ENCLOSURE 4.1
PAGE 14 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

1. Loss of offsite power
in Modes 1-6.

- ◆ Both unit related main bus lines de-energized in modes 1-6.

2. Loss of onsite AC
power capability in
Modes 1-4.

- ◆ Both D/G's are incapable (for greater than 2 hours) of powering the 4160 V essential busses in modes 1-4.

3. Loss of onsite AC
power capability in
Modes 5 and 6.

- ◆ Both D/G's are incapable (for greater than 8 hours) of powering the 4160 V essential busses in modes 5 and 6.

END

1. Loss of offsite power
and loss of all onsite
AC power for greater
than 15 minutes in
Modes 5 & 6.

- ◆ Both 4160 V essential buses are de-energized for greater than 15 minutes in modes 5 and 6.

2. Loss of all vital DC
power for greater than
15 minutes in Modes 5
& 6.

- ◆ Both unit related EVDA and EVDD buses de-energized for greater than 15 minutes in modes 5 and 6.

END

1. Loss of offsite power
and loss of all onsite
AC power for greater
than 15 minutes in
Modes 1-4.

- ◆ Both 4160 V essential buses are de-energized for greater than 15 minutes in Modes 1-4.

2. Loss of all vital DC
power for greater than
15 minutes in Modes
1-4.

- ◆ Both unit related EVDA and EVDD buses de-energized for greater than 15 minutes in Modes 1-4.

END

1. Loss of offsite power
and loss of all onsite
AC power with total
loss of S/G's feed
capability in Modes
1-4.

- ◆ Both 4160 V essential buses are de-energized in modes 1-4.

AND

Loss of CM/CF feedwater flow capability.

AND

CA flow cannot be established within 30 minutes.

END

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.7 FIRES AND SECURITY ACTIONS

CHAPTER 1
ENCLOSURE 4.1
PAGE 15 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

1. Fire within the plant (see Note) that takes more than 10 minutes to extinguish.
2. Security threat.
 - ◆ Discovery of bomb within the site boundary.
 - ◆ Civil disturbance (hostile)
 - ◆ Intrusion/Attempted Intrusion (Protected Area)
 - ◆ Hostage situation/extortion
 - ◆ Security threat as determined by Emergency Coordinator and Security

END

NOTE: Plant is defined as: Aux. Bldg, TB, SB, RB, D/G Rm, Doghouses, SSF, Interim Radwaste Facility

1. Fires defeating safety system functions required for current operating mode.

- ◆ Fire resulting in loss of any required ESF function (both trains defeated or fire defeats the single operable train).

- ◆ Fire requiring Control Room evacuation

AND

Control established (or in process of being established) from the Standby Shutdown Facility (SSF).

1. Fire compromising the functions of shutdown systems.

- ◆ Fire that results in inability to maintain Hot Shutdown

AND

NC subcooling cannot be maintained greater than 0 degrees F.

- ◆ Fire requiring Control Room evacuation

AND

Control cannot be established from the Standby Shutdown Facility (SSF).

AND

NC subcooling cannot be maintained greater than 0 degrees F.

1. Any major fire or security threat which could cause massive common damage to plant systems.

2. Loss of physical control of the plant.

- ◆ Physical attack on the plant (see Note) has resulted in occupancy of the control room or auxiliary shutdown panels by unauthorized personnel.

END

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.7 FIRES AND SECURITY ACTIONS

CA-11
ENCLOSURE 4.1
PAGE 16 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

2. Ongoing Security
compromise.

- ◆ Adversaries commandeer an area of the plant but do not control any plant vital areas.
- ◆ Discovery of breached barrier caused by intrusion or sabotage in Vital Area
- ◆ Discovery of bomb in the protected area
- ◆ Ongoing security compromise as determined by Emergency Coordinator and Security

END

2. Imminent loss of
physical control of
a plant vital area.

- ◆ Physical attack resulting in imminent occupancy of the Control Room or other vital areas
- ◆ Discovery of bomb in a plant Vital Area.

END

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.8 SPENT FUEL DAMAGE

CP-11
ENCLOSURE 4.1
PAGE 17 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

N/A

1. Damage to Spent Fuel
with release of
radioactivity .

CONTAINMENT

- ◆ Valid Trip II Alarm
on 1EMF16 or 2EMF3

AND

Dose rate calculations
using vent sample
analysis and flow rate
data are in excess of
10 times limits
established by
Technical
Specifications

FUEL HANDLING BUILDING

- ◆ Valid Trip II Alarm
on 1EMF17 or 2EMF4

AND

Dose rate calculations
using vent sample
analysis and flow rate
data are in excess of
10 times limits
established by
Technical
Specifications

END

1. Major damage to spent
fuel with release of
radioactivity

CONTAINMENT

- ◆ Valid trip II Alarm
on 1EMF16 or 2EMF3

AND

Dose rate calculations
using unit vent sample
analyses and flow rate
data equivalent to:

Greater than or equal
to 50 mRem/hr WB or 250
mRem/hr Thyroid for 30
minutes at the site
boundary

FUEL HANDLING BUILDING

- ◆ Valid Trip II Alarm
on 1EMF17 or 2EMF4

AND

Dose rate calculations
using unit vent sample
analyses and flow rate
data equivalent to:

Greater than or equal
to 50 mRem/hr WB or 250
mRem/hr thyroid for 30
minutes at the site boundary

END

N/A

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.9 NATURAL DISASTERS AND OTHER HAZARDS

CA-11
ENCLOSURE 4.1
PAGE 18 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

1. Earthquake felt in plant and detected by seismic monitoring instruments

◆ Valid Alarm on "strong motion accelerometer"

◆ Valid Alarm on "Peak shock annunciator"

2. Low water level

◆ Lake Norman level less than or equal to 745 ft.

3. Any tornado/severe weather within the site boundary.

◆ Tornado observed on site

AND

Physical damage observed to equipment/structures within the site boundary

1. Earthquake greater than OBE

◆ Greater than 0.08 g Horizontal

◆ Greater than 0.053 g Vertical

2. Damage from tornado, sustained winds, aircraft crash, train derailment, missile, or explosion.

◆ Damage to plant equipment causing the inability to maintain cold shutdown in modes 5 and 6.

3. Release of toxic or flammable gas.

◆ Uncontrolled entry of toxic substance or flammable gas into any plant area which jeopardizes the operation of systems needed to maintain cold shutdown in Modes 5 and 6.

END

1. Earthquake greater than SSE

◆ Greater than 0.15 g Horizontal

AND

Damage to plant equipment resulting in inability to maintain subcooling greater than 0 degrees F.

◆ Greater than 0.10 g Vertical

AND

Damage to plant equipment resulting in inability to maintain subcooling greater than 0 degrees F.

2. Damage from tornado, severe weather, missile, explosion, aircraft crash, or train derailment causing a loss of functions needed for plant hot shutdown.

1. Any major natural or accidental event(s) (ie: aircraft impact, earthquakes substantially beyond design levels) which could cause massive common damage to plant systems.

◆ Recovery Manager or Emergency Coordinator judgement.

END

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.9 NATURAL DISASTERS AND OTHER HAZARDS

C-11
ENCLOSURE 4.1
PAGE 19 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

- ◆ Sustained (greater than 15 minutes) winds greater than or equal to 60 mph

AND

Physical damage observed to equipment/structures within the site boundary.

4. Aircraft crash

- ◆ Aircraft crash within the site boundary.

5. Train derailment on site.

- ◆ Train derailment resulting in physical damage to equipment/structure within site boundary.

6. Explosion within site boundary.

- ◆ Explosion within the site boundary resulting in structural damage to buildings and/or injuries to personnel.

- ◆ Failure of heat sink results in the inability to maintain Hot Shutdown conditions

AND

NC subcooling cannot be maintained greater than 0 degrees F.

- ◆ Inability to feed S/Gs from any source in Modes 1-...

AND

NC subcooling cannot be maintained greater than 0 degrees F.

3. Release of toxic or flammable gas (Modes 1-4).

- ◆ Uncontrolled entry of toxic substances or flammable gas into any plant area which prevents the operation of systems needed to maintain hot shutdown in modes 1-4.

END

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.9 NATURAL DISASTERS AND OTHER HAZARDS

CP 11
ENCLOSURE 4.1
PAGE 20 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

7. Release of toxic or flammable gases.
- ◆ Release of toxic gas resulting in personnel injury or any evacuation within the Protected Area.
 - ◆ Release of flammable gas resulting in any evacuation within the Protected Area.

END

McGUIRE NUCLEAR STATION
 EMERGENCY ACTION LEVELS
 EVENT# 4.1.10 OTHER ABNORMAL PLANT CONDITIONS

CP-11
 ENCLOSURE 4.1
 PAGE 21 OF 25

NOTIFICATION OF
 UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
 EMERGENCY

1. ECCS initiated.

- ♦ Valid S/I signal verified by redundant indication

AND

discharge into the vessel

2. Abnormal coolant temperature and/or pressure or abnormal fuel temperature

- ♦ Figure 2.1-1 Tech Spec exceeded in modes 1 and 2.
- ♦ Core sub-cooling margin less than acceptable ("Subcooling Margin Alert" annunciator).
- ♦ Tech Spec (LCO 2.1.2) Reactor Coolant System pressure exceeded in modes 3, 4, and 5.

1. Evacuation of Control Room

- ♦ Evacuation of Control Room

AND

Control established (or in process of being established) from the Auxiliary Shutdown Panel

- ♦ Inability to establish control from Auxiliary Shutdown Panel.

AND

Control established (or in process of being established) from SSF.

2. Significant loss of annunciator capability in Modes 1-4.

- ♦ Loss of 50% or more of the control room annunciators for greater than 15 minutes in Modes 1-4.

1. Evacuation of Control Room

- ♦ Evacuation of Control Room

AND

Control cannot be established from the auxiliary shutdown panel or SSF

AND

NC subcooling cannot be maintained greater than 0 degrees F.

- ♦ Evacuation of Control Room in Modes 1-3

AND

Inability to feed S/G's from any source.

2. Other unit conditions exist that in the judgement of the Recovery Manager warrant declaration of site Area Emergency.

END

1. Other unit conditions exist, from whatever source, that in the judgement of the Recovery Manager make release of large amounts of radioactivity in a short time period possible.

END

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.10 OTHER ABNORMAL PLANT CONDITIONS

CN-11
ENCLOSURE 4.1
PAGE 22 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

3. Loss of containment integrity requiring shutdown by Tech Spec

- ◆ Any automatic containment isolation valve open and inoperable and unisolable.

AND

- ◆ Load reduction or plant cooldown initiated pursuant to Tech Spec 3.6.3.
- ◆ Both air lock doors of a single airlock inoperable

AND

- ◆ Load reduction or plant cooldown initiated pursuant to Tech Spec 3.6.1.3.

3. Other unit conditions exist that in the judgement of the Shift Supervisor/Emergency Coordinator warrant declaration of the Alert classification.

END

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.10 OTHER ABNORMAL PLANT CONDITIONS

CH 11
ENCLOSURE 4.1
PAGE 23 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

4. Loss of ESF or Fire
Protection System
function.

- ◆ Both trains of any ESF system found inoperable (if caused by fire, see event #4.1.7 - Fires and Security Actions, Alert Classification).

AND

Load reduction or plant cooldown initiated in accordance with Tech Specs.

- ◆ Less than minimum channels of ESF function inoperable.

AND

Load reduction or plant cooldown initiated in accordance with Tech Specs.

- ◆ Loss of all main fire protection system water pumps.

McGUIRE NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.10 OTHER ABNORMAL PLANT CONDITIONS

CS-11
ENCLOSURE 4.1
PAGE 24 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

5. Transportation of a contaminated injured individual from the site to an offsite medical facility.
- ◆ Decontamination efforts fail to reduce external contamination below 150 cpm beta-gamma or injured may require immediate medical attention and decontamination efforts are waived.

AND

Radiation Protection personnel determine that radiological controls are required for offsite medical treatment

- ◆ Internal contamination requiring medical assessment/treatment
- ◆ External exposure requiring medical assessment/treatment

McGOWAN NUCLEAR STATION
EMERGENCY ACTION LEVELS
EVENT# 4.1.10 OTHER ABNORMAL PLANT CONDITIONS

C-11
ENCLOSURE 4.1
PAGE 25 OF 25

NOTIFICATION OF
UNUSUAL EVENT

ALERT

SITE AREA EMERGENCY

GENERAL
EMERGENCY

6. Significant Loss of
assessment capability
or communication
capability

- ◆ Loss of MNS
communications
capability with all
offsite agencies
- ◆ Loss of 50% or more of
the control room
annunciators in Modes
5, 6 for greater than
15 minutes.
- ◆ Loss of all onsite
meteorological
instrumentation

AND

Inability to contact
the National Weather
Service for backup
source of data.

7. Other conditions exist
that in the judgement
of Shift Supervisor/
Emergency Coordinator
warrant increased
awareness of local
authorities.

END

ENGINEERED SAFETY FEATURES

- 1) Containment Spray
- 2) Containment Air Return and Hydrogen Skimmer
- 3) Ice Condenser
- 4) Hydrogen Control (Hydrogen Recombiners Only)
- 5) Annulus Ventilation
- 6) Auxiliary Feedwater
- 7) Nuclear Service Water
- 8) Component Cooling
- 9) Steam Line/Feedwater Line Isolation
- 10) Containment Pressure Control
- 11) ESF Interlocks
- 12) Turbine Trip
- 13) Reactor Protection System
- 14) Emergency Diesel Generators
- 15) Emergency Switchgear
- 16) Loss of Power Actuation Circuit
- 17) Emergency Core Cooling System - Safety Injection, Residual Heat Removal, Cold Leg Accumulators, Upper Head Injection, Chemical and Volume Control System, Automatic Switchover
- 18) Containment Isolation - Phase "A" and Phase "B"