

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 A R A N 0 2 0 0 - 0 0 0 0 - 0 0 4 1 1 1 1 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 58

CONT
01 L 0 5 0 1 0 0 3 6 8 1 1 1 1 1 8 0 1 2 0 9 8 1 0
7 8 9 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 During Mode 1 operation, the "A" Core Protection Calculator (CPC) failed.
03 The DNBR/LPD trips were by-passed on the "A" CPC channel per Action #2 of
04 T.S. Table 3.1-1, placing the reactor trip logic in a two out of three trip
05 sequence. The "B", "C", and "D" channels remained operable. Similar to
06 LER 50-368/79-096 (Channel "C") and 79-075 (Channel "B"). Reportable per
07 T.S. 6.9.1.9.b.
08
09

SYSTEM CODE 11 CAUSE CODE 12 CAUSE SUBCODE 13 COMPONENT CODE 14 COMP. SUBCODE 15 VALVE SUBCODE 16
9 10 11 12 13 14 15 16

17 LER NO. 8 1 0 0 8 5 0 1 3 L 0
21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN E 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER C 4 9 0
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 Investigation revealed cause of CPC failure to be a data link failure
11 between the CPC channel and the CPC operator console. The defective data
12 link card was replaced. The bypasses were removed and the CPC channel
13 was returned to operable status.
14
15

FACILITY STATUS E 28 % POWER 0 7 1 OTHER STATUS NA METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA LOCATION OF RELEASE NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL EXPOSURES
NUMBER 0 0 0 TYPE Z 38 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL INJURIES
NUMBER 0 0 0 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

LOSS OF OR DAMAGE TO FACILITY
TYPE Z 42 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PUBLICITY
ISSUED N 44 DESCRIPTION NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NRC USE ONLY
2 0 N 44 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

8012150088