

January 22, 1990

Docket Nos. 50-317
and 50-318

DISTRIBUTION

Docket Title

PDI-1 Rdg
NRC & Local PDRs
SVarga
BBoger
CVogan

OGC
EJordan
ACRS (10)
JLinville
RCapra
DMcDonald

Mr. G. C. Creel
Vice President - Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rtes. 2 & 4
P.O. Box 1535
Lusby, Maryland 20667

Dear Mr. Creel:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - TECHNICAL SPECIFICATIONS
AMENDMENTS PROPOSED UNDER GENERIC LETTER 87-09 (UNIT 1 TAC 71225;
UNIT 2 TAC 71226)

On June 4, 1987, the Commission issued Generic Letter (GL) 87-09, "Sections 3.0 and 4.0 of the Standard Technical Specifications (STS) on the Applicability of Limiting Conditions for Operation and Surveillance Requirements." The purpose of GL 87-09 was to provide guidance to resolve generic problems arising from STS Sections 3.0.4, 4.0.3 and 4.0.4.

Subsequently, your application of November 1, 1988, as supplemented on July 21, and November 21, 1989, requested that Calvert Cliffs, Units 1 and 2, Technical Specifications, Sections 4.0.3 and 4.0.4, be amended in accordance with GL 87-09.

The NRC staff has completed its initial review of your application and has determined that additional information is needed.

Please provide the information requested in the enclosed request for additional information within 35 days of this letter's issuance date.

This request for information affects fewer than 10 respondents; therefore, OMB clearance is not required under Public Law 96-511.

Sincerely,

Original signed by

Daniel G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Project - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

OFC :PDI-1 :PDI-1 :PDI-1 :
NAME :CVogan :SMcNeil/bah :RCapra :
DATE :1/18/90 :1/22/90 :1/22/90 :
OFFICIAL RECORD COPY
Document Name: RAI 71225/71226

DF01
111



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

January 22, 1990

Docket Nos. 50-317
and 50-318

Mr. G. C. Creel
Vice President - Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rtes. 2 & 4
P.O. Box 1535
Lusby, Maryland 20667

Dear Mr. Creel:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - TECHNICAL SPECIFICATIONS
AMENDMENTS PROPOSED UNDER GENERIC LETTER 87-09 (UNIT 1 TAC 71225;
UNIT 2 TAC 71226)

On June 4, 1987, the Commission issued Generic Letter (GL) 87-09, "Sections 3.0 and 4.0 of the Standard Technical Specifications (STS) on the Applicability of Limiting Conditions for Operation and Surveillance Requirements." The purpose of GL 87-09 was to provide guidance to resolve generic problems arising from STS Sections 3.0.4, 4.0.3 and 4.0.4.

Subsequently, your application of November 1, 1988, as supplemented on July 21, and November 21, 1989, requested that Calvert Cliffs, Units 1 and 2, Technical Specifications, Sections 4.0.3 and 4.0.4, be amended in accordance with GL 87-09.

The NRC staff has completed its initial review of your application and has determined that additional information is needed.

Please provide the information requested in the enclosed request for additional information within 35 days of this letter's issuance date.

This request for information affects fewer than 10 respondents; therefore, OMB clearance is not required under Public Law 96-511.

Sincerely,

A handwritten signature in dark ink, reading "Daniel G. McDonald Jr." in a cursive style.

Daniel G. McDonald, Senior Project Manager
Project Directorate I-1
Division of Reactor Project - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

Mr. G. C. Creel
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant

cc:

Mr. William T. Bowen, President
Calvert County Board of
Commissioners
Prince Frederick, Maryland 20678

Mr. Joseph H. Walter
Engineering Division
Public Service Commission of Maryland
American Building
231 E. Baltimore Street
Baltimore, Maryland 21202-3486

D. A. Brune, Esq.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Ms. Kirsten A. Burger, Esq.
Maryland People's Counsel
American Building, 9th Floor
231 E. Baltimore Street
Baltimore, Maryland 21202

Mr. Jay E. Silberg, Esq.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW
Washington, DC 20037

Ms. Patricia Birnie
Co-Director
Maryland Safe Energy Coalition
P. O. Box 902
Columbia, Maryland 21044

Mr. W. J. Lippold, General Supervisor
Technical Services Engineering
Calvert Cliffs Nuclear Power Plant
MD Rts 2 & 4, P. O. Box 1535
Lusby, Maryland 20657

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
P. O. Box 437
Lusby, Maryland 20657

Mr. Thomas Magette
Administrator - Nuclear Evaluations
Department of Natural Resources
580 Taylor Avenue
Tawes State Office Building
PPER R3
Annapolis, Maryland 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Enclosure

REQUEST FOR ADDITIONAL INFORMATION

BALTIMORE GAS AND ELECTRIC COMPANY

CALVERT CLIFFS NUCLEAR POWER PLANT

DOCKET NOS. 50-317 AND 50-318

Generic Letter 87-09 Technical Specifications

The wording proposed in your November 21, 1989 submittal for Technical Specification (TS) 4.0.3 was not consistent with the wording provided by the NRC staff in Generic Letter (GL) 87-09. Rather, your proposed TS 4.0.3 generally encompassed the standardized TS 4.0.3 but also included an additional caveat stating that, "surveillance requirements do not have to be performed on inoperable equipment."

This portion of the proposed change to TS 4.0.3 was not discussed in your safety analysis or significant hazards determination that accompanied the amendment request.

If you wish to include this additional caveat in your proposed TS 4.0.3, please provide a supplement to your safety analysis and significant hazards determination to support the change.