

Public Service
Electric and Gas
Company

Stanley LaBruna

Public Service Electric and Gas Company P.O. Box 236, Hancocks Bridge, NJ 08038 609-339-4800

Vice President - Nuclear Operations

JAN 19 1990
NLR-N90020

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

CONFIRMATORY LETTER
BULLETIN 89-02
HOPE CREEK GENERATING STATION
DOCKET NO. 50-354

Public Service Electric and Gas Company (PSE&G) has performed a review of our engineering documentation regarding the types and composition of swing check valves in use at the Hope Creek Generating Station in accordance with Bulletin 89-02. We hereby provide confirmation that Hope Creek Generating Station does not have any safety-related Anchor Darling Model S350W swing check valves with Type 410 SS internal bolting. Hope Creek does have two types of swing check valves that are of similar design to the Anchor Darling Model S350W; however, neither of these types of valves use Type 410 SS bolting material.

A summary of our research is available on site for your review. Please feel free to contact us if you have any further questions in this regard.

Sincerely,



2002010353 900119
PDR ADOCK 05000354
Q PDC

IE32
11

JAN 19 1990

C Mr. C. Y. Shiraki
Licensing Project Manager

Mr. T. Johnson
Senior Resident Inspector

Mr. W. T. Russell, Administrator
Region I

Mr. Kent Tosch, Chief
New Jersey Department of Environmental Protection
Division of Environmental Quality
Bureau of Nuclear Engineering
CN 415
Trenton, NJ 08625