



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 22, 1996

MEMORANDUM TO: David L. Morrison, Director
Office of Nuclear Regulatory Research

FROM: David L. Meyer, Chief *DS - L Meyer*
Rules Review and Directives Branch
Division of Freedom of Information and
Publications Services
Office of Administration

SUBJECT: OFFICE CONCURRENCE ON FINAL RULE ENTITLED
"REACTOR SITE CRITERIA INCLUDING SEISMIC AND
EARTHQUAKE ENGINEERING CRITERIA FOR NUCLEAR POWER
PLANTS" (10 CFR PARTS 50, 52, and 100)

The Office of Administration concurs, subject to the comments provided, on the final rule that updates the criteria used for power reactor siting (including geologic, seismic, and earthquake engineering considerations) for future nuclear power plants. We have attached a marked copy of the final rule and accompanying documents that include our editorial and format corrections.

In addition to the statement included in this rule, the Small Business Regulatory Enforcement Fairness Act of 1996 requires agencies to submit a report transmitting a copy of each final rule to each House of Congress and the General Accounting Office before the rule takes effect. The report must include a concise general statement concerning the final rule, indicate whether the action is a "major" rule as defined by the legislation and determined by the Office of Management and Budget, and state the anticipated effective date of the final rule. We have attached a list of addresses for the required communication and a sample draft letter for a non-major rule. Your staff should contact Trip Rothschild, OGC, to coordinate with the Office of Information and Regulatory Affairs (OIRA) Office of Management and Budget concerning whether the action is a "major rule" as defined in Section 804 of the Act. Also, the Act requires that the final regulatory guides associated with this final rule be submitted to Congress when they are issued as final NRC actions.

Please note that when the rule is submitted for publication in the Federal Register, it must be presented as a single-sided copy. Also, please have a member of your staff include a 3.5-inch diskette that contains a copy of the final rule in WordPerfect 5.0 or 5.1 as part of the transmittal package. The diskette will be forwarded to the Office of the Federal Register and the Government Printing Office for their use in typesetting the document.

If you have any questions regarding our comments, please have a member of your staff contact Michael T. Lesar on 415-7163 or Alzonía Shepard on 415-6864.

Attachments: As stated

65
NRC FILE CENTER COPY

DFX2
11

100024
9606190134 960522
CF SUBJ
RES-2D-4 CF

Attachments:

1. Federal Register Notice of Rulemaking
 2. Resolution of Public Comments on the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants
 3. ACRS Letter
 4. Draft Public Announcement
 5. Draft Congressional Letters
 6. Regulatory Analysis
 7. Environmental Assessment
 - *8. Regulatory Guide 1.165 (Seismic Sources, Draft was DG-1032)
 - *9. Standard Review Plan Section 2.5.1, Revision 3
 - *10. Standard Review Plan Section 2.5.2, Revision 3
 - *11. Standard Review Plan Section 2.5.3, Revision 3
 - *12. Regulatory Guide 1.12, Revision 2 (Instrumentation, Draft was DG-1033)
 - *13. Regulatory Guide 1.166 (Plant Shutdown, Draft was DG-1034)
 - *14. Regulatory Guide 1.167 (Plant Restart, Draft was DG-1035)
 - *15. Resolution of Public Comments on Draft Regulatory Guides and Standard Review Plan Sections Pertaining to the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants
 - *16. Draft Regulatory Guide DG-4004 (General Site Suitability Criteria)
- * Commissioners, SECY, OGC only

Distribution:

R. McMullen
 N. Chokshi
 T. King
 R. Rothman
 G. Bagchi
 A. Ibrahim
 P. Sobel
 W. Travers
 C. Haughney
 SGEB r/f
 RES-2D-4

DOCUMENT NAME: a:\comm-ppr.r10 SEE PREVIOUS CONCURRENCE

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RES/DET/SGEB	RES/DET/SGEB	RES/DST/AEB	RES/DET/AD	RES/DST
NAME	RKennedy*	AMurphy*	CAder*	JMurphy*	WHodges*
DATE	5/20/96	5/20/96	5/20/96	5/20/96	5/21/96
OFFICE	RES/OD	RES/OD	NRR/DONRR	ADM/RRDB	OGC
NAME	TSpeis	DMorrison	WRussell	DMayer	MMalsch
DATE	5/21/96	5/21/96	5/ /96	5/ /96	5/24/96
OFFICE	EDO	EDO	EDO		
NAME	LSoffer	JMilhoan	JTaylor		
DATE	5/21/96	5/ /96	5/ /96		

OFFICIAL RECORD COPY

Attachments:

1. Federal Register Notice of Rulemaking
 2. Resolution of Public Comments on the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants
 3. ACRS Letter
 4. Draft Public Announcement
 5. Draft Congressional Letters
 6. Regulatory Analysis
 7. Environmental Assessment
 - *8. Regulatory Guide 1.165 (Seismic Sources, Draft was DG-1032)
 - *9. Standard Review Plan Section 2.5.1, Revision 3
 - *10. Standard Review Plan Section 2.5.2, Revision 3
 - *11. Standard Review Plan Section 2.5.3, Revision 3
 - *12. Regulatory Guide 1.12, Revision 2 (Instrumentation, Draft was DG-1033)
 - *13. Regulatory Guide 1.166 (Plant Shutdown, Draft was DG-1034)
 - *14. Regulatory Guide 1.167 (Plant Restart, Draft was DG-1035)
 - *15. Resolution of Public Comments on Draft Regulatory Guides and Standard Review Plan Sections Pertaining to the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants
 - *16. Draft Regulatory Guide DG-4004 (General Site Suitability Criteria)
- * Commissioners, SECY, OGC only

Distribution:

R. McMullen
 N. Chokshi
 T. King
 R. Rothman
 G. Bagchi
 A. Ibrahim
 P. Sobel
 W. Travers
 C. Haughney
 SGEB r/f
 RES-2D-4

DOCUMENT NAME: a:\comm-ppr.r10 SEE PREVIOUS CONCURRENCE

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RES/DET/SGEB	RES/DET/SGEB	RES/DST/AEB	RES/DET/AD	RES/DST
NAME	RKennedy*	AMurphy*	CAder*	JMurphy*	WHodges*
DATE	5/20/96	5/20/96	5/20/96	5/20/96	5/21/96
OFFICE	RES/OD	RES/OD	NRR/DONER	ADM/RRDB	OGC
NAME	TSpels	DMorrison	WRussell #1 5/22	DMeyer	MMalsch
DATE	5/21/96	5/21/96	5/22/96	5/ /96	5/ /96
OFFICE	EDO	EDO	EDO		
NAME	LSoffer	JMilhoan	JTaylor		
DATE	5/21/96	5/ /96	5/ /96		

OFFICIAL RECORD COPY

Attachments:

1. Federal Register Notice of Rulemaking
 2. Resolution of Public Comments on the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants
 3. ACRS Letter
 4. Draft Public Announcement
 5. Draft Congressional Letters
 6. Regulatory Analysis
 7. Environmental Assessment
 - *8. Regulatory Guide 1.165 (Seismic Sources, Draft was DG-1032)
 - *9. Standard Review Plan Section 2.5.1, Revision 3
 - *10. Standard Review Plan Section 2.5.2, Revision 3
 - *11. Standard Review Plan Section 2.5.3, Revision 3
 - *12. Regulatory Guide 1.12, Revision 2 (Instrumentation, Draft was DG-1033)
 - *13. Regulatory Guide 1.166 (Plant Shutdown, Draft was DG-1034)
 - *14. Regulatory Guide 1.167 (Plant Restart, Draft was DG-1035)
 - *15. Resolution of Public Comments on Draft Regulatory Guides and Standard Review Plan Sections Pertaining to the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants
 - *16. Draft Regulatory Guide DG-4004 (General Site Suitability Criteria)
- * Commissioners, SECY, OGC only

Distribution:

R. McMullen
 N. Chokshi
 T. King
 R. Rothman
 G. Bagchi
 A. Ibrahim
 P. Sobel
 W. Travers
 C. Haughney
 SGEB r/f
 RES-2D-4

DOCUMENT NAME: a:\comm-ppr.r10 SEE PREVIOUS CONCURRENCE

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RES/DET/SGEB	RES/DET/SGEB	RES/DST/AEB	RES/DET/AD	RES/DST
NAME	RKenneally*	AMurphy*	CAder*	JMurphy*	WHodges*
DATE	5/20/96	5/20/96	5/20/96	5/20/96	5/21/96
OFFICE	RES/OD	RES/OD	NRR/DONRR	ADM/RRDB	OGC
NAME	TSpeis	DMorrison	WRussell	DMeyer	MMalsch
DATE	5/21/96	5/21/96	5/ /96	5/ /96	5/ /96
OFFICE	EDO	EDO	EDO		
NAME	LSoffer	JMilhoan	JTaylor		
DATE	5/21/96	5/ /96	5/ /96		

OFFICIAL RECORD COPY

Attachments:

1. Federal Register Notice of Rulemaking
2. Resolution of Public Comments on the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants
3. ACRS Letter
4. Draft Public Announcement
5. Draft Congressional Letters
6. Regulatory Analysis
7. Environmental Assessment
- *8. Regulatory Guide 1.165 (Seismic Sources, Draft was DG-1032)
- *9. Standard Review Plan Section 2.5.1, Revision 3
- *10. Standard Review Plan Section 2.5.2, Revision 3
- *11. Standard Review Plan Section 2.5.3, Revision 3
- *12. Regulatory Guide 1.12, Revision 2 (Instrumentation, Draft was DG-1033)
- *13. Regulatory Guide 1.166 (Plant Shutdown, Draft was DG-1034)
- *14. Regulatory Guide 1.167 (Plant Restart, Draft was DG-1035)
- *15. Resolution of Public Comments on Draft Regulatory Guides and Standard Review Plan Sections Pertaining to the Proposed Seismic and Earthquake Engineering Criteria for Nuclear Power Plants

* Commissioners, SECY, OGC only

Distribution:

R. McMullen
N. Chokshi
T. King
R. Rothman
G. Bagchi
A. Ibrahim
P. Sobel
W. Travers
C. Haughney
SGEB r/f
RES-2D-4

DOCUMENT NAME: a:\comm-ppr.r9

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RES/DET/SGEB	E	RES/DET/SGEB	E	RES/DST/AEB	E	RES/DET/AD	RES/DST
NAME	RKenneally		AMurphy		CAder		JMunro	WHodges
DATE	5/20/96		5/20/96		5/20/96		5/20/96	5/20/96
OFFICE	RES/OD		RES/OD		NRR/DONRR		ADM/RRDB	OGC
NAME	TSpeis		DMorrison		WRsell		DMeyer	MMalsch
DATE	5/ /96		5/ /96		5/ /96		5/ /96	5/ /96
OFFICE	FDO		EDO		EDO			
NAME	LSoffer		JMilhoan		JTaylor			
DATE	5/ /96		5/ /96		5/ /96			

OFFICIAL RECORD COPY

ATTACHMENT 10

**REGULATORY GUIDE 1.165
DRAFT WAS DG-1032**

(SEISMIC SOURCES)



U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REGULATORY RESEARCH
DRAFT REGULATORY GUIDE

February 1995
Division 1
Task DG-1032

Contact: A.J. Murphy (301) 415-6010

DRAFT REGULATORY GUIDE DG-1032.165
(Previously issued as Draft DG-101532)

IDENTIFICATION AND CHARACTERIZATION OF SEISMIC SOURCES AND DETERMINATION OF
SAFE SHUTDOWN EARTHQUAKE GROUND MOTION

A. INTRODUCTION

The NRC has recently proposed amendments to 10 CFR Part 100, "Reactor Site Criteria," in the Federal Register on October 17, 1994 (59 FR 52255). In the proposed Section 100.23, "Geologic and Seismic Siting Factors," paragraph (c), "Geological, Seismological, and Engineering Characteristics," would require that the geological, seismological, and engineering characteristics of a site and its environs be investigated in sufficient scope and detail to permit an adequate evaluation of the proposed site, to provide sufficient information to support evaluations performed to arrive at estimates of the Safe Shutdown Earthquake Ground Motion (SSE), and to permit adequate engineering solutions to actual or potential geologic and seismic effects at the proposed site. Data on the vibratory ground motion, tectonic surface deformation, nontectonic deformation, earthquake recurrence rates, fault geometry and slip rates, site foundation material, and seismically induced floods, water waves, and other siting factors would will be obtained by reviewing pertinent literature and carrying out field investigations.

In the proposed 10 CFR Section 100.23, paragraph (d), "Geologic and Seismic Siting Factors," would require that the geologic and seismic siting factors considered for design include a determination of the SSE for the site, the potential for surface tectonic and nontectonic deformations, the design bases for seismically induced floods and water waves, and other design conditions.

This regulatory guide is being issued in draft for review. It has not received complete staff review.

It is intended to involve the public in the early stages of the development of a regulatory position in this area. It does not represent an official NRC staff position.

Public comments are being solicited on the draft guide (including any implementation schedule) and its associated regulatory analysis or value/impact statement. Comments should be accompanied by appropriate supporting data. Written comments may be submitted to the Rules Review and Directives Branch, DFIRS, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Copies of comments received may be examined at the NRC Public Document Room, 2120 L Street NW, Washington, DC. Comments will be most helpful if received by May 12, 1995.

Requests for single copies of draft guide (which may be reproduced) or for placement on an automatic distribution list for single copies of future guides in specific divisions should be made in writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Office of Administration, Distribution and Mail Services Section.

1 ~~In the proposed~~ In 10 CFR Section 100.23, paragraph (d)(1),
2 "Determination of the Safe Shutdown Earthquake Ground Motion," ~~would require~~
3 that uncertainty inherent in estimate of the SSE be addressed through an
4 appropriate analysis, such as a probabilistic seismic hazard analysis or
5 suitable sensitivity analysis.

6 This guide ~~is has~~ being ~~been~~ developed to provide general guidance on
7 procedures acceptable to the NRC staff ~~for to~~ (1) conducting geological,
8 geophysical, seismological, and geotechnical investigations, (2) identifying
9 and characterizing seismic sources, (3) conducting probabilistic seismic
10 hazard analyses, and (4) determining the SSE for satisfying the requirement
11 of ~~the proposed Section~~ 10 CFR 100.23.

12 This guide contains several appendices that address the objectives
13 stated above. Appendix A contains a list of definitions of pertinent terms.
14 Appendix B describes the procedure used to determine the reference probability
15 for the SSE exceedance level that is acceptable to the staff. Appendix C
16 discusses the development of a seismic hazard information base and the
17 determination of the probabilistic ground motion level and controlling
18 earthquakes. Appendix D discusses site-specific geological, seismological,
19 and geophysical investigations. Appendix E describes a method to confirm the
20 adequacy of existing seismic sources and source parameters as the basis for
21 determining the SSE for a site. Appendix F describes procedures to determine
22 the SSE.

23 ~~Regulatory guides are issued to describe and make available to the~~
24 ~~public such information as methods acceptable to the NRC staff for~~
25 ~~implementing specific parts of the Commission's regulations, techniques used~~
26 ~~by the staff in evaluating specific problems or postulated accidents, and~~
27 ~~guidance to applicants. Regulatory guides are not substitutes for~~
28 ~~regulations, and compliance with regulatory guides is not required.~~
29 ~~Regulatory guides are issued in draft form for public comment to involve the~~
30 ~~public in the early stages of developing the regulatory positions. Draft~~
31 ~~regulatory guides have not received complete staff review and do not represent~~
32 ~~official NRC staff positions.~~

33 Any information collection activities mentioned in this regulatory guide
34 are contained as requirements ~~in the proposed amendments to~~ in 10 CFR Part
35 100, ~~that would which~~ provides the regulatory basis for this guide. The
36 ~~proposed amendments have been submitted to the~~ information collection
37 requirements in 10 CFR Part 100 have been approved by the Office of Management

1 and Budget for clearance that may be appropriate under the Paperwork Reduction
2 Act. Such clearance, if obtained, would also apply to any information
3 collection activities mentioned in this guide. Approval No. 3150-0093.

4 B. DISCUSSION

5 BACKGROUND

6 A probabilistic seismic hazard analysis (PSHA) has been identified in
7 the proposed Section 10 CFR 100.23 as one of the means to address determine
8 the SSE and account for uncertainties in estimates of the SSE the
9 seismological and geological evaluations. The proposed rule further
10 recognizes that the nature of uncertainty and the appropriate approach to
11 account for it depend on the tectonic regime and parameters such as the
12 knowledge of seismic sources, the existence of historical and recorded data,
13 and the level of understanding of the tectonics. Therefore, methods other
14 than probabilistic methods such as sensitivity analyses may be adequate for
15 some sites to account for uncertainties.

16 Appendix A, "Seismic and Geologic Siting Criteria for Nuclear Power
17 Plants," to 10 CFR Part 100 is primarily based on a deterministic methodology.
18 Past licensing experience in applying Appendix A has demonstrated the need to
19 formulate procedures that quantitatively incorporate uncertainty (including
20 alternative scientific interpretations) in the evaluation of seismic hazards.
21 A single deterministic representation of seismic sources and ground motions at
22 a site does may not explicitly provide a quantitative representation of the
23 uncertainties in scientific interpretations of geological, seismological, and
24 geophysical data and alternative scientific interpretations.

25 Probabilistic procedures were developed during the past 10-15 years
26 specifically for nuclear power plant seismic hazard assessments in the Central
27 and Eastern United States (CEUS) (the area east of the Rocky Mountains), also
28 referred to as the Stable Continent Region (SCR). These procedures provide a
29 structured approach for decision making with respect to the SSE when performed
30 together with site-specific investigations. A PSHA provides a framework to
31 address the uncertainties associated with the identification and
32 characterization of seismic sources by incorporating multiple interpretations
33 of seismological parameters. A PSHA also provides an evaluation of the
34 likelihood of SSE recurrence during the design life time of a given facility,

1 given the recurrence interval and recurrence pattern of pertinent seismic
2 sources. Within the framework of a probabilistic analysis, uncertainties in
3 the characterization of seismic sources and ground motions are identified and
4 incorporated in the procedure at each step of the process for estimating the
5 SSE. The role of ~~site-specific regional and site~~ geological, seismological,
6 and geophysical investigations is to develop geosciences information about the
7 site for use in the detailed design analysis of the facility, as well as to
8 ensure that the seismic hazard analysis is based on up-to-date information.

9 Experience in performing seismic hazard evaluations in active plate-
10 margin regions in the Western United States (for example, the San Gregorio-
11 Hosgri fault zone and the Cascadia Subduction Zone) has also identified
12 uncertainties associated with the characterization of seismic sources (Refs.
13 1, 2, and 3). Sources of uncertainty include fault geometry, rupture
14 segmentation, rupture extent, seismic-activity rate, ground motion, and
15 earthquake occurrence modeling. As is the case for sites in the CEUS,
16 alternative hypotheses and parameters must be considered to account for these
17 uncertainties.

18 Uncertainties associated with the identification and characterization of
19 seismic sources in tectonic environments in both the CEUS and the Western
20 United States should be evaluated. Therefore, the same basic approach can be
21 applied to determine the SSE.

22 APPROACH

23 The general process to determine the SSE at a site ~~should in general~~
24 includes:

- 26 1. Site- and region-specific geological, seismological, geophysical,
27 and geotechnical investigations, and
- 28 2. A probabilistic seismic hazard assessment.

29 CENTRAL AND EASTERN UNITED STATES

30 The CEUS is considered to be that part of the United States east of the
31 Rocky Mountain front, or east of Longitude 105° West (Refs. 4 and 5). To
32 determine the SSE in the CEUS, an accepted PSHA methodology with a range of
33 credible alternative input interpretations should be used. For sites in the

1 CEUS, the seismic hazard methods, the data developed, and seismic sources
2 identified by Lawrence Livermore National Laboratory (LLNL) (Refs. 4, 5, and
3 6) and the Electric Power Research Institute (EPRI) (Ref. 7) have been
4 reviewed and accepted by the staff. The LLNL and EPRI studies developed data
5 bases and scientific interpretations of available information and determined
6 seismic sources and source characterizations for the CEUS (e.g., earthquake
7 occurrence rates, estimates of maximum magnitude).

8 In the CEUS, characterization of seismic sources is more problematic
9 than in the active plate-margin region because there is generally no clear
10 association between seismicity and known tectonic structures or near-surface
11 geology. In general, the observed geologic structures were generated in
12 response to tectonic forces that no longer exist and ~~have~~ bear little or no
13 correlation with current tectonic forces. ~~Thus, there is greater uncertainty~~
14 ~~in making judgments about the CEUS than there is for active plate margin~~
15 ~~regions, and Therefore,~~ it is important to account for this uncertainty by the
16 use of multiple alternative models.

17 The identification of seismic sources and reasonable alternatives in the
18 CEUS considers hypotheses presently advocated for the occurrence of
19 earthquakes in the CEUS (for example, the reactivation of favorably oriented
20 zones of weakness or the local amplification and release of stresses
21 concentrated around a geologic structure). In tectonically active areas of
22 the CEUS, such as the New Madrid Seismic Zone, where geological,
23 seismological, and geophysical evidence suggest the nature of the sources that
24 generate the earthquakes ~~in that region~~, it may be more appropriate to
25 evaluate those seismic sources by using procedures similar to those normally
26 applicable ~~applied~~ in the Western United States.

27 28 WESTERN UNITED STATES

29 The Western United States is considered to be that part of the United
30 States that lies west of the Rocky Mountain front, or west of approximately
31 105° West Longitude. For the Western United States, an information base of
32 earth science data and scientific interpretations of seismic sources and
33 source characterizations (e.g., geometry, seismicity parameters) comparable to
34 the CEUS as documented in the LLNL and EPRI studies does not exist. For this
35 region, specific interpretations on a site-by-site basis should be applied
36 (Ref. 1).

1 The active plate-margin region includes, for example, coastal
2 California, Oregon, and Washington. For the active plate-margin region, where
3 earthquakes can often be correlated with known tectonic structures, those
4 structures should be assessed for their earthquake and surface deformation
5 potential. In this region, at least three types of sources exist: (1) faults
6 that are known to be at or near the surface, (2) buried (blind) sources that
7 may often be manifested as folds at the earth's surface, and (3) subduction
8 zone sources, such as those in the Pacific Northwest. The nature of surface
9 faults can be evaluated by conventional surface and near-surface investigation
10 techniques to assess strike orientation, geometry, sense of displacements,
11 length of rupture, Quaternary history, etc.

12 Buried (blind) faults are often ~~accompanied by coseismic~~ associated with
13 surficial deformation such as folding, uplift, or subsidence. The surface
14 expression of blind faulting can be detected by mapping the uplifted or down-
15 dropped geomorphological features or stratigraphy, survey leveling, and
16 geodetic methods. The nature of the structure at depth can often be evaluated
17 by core borings and geophysical techniques.

18 Continental United States subduction zones are located in the Pacific
19 Northwest and Alaska. Seismic sources associated with subduction zones are
20 sources within the overriding plate, on the interface between the subducting
21 and overriding lithospheric plates, and ~~intraslab sources~~ in the interior of
22 the downgoing oceanic slab. The characterization of subduction zone seismic
23 sources includes consideration of the ~~following~~ three-dimensional geometry
24 of the subducting plate, rupture segmentation of subduction zones, geometry of
25 historical ruptures, constraints on the up-dip and down-dip extent of rupture,
26 and comparisons with other subduction zones worldwide.

27 The Basin and Range region of the Western United States, and to a lesser
28 extent the Pacific Northwest and the Central United States, ~~include~~ exhibit
29 temporal clustering of earthquakes. Temporal clustering is best exemplified
30 by the rupture histories within the Wasatch fault zone in Utah and the Meers
31 fault in central Oklahoma, where several large late Holocene coseismic
32 faulting events occurred at relatively close intervals (hundreds to thousands
33 of years) that were preceded by long periods of quiescence that lasted
34 thousands to tens of thousand years. Temporal clustering should be considered
35 in these regions or wherever paleoseismic evidence indicates that it has
36 occurred.

C. REGULATORY POSITION

1. GEOLOGICAL, GEOPHYSICAL, SEISMOLOGICAL, AND GEOTECHNICAL INVESTIGATIONS

1.1 Comprehensive geological, seismological, geophysical, and geotechnical investigations of the site and regions around the site should be performed. For existing nuclear power plant sites where additional units are planned, the geosciences technical information used originally used to validate those sites may be inadequate, depending on how much new or additional information has become available since the initial investigations and analyses were performed, the quality of the investigations performed at the time, and the complexity of the site and regional geology and seismology. This technical information should be utilized along with all other available information to plan and determine the scope of additional investigations. These investigations described in this regulatory guide are performed primarily to gather information needed to confirm the suitability of the site and to gather data pertinent to the safe design and construction of the nuclear power plant. Appropriate geological, seismological, and geophysical investigations are described in Appendix D to this draft guide. Geotechnical investigations are described in Regulatory Guide 1.132, "Site Investigations for Foundations of Nuclear Power Plants" (Ref. 8). Another important purpose for the site-specific investigations is to determine whether there are new data or interpretations that are not adequately incorporated in the existing PSHA databases. Appendix E describes a method for evaluating new information derived from the site-specific investigations in the context of the PSHA.

These investigations should be performed at four levels, with the degree of their detail based on distance from the site, the nature of the Quaternary tectonic regime, the geological complexity of the site and region, the existence of potential seismic sources, the potential for surface deformations, etc. A more detailed discussion of the areas and levels of investigations and the bases for them is presented in Appendix A to this regulatory guide. The levels of investigation are characterized as follows.

1. Regional geological and seismological investigations such as geological reconnaissances and literature reviews should be are not expected to be extensive nor in great detail, but should

1 include literature reviews, the study of maps and remote sensing
2 data, and, if necessary, ground truth reconnaissances conducted
3 within a radius of 320 km (200 miles) of the site to identify
4 seismic sources (seismogenic and capable tectonic sources).

5 2. Geological, seismological, and geophysical investigations should
6 be carried out within a radius of 40 km (25 miles) in greater
7 detail than the regional investigations to identify and
8 characterize the seismic and surface deformation potential of any
9 capable tectonic sources and the seismic potential of seismogenic
10 sources, or to demonstrate that such structures are not present.
11 Sites with capable tectonic or seismogenic sources within a radius
12 of 40 km (25 miles) may require more extensive geological and
13 seismological investigations and analyses (similar in detail to
14 investigations and analysis usually preferred within an 8-km (5-
15 mile) radius).

16 3. Detailed geological, seismological, geophysical, and geotechnical
17 investigations should be conducted within a radius of 8 km (5
18 miles) of the site, as appropriate, to evaluate the potential for
19 tectonic deformation at or near the ground surface and to assess
20 the ground motion transmission characteristics of soils and rocks
21 in the site vicinity. Investigations should include monitoring by
22 a network of seismic stations.

23 4. Very detailed geological, geophysical, and geotechnical
24 engineering investigations should be conducted within the site
25 (radius of approximately 1 km (0.5 miles)) to assess specific
26 soil and rock characteristics as described in Regulatory Guide
27 1.132 (Ref. 8).

28 1.2 The areas of investigations may be expanded beyond those specified
29 above in regions that include capable tectonic sources, relatively high
30 seismicity, ~~or~~ complex geology, or ~~that which~~ have experienced a large
31 geologically recent earthquake.

1 1.3 It should be demonstrated that deformation features discovered
2 during construction, particularly faults, do not have the potential to
3 compromise the safety of the plant. The two-step licensing practice, ~~which~~
4 ~~requiring~~ applicants to acquire a Construction Permit (P), and then during
5 construction apply for an Operating License (OL), has ~~been~~ expanded ~~modified~~
6 to allow for an alternative procedure. The requirements and procedures
7 applicable to NRC's issuance of combined licenses for nuclear power facilities
8 are in 10 CFR 52.71. Applying the combined licensing procedure to a site
9 could result in the award of a license prior to ~~the start of~~ construction.
10 During the construction of nuclear power plants licensed in the past two
11 decades, previously unknown faults were often discovered in site excavations.
12 Before ~~issuance of the~~ ~~an OL would be issued~~, it was necessary to
13 demonstrate that the faults in the excavation posed no hazard to the facility.
14 Under the combined license procedure, these kinds of features should be mapped
15 and assessed as to their rupture and ground motion generating potential while
16 the excavations' walls and bases are exposed. Therefore, a commitment should
17 be made, in documents (Safety Analysis Reports) supporting the license
18 application, ~~to geologically map all excavations and to notify the NRC staff~~
19 ~~when excavations are open for inspection and to geologically map all~~
20 ~~excavations.~~

21 1.4 ~~Data~~ ~~Sufficient data~~ to clearly justify all conclusions should be
22 presented. Because engineering solutions cannot always be ~~satisfactorily~~
23 demonstrated for the effects of permanent ground displacement, it is prudent
24 to avoid a site that has a potential for surface or near-surface deformation.
25 Such sites normally ~~require~~ require extensive additional investigations.

26 1.5 For the site and ~~for~~ the area surrounding the site, the
27 lithologic, stratigraphic, hydrologic, and structural geologic conditions
28 should be characterized. The investigations should include the measurement of
29 the static and dynamic engineering properties of the materials underlying the
30 site and an evaluation of physical evidence concerning the behavior during
31 prior earthquakes of the surficial materials and the substrata underlying the
32 site. The properties needed to assess the behavior of the underlying material
33 during earthquakes, including the potential for liquefaction, and the
34 characteristics of the underlying material in transmitting earthquake ground
35 motions to the foundations of the plant (such as seismic wave velocities,

density, water content, porosity, elastic moduli, and strength) should be measured.

2. SEISMIC SOURCES SIGNIFICANT TO THE SITE SEISMIC HAZARD

~~2.1~~ For sites located in the CEUS, when the EPRI and LLNL PSHA methodologies are used to determine the SSE, it still may be necessary to investigate and characterize potential seismic sources that were previously unknown or uncharacterized, and to perform sensitivity analyses to assess their significance to the seismic hazard estimate. However, it is expected that newly discovered seismic sources, along with their uncertainties, are enveloped by the data base of the PSHA methods used. The results of investigations discussed in Regulatory Position 1 should be used, in accordance with Appendix E, to determine whether updating of the LLNL or EPRI seismic sources and their characterization should be updated is needed. The guidance in Subsections Regulatory Positions 2.2 and 2.3 below and in Appendix D of this guide may be used if additional seismic sources are to be developed as a result of investigations.

2.1.2 When the LLNL and EPRI methods are not used or are not applicable, the guidance in Regulatory Positions 2.2 and 2.3 should be used ~~this and the following Subsection 2.3 provide general guidance~~ for identification and characterization of seismic sources. The uncertainties in the characterization of seismic sources should be addressed as appropriate. A seismic source is a general term referring to both seismogenic sources and capable tectonic sources. The main distinction between these two types of seismic sources is that a seismogenic source would not cause surface displacement, but a capable tectonic source causes surface or near-surface displacement.

Identification and characterization of seismic sources should be based on regional and site geological and geophysical data, historical and instrumental seismicity data, the regional stress field, and geological evidence of prehistoric earthquakes. Investigations to identify seismic sources are described in Appendix D. The bases for the identification of seismic sources should be documented. A general list of characteristics to be evaluated for a seismic source is presented in Appendix D.

1 2.23 As part of the seismic source characterization, the seismic
2 potential ~~{magnitude and recurrence rate}~~ for each source should be
3 determined~~evaluated~~. Typically, characterization of the seismic potential
4 consists of four equally important elements:

5 1.) Selection of a model for the spatial distribution of
6 earthquakes in a source.

7 2.) Selection of a model for the temporal distribution of
8 earthquakes in a source.

9 3.) Selection of a model for the relative frequency of
10 earthquakes of various magnitudes, including an estimate for
11 the largest earthquake that could occur in the source under
12 the current tectonic regime.

13 4.) A complete description of the uncertainty.

14 For example, in the LLNL study a truncated exponential model was used
15 for the distribution of magnitudes given that an earthquake has occurred in a
16 source. A stationary Poisson process is used to model the spatial and
17 temporal occurrences of earthquakes in a source.

18 For a general discussion of evaluating the earthquake potential and
19 characterizing the uncertainty, refer to the Senior Seismic Hazard Analysis
20 Committee Report (1995) (Ref. 9).

21 2.3.1 For sites in the CEUS, when the LLNL or EPRI method is not used
22 or not applicable (such as in the New Madrid Seismic Zone, etc.), then it is
23 necessary to evaluate the seismic potential for each source. The seismic
24 sources and data that have been accepted by the NRC in past licensing
25 decisions may be used, along with the data gathered from~~as the result of the~~
26 investigations carried out as described in Section 1.

27 Generally, the seismic sources for the CEUS are area sources because
28 there is uncertainty about the underlying causes of earthquakes. This
29 uncertainty is due to ~~a~~the lack of active surface faulting, a low rate of

1 seismic activity and a short historical record. The assessment of earthquake
2 recurrence for CEUS area sources commonly relies heavily on catalogs of
3 observed seismicity. Because these catalogs are too short and incomplete and
4 cover a relatively short period of time, it is difficult to obtain reliable
5 estimates of the rate of activity. Considerable care must be taken to correct
6 for incompleteness and to model the uncertainty in the rate of earthquake
7 recurrence. To completely characterize the seismic potential for a source it
8 is also necessary to estimate the largest earthquake magnitude that a seismic
9 source is capable of generating under the current tectonic regime. This
10 estimated magnitude defines the upper-bound of the earthquake recurrence
11 relationship.

12 The assessment of earthquake potential for area sources is particularly
13 difficult because the physical constraint most important to the assessment,—
14 the dimensions of the fault rupture,— is not known. As a result, the primary
15 methods for assessing maximum earthquakes for area sources usually include a
16 consideration of the historical seismicity record, the pattern and rate of
17 seismic activity, the Quaternary (2 million years and younger),
18 characteristics of the source, the current stress regime (and how it aligns
19 with known tectonic structures), paleoseismic data, and analogies to other
20 sources in regions considered tectonically similar to the CEUS. Because of
21 the shortness of the historical catalog and low rate of seismic activity,
22 considerable judgement is needed. It is important to characterize the large
23 uncertainties in the assessment of the earthquake potential.

24 ~~For sites located in the CEUS (when the LLNL or EPRI method is not used or~~
25 ~~not applicable), the seismic sources and data that have been accepted by the~~
26 ~~NRC staff in past licensing decisions may be used to estimate seismic~~
27 ~~potential. It is necessary to use a variety of approaches to estimate the~~
28 ~~maximum magnitude for a seismic source in the CEUS because there is~~
29 ~~uncertainty about the underlying causes of earthquakes because of due to the~~
30 ~~lack of active surface faulting. Also, there is a short historical record and~~
31 ~~low seismicity rate. The determination of the maximum magnitude for each~~
32 ~~identified seismic source is based on the maximum historical earthquake, the~~
33 ~~pattern and rate of seismic activity, the Quaternary (2 million years and~~
34 ~~younger) characteristics of the source, the current stress regime (and how it~~
35 ~~aligns with the known tectonic structures in the source), and paleoseismic~~

1 ~~data. These seismic sources and their parameters should be used to judge the~~
2 ~~adequacy of seismic sources and parameters used in the LLNL or EPRI PSHA.~~

3 2.23.2 For sites located within the Western United States,
4 earthquakes can often be associated with known tectonic structures. For
5 faults, the ~~maximum-magnitude~~ earthquake **potential** is related to the
6 characteristics of the ~~estimated rupture, such as the length or the amount of~~
7 ~~fault displacement~~ **for the future rupture, such as the total rupture area, or**
8 **the length, or the amount of fault displacement.** The following empirical
9 relations can be used to estimate the earthquake potential from fault behavior
10 data and also to estimate the amount of displacement that might be expected
11 for a given magnitude. It is prudent to use several of these different
12 relations to obtain an estimate of the earthquake magnitude.

- 13 1. Surface rupture length versus magnitude (Refs. ~~9-12~~ **10-13**).
- 14 2. Subsurface rupture length versus magnitude (Ref. ~~143~~).
- 15 3. Rupture area versus magnitude (Ref. ~~154~~).
- 16 4. Maximum and average displacement versus magnitude (Ref.
17 ~~143~~).
- 18 5. Slip rate versus magnitude (Ref. ~~165~~).

19 ~~Fault hazard analyses in the Western United States using these and other~~
20 ~~methods should consider the frequency of occurrence and calculated slip rates~~
21 ~~on faults based on the geochronology of strata and crosscutting relationships.~~
22 ~~Additionally, the phenomenon of temporal clustering should be considered when~~
23 ~~there is geological evidence of its past occurrence.~~

24 **When such correlations as References ~~9-15~~ 10-16 are used, the**
25 **earthquake potential is often evaluated as the mean of the distribution. The**
26 **difficult issue is the evaluation of the appropriate rupture dimension to be**
27 **used. This is a judgemental process based on geological data for the fault in**
28 **question and the behavior of other regional fault systems of the same type.**

29 **The other elements of the recurrence model are generally obtained using**
30 **catalogs of seismicity, fault slip rate, and other data. In some cases, it**

may be appropriate to use recurrence models with memory. All the sources of uncertainty must be appropriately modeled. Additionally, the phenomenon of temporal clustering should be considered when there is geological evidence of its past occurrence.

2.23.3 For sites near subduction zones, such as in the Pacific Northwest and Alaska, the maximum magnitude must be assessed for subduction zone seismic sources. Worldwide observations indicate that the largest known earthquakes are associated with the plate interface, although intraslab earthquakes may also have large magnitudes. The assessment of plate interface earthquakes can be based on estimates of the expected dimensions of rupture or analogies to other subduction zones worldwide.

3. PROBABILISTIC SEISMIC HAZARD ANALYSIS (PSHA) PROCEDURES

A PSHA should be performed for the site as it allows the use of multiple models to estimate the likelihood of earthquake ground motions occurring at a site, and a PSHA systematically takes into account uncertainties that exist in various parameters (such as seismic sources, maximum earthquakes, and ground motion attenuation). Alternative hypotheses are considered in a quantitative fashion in a PSHA. The PSHA, and Alternative hypotheses can also be used to evaluate the hazard sensitivity of the hazard to the uncertainties in the varying significant parameters and to identify the relative contribution of each seismic source to the hazard. Reference 9 provides guidance for conducting a PSHA.

The following steps describe a PSHA procedure that is acceptable to the NRC staff for performing a PSHA. The details of the calculational aspects of deriving controlling earthquakes from the PSHA are included in Appendix C.

1. Perform regional and site geological, seismological, and geophysical investigations in accordance with Regulatory Position 1 and Appendix D.
2. For CEUS sites, perform an evaluation of LLNL or EPRI seismic sources in accordance with Appendix E to determine whether they are consistent with the site-specific data gathered in Step 1 or require updating.

1 The PSHA should only be updated if ~~it will lead to higher~~
2 ~~hazard estimates.~~ the new information indicates that the
3 current version significantly underestimates the hazard and
4 there is a strong technical basis that supports such a
5 revision. It may be possible to justify a lower hazard
6 estimate with an exceptionally strong technical basis.
7 However, it is expected that large uncertainties in
8 estimating seismic hazard in the CEUS ~~will continue to exist~~
9 in the future, and substantial delays in the licensing
10 process will result in trying to address them with respect
11 to a specific site. For these reasons the NRC staff
12 discourages efforts to justify a lower hazard estimate.
13 ~~For~~In most cases, limited-scope sensitivity studies should
14 be sufficient to demonstrate that the existing data base in
15 the PSHA envelops the findings ~~from~~ site-specific
16 investigations. In general, the significant revisions to
17 the LLNL and EPRI data base ~~are~~is to be ~~only~~undertaken only
18 periodically (every ten years), or when there is an
19 important new finding or occurrence ~~that has, based on~~
20 ~~sensitivity studies, resulted in a significant increase in~~
21 ~~the hazard estimate.~~ TheAn overall revision of the data
22 base would~~will~~ also require a reexamination of the
23 acceptability of the reference probability discussed in
24 Appendix B and used in Step 4 below. Any significant update
25 should follow the guidance of Reference 9.

- 26 3. For CEUS sites only, ~~perform~~ the LLNL or EPRI probabilistic
27 seismic hazard analysis ~~(for CEUS sites only)~~ using original
28 or updated sources as determined in Step 2, ~~or a site-~~
29 ~~specific PSHA~~ ~~For~~ sites in other parts of the country,
30 perform a site-specific PSHA (Reference 9). The ground
31 motion estimates should be made for rock conditions in the
32 free-field or by assuming hypothetical rock conditions for a
33 nonrock site to develop the seismic hazard information base
34 discussed in Appendix C.

1 4. Using the reference probability ($1E-5$ per year) described in
2 Appendix B, ~~which is applicable to all sites~~, determine 5%
3 of ~~the~~ critically damped median spectral ground motion
4 levels for the average of 5 and 10 Hz, $S_{a,5-10}$, and for the
5 average of 1 and 2.5 Hz, $S_{a,1-2.5}$. Appendix B discusses
6 situations in which an alternative reference probability may
7 be more appropriate. The alternative reference probability
8 is reviewed and accepted on a case-by-case basis. Appendix
9 B also describes a procedure that should be used when a
10 general revision to the reference probability is needed.

11 5. ~~Deaggregation of the median probability~~ ~~is~~ the hazard
12 ~~characterization~~ in accordance with Appendix C to determine
13 the controlling earthquakes (i.e., magnitudes and
14 distances). Document the hazard information base as
15 discussed in Appendix C.

16 4. PROCEDURES FOR DETERMINING THE SSE

17 After completing the PSHA (See Regulatory Position 3) and determining
18 ~~the~~ controlling earthquakes, the following procedure should be used to
19 determine the SSE. Appendix F contains an additional discussion of some of
20 the characteristics of the SSE.

21 1. With the controlling earthquakes determined as described in
22 Regulatory Position 3 and by using the procedures in ~~Draft~~
23 Standard Review Plan (SRP) Section 2.5.2 (which may include
24 the use of ground motion models not included in the
25 ~~PSHA probabilistic seismic hazard analysis~~ but that are more
26 appropriate for the source, region, and site under
27 consideration or that represent the latest scientific
28 development), develop 5% of critical damping response
29 spectral shapes for the actual or assumed rock conditions.
30 The same controlling earthquakes are also used to derive
31 vertical response spectral shapes.

1 2. Use $S_{a,5-10}$ to scale the response spectrum shape corresponding
2 to the controlling earthquake. If, as described in Appendix
3 C, there is a controlling earthquake for $S_{a,1-2.5}$, determine
4 that the $S_{a,5-10}$ scaled response spectrum also envelopes the
5 ground motion spectrum for the controlling earthquake for
6 $S_{a,1-2.5}$. Otherwise, modify the shape to envelope the low-
7 frequency spectrum or use two spectra in the following
8 steps. See additional discussion in Appendix F. For ~~the~~ the
9 rock site go to Step 4.

10 3. For ~~the~~ nonrock sites, perform a site-specific soil
11 amplification analysis considering uncertainties in site-
12 specific geotechnical properties and parameters to determine
13 response spectra at the free ground surface in the free-
14 field for the actual site conditions.

15 4. Compare the smooth SSE spectrum or spectra used in design
16 (e.g., 0.3g, broad-band spectra used in Advanced Light
17 Water Reactor designs) with the spectrum or spectra
18 determined in Step 2 for rock sites or determined in Step 3
19 for the nonrock sites to assess the adequacy of the SSE
20 spectrum or spectra.

21 ~~For situations where~~ When site-specific design response
22 spectra are needed, ~~7~~ to obtain an adequate design SSE based
23 on the site-specific response spectrum or spectra, develop a
24 smooth spectrum or spectra or use a standard broad band
25 shape that envelopes the spectra of Step 2 or Step 3.

26 Additional discussion of this step is provided in
27 Appendix F.

28 D. IMPLEMENTATION

29 The purpose of this section is to provide guidance to applicants and
30 licensees regarding the NRC staff's plans for using this regulatory guide.

31 ~~This proposed revision has been released to encourage public~~
32 ~~participation in its development.~~ Except in those cases in which the
33 applicant proposes an acceptable alternative method for complying with the

1 specified portions of the Commission's regulations, ~~the method to be described~~
2 ~~in this active guide reflecting public comments will~~ be used in the
3 evaluation of applications for construction permits, operating licenses, early
4 site permits, or combined licenses submitted after ~~the implementation date to~~
5 ~~be specified in the active guide~~ EFFECTIVE DATE OF THE FINAL RULE. This guide
6 ~~would~~ will not be used in the evaluation of an application for an operating
7 license submitted after ~~the implementation date to be specified in the active~~
8 ~~guide~~ EFFECTIVE DATE OF THE FINAL RULE if the construction permit was issued
9 prior to that date.

REFERENCES

1. Pacific Gas and Electric Company, "Final Report of the Diablo Canyon Long Term Seismic Program; Diablo Canyon Power Plant," Docket Nos. 50-275 and 50-323, 1988.¹
2. H. Rood et al., "Safety Evaluation Report Related to the Operation of Diablo Canyon Nuclear Power Plant, Units 1 and 2," NUREG-0675, Supplement No. 34, USNRC, June 1991.²
3. Letter from G. Sorensen, Washington Public Power Supply System, to Document Control Branch, USNRC. Subject: Nuclear Project No. 3, Resolution of Key Licensing Issues, Response; February 29, 1988.¹
4. D.L. Bernreuter et al., "Seismic Hazard Characterization of 69 Nuclear Plant Sites East of the Rocky Mountains," NUREG/CR-5250, Volumes 1-8, January 1989.²
5. P. Sobel, "Revised Livermore Seismic Hazard Estimates for Sixty-Nine Nuclear Power Plant Sites East of the Rocky Mountains," NUREG-1488, USNRC, April 1994.²
6. J.B. Savy et al., "Eastern Seismic Hazard Characterization Update," UCRL-ID-115111, Lawrence Livermore National Laboratory, June 1993.¹ (Accession number 9310190318 in NRC's Public Document Room)

¹Copies are available for inspection or copying for a fee from the NRC Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax (202)634-3343.

²Copies are available for inspection or copying for a fee from the NRC Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax (202)634-3343. Copies may be purchased at current rates from the U.S. Government Printing Office, P.O. Box 37082, Washington, DC 20402-9328 (telephone (202)512-2249); or from the National Technical Information Service by writing NTIS at 5285 Port Royal Road, Springfield, VA 22161.

- 1 7. Electric Power Research Institute, "Probabilistic Seismic Hazard
2 Evaluations at Nuclear Power Plant Sites in the Central and Eastern
3 United States," NP-4726, All Volumes, 1989-1991.
- 4 8. USNRC, "Site Investigations for Foundations of Nuclear Power Plants,"
5 Regulatory Guide 1.132.²⁸
- 6 9. Senior seismic Hazard Analysis Committee (SSHAC), "Recommendations for
7 Probabilistic Seismic Hazard Analysis: Guidance on Uncertainty and Use
8 of Experts," NUREG/CR-6372, August, 1995.
- 9 109. D.B. Slemmons, "Faults and Earthquake Magnitude," U.S. Army Corps of
10 Engineers, Waterways Experiment Station, Misc. Papers S-73-1, Report 6,
11 1977.
- 12 110. D.B. Slemmons, "Determination of Design Earthquake Magnitudes for
13 Microzonation," Proceedings of the Third International Microzonation
14 Conference, University of Washington, Seattle, Volume 1, pp. 119-130,
15 1982.¹
- 16 121. M.G. Bonilla, H.A. Villalobos, and R.E. Wallace, "Exploratory Trench
17 Across the Pleasant Valley Fault, Nevada," Professional Paper 1274-B,
18 U.S. Geological Survey, pp. B1-B14, 1984.¹
- 19 132. S.G. Wesnousky, "Relationship Between Total Affect, Degree of Fault
20 Trace Complexity, and Earthquake Size on Major Strike-Slip Faults in
21 California" (Abs), Seismological Research Letters, Volume 59, No. 1,
22 p. 3, 1988.
- 23 143. D.L. Wells, and K.J. Coppersmith, "New Empirical Relationships Among
24 Magnitude, Rupture Length, Rupture Width, Rupture Area, and Surface
25 Displacement," Bulletin of the Seismological Society of America, Volume
26 84, August 1994.

27 ²⁸Single copies of the regulatory guides, both active and draft, may be
28 obtained free of charge by writing the Office of Administration, Attn:
29 Distribution and Services Section, USNRC, Washington, DC 20555 or by fax at
30 (302)415-2260.

- 1 154. M. Wyss, "Estimating Maximum Expectable Magnitude of Earthquakes from
2 Fault Dimensions," Geology, Volume 7 (7), pp. 336-340, 1979.
- 3 165. D.P. Schwartz and K.J. Coppersmith, "Seismic Hazards: New Trends in
4 Analysis Using Geologic Data," Active Tectonics, National Academy Press,
5 Washington DC, pp. 215-230, 1986.

APPENDIX A
DEFINITIONS

Controlling Earthquakes -- ~~The~~ Controlling earthquakes are the earthquakes used to determine spectral shapes or to estimate ground motions at the site. There may be several controlling earthquakes for a site. In As a result of the probabilistic seismic hazard analysis (PSHA), the controlling earthquakes are characterized as mean magnitudes and distances derived from a deaggregation analysis of the median estimate of the PSHA. ~~The controlling earthquakes are the earthquakes used to determine spectral shapes or to estimate ground motions at the site. There may be several controlling earthquakes for a site.~~

Earthquake Recurrence -- Earthquake recurrence ~~Earthquake recurrence is the~~ frequency of recurrence of earthquakes having various magnitudes. Recurrence relationships or curves are developed for each seismic source, and they reflect the frequency of occurrence (usually expressed on an annual basis) of magnitudes up to the maximum, including measures of uncertainty.

Intensity -- The intensity of an earthquake is a measure of vibratory ground motion effects on humans, human-built structures, and on the earth's surface at a particular location. Intensity is described by a numerical value on the Modified Mercalli scale.

Magnitude -- An earthquake's magnitude is a measure of the strength of the earthquake as determined from seismographic observations.

Maximum Magnitude -- The maximum magnitude is the upper-bound to recurrence curves.

Nontectonic Deformation -- Nontectonic deformation is distortion of surface or near-surface soils or rocks that is not directly attributable to tectonic activity. Such deformation includes features associated with subsidence, karst terrane, glaciation or deglaciation, and growth faulting.

1 Safe Shutdown Earthquake Ground Motion (SSE) -- The Safe Shutdown Earthquake
2 Ground Motion is the free-field vibratory ground motion for which certain
3 structures, systems, and components ~~would be~~ designed, pursuant to the
4 proposed Appendix S to 10 CFR Part 50, to remain functional.

5 Seismic Potential -- A model giving a complete description of the future
6 earthquake activity in a seismic source zone. The model includes a relation
7 giving the frequency (rate) of earthquakes of any magnitude, an estimate of
8 the largest earthquake that could occur under the current tectonic regime, and
9 a complete description of the uncertainty. A typical model used for PSHA is
10 the use of a truncated exponential model for the magnitude distribution and a
11 stationary Poisson process for the temporal and spatial occurrence of
12 earthquakes.

13 Seismic Source -- A "Seismic source" is a general term referring to both
14 seismogenic sources and capable tectonic sources.

15 Capable Tectonic Source -- A "capable tectonic source" is a tectonic
16 structure that can generate both vibratory ground motion and tectonic
17 surface deformation such as faulting or folding at or near the earth's
18 surface in the present seismotectonic regime. It is described by at
19 least one of the following characteristics:

- 20 a. Presence of surface or near-surface deformation of landforms or
21 geologic deposits of a recurring nature within the last
22 approximately 500,000 years or at least once in the last
23 approximately 50,000 years.
- 24 b. A reasonable association with one or more large earthquakes or
25 sustained earthquake activity that are usually accompanied by
26 significant surface deformation.
- 27 c. A structural association with a capable tectonic source having
28 characteristics of section a in this paragraph such that movement
29 on one could be reasonably expected to be accompanied by movement
30 on the other.

1 In some cases, the geological evidence of past activity at or near
2 the ground surface along a particular capable tectonic source may be
3 obscured at a particular site. This might occur, for example, at a site
4 having a deep overburden. For these cases, evidence may exist elsewhere
5 along the structure from which an evaluation of its characteristics in
6 the vicinity of the site can be reasonably based. Such evidence is to
7 be used in determining whether the structure is a capable tectonic
8 source within this definition.

9 Notwithstanding the foregoing paragraphs, ~~structural~~ the
10 association of a structure with the geological ~~structural~~ features that
11 are ~~geologically old (at least pre-Quaternary)~~, such as many of those
12 found in the Central and Eastern region of the United States ~~will~~, in
13 the absence of conflicting evidence, ~~will~~ demonstrate that the structure
14 is not a capable tectonic source within this definition.

15 Seismogenic Source -- A "seismogenic source" is a portion of the earth
16 that ~~has~~ ~~we assumed~~ ~~has~~ uniform earthquake potential (same expected
17 maximum earthquake and ~~recurrence frequency of recurrence~~), distinct
18 from ~~other~~ the seismicity of the surrounding regions. A seismogenic
19 source will generate vibratory ground motion but is assumed not to cause
20 surface displacement. Seismogenic sources cover a wide range of
21 possibilities from a well-defined tectonic structure to simply a large
22 region of diffuse seismicity (seisotectonic province) thought to be
23 characterized by the same earthquake recurrence model. A seismogenic
24 source is also characterized by its involvement in the current tectonic
25 regime (the Quaternary, or approximately the last 2 million years).

26 Stable Continental Region -- A "stable continental region" (SCR) is composed
27 of continental crust, including continental shelves, slopes, and attenuated
28 continental crust, and excludes active plate boundaries and zones of currently
29 active tectonics directly influenced by plate margin processes. It exhibits
30 no significant deformation associated with the major Mesozoic-to-Cenozoic
31 (last 240 million years) orogenic belts. It excludes major zones of Neogene
32 (last 25 million years) rifting, volcanism, or suturing.

33 Stationary Poisson Process -- A probabilistic model of the occurrence of an
34 event over time (space) that is characterized by the following properties: (1)

1 the occurrence of the event in small interval is constant over time (space),
2 (2) the occurrence of two (or more) events in a small interval, is
3 "negligible," and (3) the occurrence of the event in non-overlapping intervals
4 is independent. ~~---This---~~

5 Tectonic Structure -- A tectonic structure is a large-scale dislocation or
6 distortion, usually within the earth's crust. Its extent may be on the order
7 of tens of meters (yards) to hundreds of kilometers (miles).

APPENDIX B

REFERENCE PROBABILITY FOR THE EXCEEDANCE LEVEL OF THE SAFE SHUTDOWN EARTHQUAKE GROUND MOTION

B.1 INTRODUCTION

This appendix describes the procedure ~~that is acceptable~~ ~~toused by~~ the NRC staff to determine the reference probability, an annual probability of exceeding the Safe Shutdown Earthquake Ground Motion (SSE) at future nuclear power plant sites, ~~that is acceptable to the NRC staff~~. The reference probability is used in Appendix C in conjunction with the probabilistic seismic hazard analysis (PSHA).

B.2 REFERENCE PROBABILITY FOR THE SSE

The reference probability is the annual probability level such that 50% of a set of currently operating plants (selected by the NRC, see Table B.1) has an annual median probability of exceeding the SSE that is below this level. The reference probability is determined for the annual probability of exceeding the average of the 5 and 10 Hz SSE response spectrum ordinates associated with 5% of critical damping.

B.3 PROCEDURE TO DETERMINE THE REFERENCE PROBABILITY

The following procedure was used to determine the reference probability and should be used in the future if general revisions to PSHA methods or data bases result in significant changes in hazard predictions for the selected plant sites in Table B.1.

The reference probability is calculated using the Lawrence Livermore National Laboratory (LLNL) methodology and results (Refs. B.1 and B.2) but is also considered applicable for the Electric Power Research Institute (EPRI) study (Refs. B.3 and B.4). This reference probability is also to be used in conjunction with sites not in the Central and Eastern United States (CEUS) and for sites for which LLNL and EPRI methods and data have not been used or are not available. ~~Howeve~~ / the final SSE ground motion at a higher reference

1 probability may be more appropriate and acceptable¹ for some sites
2 considering the slope characteristics of the site hazard curves, the overall
3 uncertainty in calculations (i.e., differences between mean and median hazard
4 estimates), and the knowledge of the seismic sources that contribute to the
5 hazard. Reference B.4 includes a procedure to determine an alternative
6 reference probability on the risk-based considerations; its application will
7 also be reviewed on a case-by-case basis.

8 B.3.1 Selection of Current Plants for Reference Probability Calculations

9 Table B.1 identifies plants, along with their site characteristics, used
10 in calculating the reference probability. These plants represent relatively
11 recent designs that used Regulatory Guide 1.60, "Design Response Spectra for
12 Seismic Design of Nuclear Power Plants" (Ref. B.5), or similar spectra as
13 their design bases. The use of these plants should ensure an adequate level
14 of conservatism in determining an SSE consistent with recent licensing
15 decisions.

16 B.3.2 Procedure To Establish Reference Probability

17 Step 1

18 Using LLNL, EPRI, or a comparable methodology that is acceptable to the
19 NRC staff, ~~an accepted methodology~~, calculate the seismic hazard results for
20 the site for spectral responses at 5 and 10 Hz (as stated earlier, the staff
21 used the LLNL methodology and associated results as documented in Refs. B.1
22 and B.2).
23

24 Step 2

25 Calculate the ~~median~~ composite annual probability of exceeding the SSE
26 for spectral responses at 5 and 10 Hz using median hazard estimates. The
27 composite annual probability is determined as:

28 ¹ The use of a higher reference probability will be reviewed and accepted on
29 a case-by-case basis.

1 $\text{Composite probability} = 1/2(a_1) + 1/2(a_2)$

2 where a_1 and a_2 represent median annual probabilities of exceeding SSE
3 spectral ordinates at 5 and 10 Hz, respectively. The procedure is illustrated
4 in Figure B-1.

5 Step 3

6 Figure B-2 illustrates the distribution of median probabilities of
7 exceeding the SSEs for the plants in Table B.1 based on the LLNL methodology
8 (Refs. B.1 and B.2). The reference probability is simply the median
9 probability of this distribution.

10 For the LLNL methodology, this reference probability is $1E-5/\text{yr}$ and, as
11 stated earlier, is also to be used in conjunction with the current EPRI
12 methodology (Ref. B.3) or for sites not in the CEUS.

Table B.1 Plants/Sites Used in Determining Reference Probability

Plant/Site Name	Soil Condition Primary/Secondary*
Limerick	Rock
Shearon Harris	Sand - S1
Braidwood	Rock
River Bend	Deep Soil
Wolf Creek	Rock
Watts Bar	Rock
Vogtle	Deep Soil
Seabrook	Rock
Three Mile Is.	Rock/Sand - S1
Catawba	Rock/Sand - S1
Hope Creek	Deep Soil
McGuire	Rock
North Anna	Rock/Sand - S1
Summer	Rock/Sand - S1
Beaver Valley	Sand - S1
Byron	Rock
Clinton	Till - T3
Davis Besse	Rock
LaSalle	Till - T2
Perry	Rock
Bellefonte	Rock
Callaway	Rock/Sand - S1
Commanche Peak	Rock
Grand Gulf	Deep Soil
South Texas	Deep Soil
Waterford	Deep Soil
Millstone 3	Rock
Nine Mile Point	Rock/Sand - S1
Brunswick	Sand - S1

* If two soil conditions are listed, the first is the primary and the second is the secondary soil condition. See Ref. B.1 for a discussion of soil conditions.





Figure B.1 Procedure to Compute Probability of Exceeding Design Basis

$$\text{Comp. Prob.} = 1/2(a1) + 1/2(a2)$$

LLNL Median Hazard Values For the SSE
Average of 5 and 10 Hz



Probability of Exceeding SSE

Figure B.2 Probability of Exceeding SSE using Median
LLNL Hazard Estimates

1 REFERENCES

- 2 B.1 D.L. Bernreuter et al., "Seismic Hazard Characterization of 69 Nuclear
3 Plant Sites East of the Rocky Mountains," NUREG/CR-5250, January 1989.²
- 4 B.2 P. Sobel, "Revised Livermore Seismic Hazard Estimates for Sixty-Nine
5 Nuclear Power Plant Sites East of the Rocky Mountains," NUREG-1488,
6 USNRC, April 1994.²
- 7 B.3 Electric Power Research Institute, "Probabilistic Seismic Hazard
8 Evaluations at Nuclear Power Plant Sites in the Central and Eastern
9 United States: Resolution of the Charleston Earthquake Issue," Report
10 NP-6395-D, April 1989.
- 11 B.4 Attachment to Letter from D. J. Modeen, Nuclear Energy Institute, to
12 A.J. Murphy, USNRC, Subject: Seismic Siting Decision Process,
13 May 25, 1994.³
- 14 B.5 USNRC, "Design Response Spectra for Seismic Design of Nuclear Power
15 Plants," Regulatory Guide 1.60.²⁴

16 ² Copies are available for inspection or copying for a fee from the NRC
17 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
18 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
19 (202)634-3343. Copies may be purchased at current rates from the U.S. Government
20 Printing Office, P.O. Box 37082, Washington, DC 20402-9328 (telephone (202)512-
21 2249); or from the National Technical Information Service by writing NTIS at 5285
22 Port Royal Road, Springfield, VA 22161.

23 ³ Copies are available for inspection or copying for a fee from the NRC
24 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
25 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
26 (202)634-3343.

27 ⁴Single copies of regulatory guides, both active and draft, may be obtained free
28 of charge by writing the Office of Administration, Attn: Distribution and Services
29 Section, USNRC, Washington, DC 20555, or by fax at (301)415-2260.
30 Copies are also available for inspection or copying for a fee from the NRC Public
31 Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing address
32 is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax (202)634-
33 3343.

APPENDIX C

DETERMINATION OF CONTROLLING EARTHQUAKES AND DEVELOPMENT OF SEISMIC HAZARD INFORMATION BASE

C.1 INTRODUCTION

This appendix elaborates on the steps described in Regulatory Position 3 of ~~this regulatory guide~~ ~~Draft Regulatory Guide DG-1032~~ to determine the controlling earthquakes used to define the Safe Shutdown Earthquake Ground Motion (SSE) at the site and to develop a seismic hazard information base. The information base summarizes the contribution of individual magnitude and distance ranges to the seismic hazard and the magnitude and distance values of the controlling earthquakes at the average of 1 and 2.5 Hz and the average of 5 and 10 Hz. They are developed for the ground motion level corresponding to the reference probability as defined in Appendix B to this regulatory guide.

The spectral ground motion levels, as determined from a probabilistic seismic hazard analysis (PSHA), are used to scale a response spectrum shape. A site-specific response spectrum shape is determined for the controlling earthquakes and local site conditions. Regulatory Position 4 and Appendix F to this regulatory guide describe a procedure to determine the SSE using the controlling earthquakes ~~and results from the PSHA.~~

C.2 PROCEDURE TO DETERMINE CONTROLLING EARTHQUAKES

The following is an approach acceptable to the NRC staff for determining the controlling earthquakes and developing a seismic hazard information base. This procedure is based on a de-aggregation of the probabilistic seismic hazard in terms of earthquake magnitudes and distances. Once the controlling earthquakes have been obtained, the SSE response spectrum can be determined according to the procedure described in Appendix F to this regulatory guide.

Step 1

(a) Perform a site-specific PSHA using the Lawrence Livermore National Laboratory (LLNL) or Electric Power Research Institute (EPRI) methodologies for Central and Eastern United States (CEUS) sites or perform a site-specific

PSHA for sites not in the CEUS or for sites for which LLNL or EPRI methods and data are not ~~applicable~~available, for actual or assumed rock conditions. The hazard assessment (mean, median, 85th percentile, and 15th percentile) should be performed for spectral accelerations at 1, 2.5, 5, 10, and 25 Hz, and the peak ground acceleration. A lower-bound magnitude of 5.0 is recommended. The PSHA should include an uncertainty assessment.

~~(b) Determine the following parameters as part of the assessment for each ground motion measure:~~

- ~~• Total hazard in terms of the median (50th percentile), mean, 85th, and 15th percentile hazard curves.~~

- ~~• De-aggregated median hazard results for a matrix of magnitude-distance pairs discussed in Step 3. As a part of the information base, de-aggregated results for mean hazard results may also be useful.~~

~~These results obtained from the de-aggregation of the median hazard are used to determine the SSE and to develop the seismic hazard information base.~~

Step 2

(a) Using the reference probability as defined in Appendix B to this regulatory guide, determine the ground motion levels for the spectral accelerations at 1, 2.5, 5, and 10 Hz from the total median hazard obtained in Step 1.

(b) Calculate the average of the ground motion level for the 1 and 2.5 Hz and the 5 and 10 Hz spectral acceleration pairs.

~~Steps 3 to 5 describe the procedure to develop the seismic hazard information base for each ground motion level determined in Step 2. This information base will consist of:~~

- ~~• Fractional contribution of each magnitude-distance pair to the total median seismic hazard.~~

- ~~• Magnitudes and distances of the controlling earthquakes.~~

- ~~• The ground motion levels for the spectral accelerations at 1, 2.5,~~

5, and 10 Hz defined in Step 2.

The average of the ground motion levels listed above at the 1 and 2.5 Hz, $S_{avg-2.5}$, and 5 and 10 Hz, S_{avg-10} , spectral accelerations corresponding to the reference probability.

Step 3

Perform a complete probabilistic seismic hazard analysis is performed for each of the magnitude-distance bins described in Table C.3.

Step 4

Using the de-aggregated median hazard results from Step 13, at the ground motion levels obtained from Step 2 calculate the fractional contribution to the total median hazard of earthquakes in a selected set of magnitude and distance bins (Section Table C.3 provides magnitude and distance bins to be used in conjunction with the LLNL and EPRI methods) for the average of 1 and 2.5 Hz and 5 and 10 Hz. The median annual probability of exceeding the ground motion levels calculated in Step 123 for each magnitude and distance bin and ground motion measure is denoted by H_{mf} .

The fractional contribution of each magnitude and distance bin to the total hazard for the average of 1 and 2.5 Hz, $P(m,d)_1$, is computed according to:

$$P(m,d)_1 = \frac{\frac{(\sum_{f=1,2} H_{mf})}{2}}{\sum_m \sum_d \frac{(\sum_{f=1,2} H_{mf})}{2}} \quad (\text{Equation 1})$$

where $f = 1$ and $f = 2$ represent the ground motion measure at 1 and 2.5 Hz, respectively.

The fractional contribution of each magnitude and distance bin to the total hazard for the average of 5 and 10 Hz, $P(m,d)_2$, is computed according to:

$$P(m,d)_2 = \frac{\frac{(\sum_{f=1,2} H_{m,d})}{2}}{\sum_m \sum_d \frac{(\sum_{f=1,2} H_{m,d})}{2}} \quad (\text{Equation 2})$$

where $f = 1$ and $f = 2$ represent the ground motion measure at 5 and 10 Hz, Step 2 respectively.

Step 45

Review the magnitude-distance distribution for the average of 1 and 2.5 Hz to determine whether the contribution to the hazard for distances of 100 km or greater is substantial (on the order of 5% or greater).

If the contribution to the hazard for distances of 100 km or greater exceeds 5%, additional calculations are needed to determine the controlling earthquakes using the magnitude-distance distribution for distances greater than 100 km (63 mi). This distribution, $P_{>100}(m,d)_1$, is defined by:

$$P_{>100}(m,d)_1 = \frac{P(m,d)_1}{\sum_m \sum_{d>100} P(m,d)_1} \quad (\text{Equation 3})$$

The purpose of this calculation is to identify a distant, larger event that may control low-frequency content of a response spectrum.

The distance of 100 km is chosen for CEUS sites. However, for all sites ~~CEUS sites and sites not in the CEUS~~ the results of full magnitude-distance distribution should be carefully examined to ensure that proper controlling earthquakes are clearly identified.

Step 56

Calculate the mean magnitude and distance of the controlling earthquake associated with the ground motions determined in Step 2 for the average of 5 and 10 Hz. The following relation is used to calculate the mean magnitude using results of the entire magnitude-distance bins matrix:

$$M_c (5-10 \text{ Hz}) = \sum_m m \sum_d P(m,d)_2 \quad (\text{Equation 4})$$

where m is the central magnitude value for each magnitude bin.

The mean distance of the controlling earthquake is determined using results of the entire magnitude-distance bins matrix:

$$\ln \{D_c (5-10 \text{ Hz})\} = \sum_d \ln(d) \sum_m P(m,d)_2 \quad (\text{Equation 5})$$

where d is the centroid distance value for each distance bin.

Step 6

If the contribution to the hazard calculated in Step 4 for distances of 100 km or greater exceeds 5% for the average of 1 and 2.5 Hz, calculate the mean magnitude and distance of the controlling earthquakes associated with the ground motions determined in Step 2 for the average of 1 and 2.5 Hz. The following relation is used to calculate the mean magnitude using calculations based on magnitude-distance bins greater than distances of 100 km as discussed in Step 4:

$$M_c (1-2.5 \text{ Hz}) = \sum_m m \sum_{d > 100} P_{>100}(m,d)_2 \quad (\text{Equation 6})$$

where m is the central magnitude value for each magnitude bin.

The mean distance of the controlling earthquake is based on magnitude-distance bins greater than distances of 100 km as discussed in Step 4 and determined according to:

$$\ln \{D_c (1-2.5 \text{ Hz})\} = \sum_{d > 100} \ln(d) \sum_m P_{>100}(m,d)_2 \quad (\text{Equation 7})$$

where d is the centroid distance value for each distance bin.

1 Step 78

2 Determine the SSE response spectrum using the procedure described in
3 Appendix F of this regulatory guide.

4 C.3 EXAMPLE FOR A CEUS SITE

5 To illustrate the procedure in Section C.2, calculations are shown here
6 for a CEUS site using the 1993 LLNL hazard results (Refs. C.1 and C.2). It
7 must be emphasized that the recommended magnitude and distance bins and
8 procedure used to establish controlling earthquakes were developed for
9 application in the CEUS where the nearby earthquakes generally control the
10 response in the 5 to 10 Hz frequency range and larger but distant events can
11 control the lower frequency range. For other situations, alternative binning
12 schemes as well as a study of contributions from various bins will be
13 necessary to identify controlling earthquakes consistent with the distribution
14 of the seismicity.

15 Step 1

16 The 1993 LLNL seismic hazard methodology (Ref. C.1 and C.2) was used to
17 determine the hazard at the site. A lower bound magnitude of 5.0 was used in
18 this analysis. The analysis was performed for spectral acceleration at 1,
19 2.5, 5, and 10 Hz. The resultant hazard curves are plotted in Figure C.1.

20 Step 2

21 The hazard curves at 1, 2.5, 5, and 10 Hz obtained in Step 1 are
22 assessed at the reference probability value of $1E-5/\text{yr}$, as defined in
23 Appendix B to this regulatory guide. The corresponding ground motion level
24 values are given in Table C.1. See Figure C.1.

25
26 Table C.1
27 Ground Motion Levels

Frequency (Hz)	1	2.5	5	10
Spectral Acc. (cm/s/s)	88	258	351	551

The average of the ground motion levels at the 1 and 2.5 Hz, $S_{a1-2.5}$, and 5 and 10 Hz, S_{a5-10} , are given in Table C.2.

Table C.2

Average Ground Motion Values

$S_{a1-2.5}$ (cm/s/s)	173
S_{a5-10} (cm/s/s)	451

Step 3

The median seismic hazard is de-aggregated for the matrix of magnitude and distance bins as given in Table C.3.

Table C.3

Recommended Magnitude and Distance Bins

Distance Range of Bin (km)	Magnitude Range of Bin				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
0-15					
15-25					
25-50					
50-100					
100-200					
200-300					
> 300					

A complete probabilistic hazard analysis was performed for each bin to determine the contribution to the hazard from all earthquakes within the bin, e.g., all earthquakes with magnitudes 6 to 6.5 and distance 25 to 50 km from the site. ~~The hazard values corresponding to the ground motion levels defined in step 2 for the spectral acceleration at 1, 2.5, 5, and 10 Hz are listed in Tables C.4-C.7.~~ See Figure C.2 where the median 1 Hz hazard curve is plotted for distance-bin 25-50 km and magnitude-bin 6-6.5.

The hazard values corresponding to the ground motion levels found in step 2, and listed in Table C.1., are then determined from the hazard curve for each bin for spectral accelerations of 1, 2.5, 5 and 10 Hz. This process is

illustrated in Figure C.1. The vertical line corresponds to the value 88 cm/s/s listed in Table C.1 for the 1 Hz hazard curve and intersects the hazard curve for the 25-50 bin, 6-6.5 bin at a hazard value (probability of exceedance) of $2.14\text{E-}08$ per year. Tables C.4 to C.7 list the appropriate hazard value for each bin for 1, 2.5, 5 and 10 Hz respectively

It should be noted that if the median hazard in each of the 35 bins is added up it does not equal $1.0\text{E-}05$. That is because the sum of the median of each of the bins does not equal the overall median. However, if we gave the mean hazard for each bin it would add up to the overall mean hazard curve.

Table C.4
Median Exceeding Probability Values for Spectral Accelerations
at 1 Hz (88 cm/s/s)

Distance Range of Bin (km)	Magnitude Range of Bin				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
0-15	$1.98\text{E-}08$	$9.44\text{E-}08$	$1.14\text{E-}08$	0	0
15-25	$4.03\text{E-}09$	$2.58\text{E-}08$	$2.40\text{E-}09$	0	0
25-50	$1.72\text{E-}09$	$3.03\text{E-}08$	$2.14\text{E-}08$	0	0
50-100	$2.35\text{E-}10$	$1.53\text{E-}08$	$7.45\text{E-}08$	$2.50\text{E-}08$	0
100-200	$1.00\text{E-}11$	$2.36\text{E-}09$	$8.53\text{E-}08$	$6.10\text{E-}07$	0
200-300	0	$1.90\text{E-}11$	$1.60\text{E-}09$	$1.84\text{E-}08$	0
> 300	0	0	$8.99\text{E-}12$	$1.03\text{E-}11$	$1.69\text{E-}10$

Table C.5

Median Exceeding Probability Values for Spectral Accelerations
at 2.5 Hz (258 cm/s/s)

Distance Range of Bin (km)	Magnitude Range of Bin				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
0-15	2.24E-07	3.33E-07	4.12E-08	0	0
15-25	5.39E-08	1.20E-07	1.08E-08	0	0
25-50	2.60E-08	1.68E-07	6.39E-08	0	0
50-100	3.91E-09	6.27E-08	1.46E-07	4.09E-08	0
100-200	1.50E-10	7.80E-09	1.07E-07	4.75E-07	0
200-300	7.16E-14	2.07E-11	7.47E-10	5.02E-09	0
> 300	0	1.52E-14	4.94E-13	9.05E-15	2.36E-15

Table C.6

Median Exceeding Probability Values for Spectral Accelerations
at 5 Hz (351 cm/s/s)

Distance Range of Bin (km)	Magnitude Range of Bin				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
0-15	4.96E-07	5.85E-07	5.16E-08	0	0
15-25	9.39E-08	2.02E-07	1.36E-08	0	0
25-50	2.76E-08	1.84E-07	7.56E-08	0	0
50-100	1.23E-08	3.34E-08	9.98E-08	2.85E-08	0
100-200	8.06E-12	1.14E-09	2.54E-08	1.55E-07	0
200-300	0	2.39E-13	2.72E-11	4.02E-10	0
> 300	0	0	0	0	0

Table C.7

Median Exceeding Probability Values for Spectral Accelerations
at 10 Hz (551 cm/s/s)

Distance Range of Bin (km)	Magnitude Range of Bin				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
0-15	1.11E-06	1.12E-06	8.30E-08	0	0
15-25	2.07E-07	3.77E-07	3.12E-08	0	0
25-50	4.12E-08	2.35E-07	1.03E-07	0	0
50-100	5.92E-10	2.30E-08	6.89E-08	2.71E-08	0
100-200	1.26E-12	1.69E-10	6.66E-09	5.43E-08	0
200-300	0	3.90E-15	6.16E-13	2.34E-11	0
> 300	0	0	0	0	0

Step 4

Using de-aggregated median hazard results, the fractional contribution of each magnitude-distance pair to the total hazard is determined.

Tables C.48 and C.59 show $P(m,d)_1$ and $P(m,d)_2$ for the average of 1 and 2.5 Hz and 5 and 10 Hz, respectively.

Table C.48
 $P(m,d)_1$ for Average Spectral Accelerations 1 and 2.5 Hz
Corresponding to the Reference Probability

Distance Range of Bin (km)	Magnitude Range of Bin				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
0-15	0.083	0.146	0.018	0.000	0.000
15-25	0.020	0.050	0.005	0.000	0.000
25-50	0.009	0.067	0.029	0.000	0.000
50-100	0.001	0.027	0.075	0.022	0.000
100-200	0.000	0.003	0.066	0.370	0.000
200-300	0.000	0.000	0.001	0.008	0.000
> 300	0.000	0.000	0.000	0.000	0.000

Table C.59

$P(m,d)$, for Average Spectral Accelerations 5 and 10 Hz
Corresponding to the Reference Probability

Distance Range of Bin (km)	Magnitude Range of P_a				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
0-15	0.289	0.306	0.024	0.000	0.000
15-25	0.054	0.104	0.008	0.000	0.000
25-50	0.012	0.075	0.032	0.000	0.000
50-100	0.001	0.010	0.030	0.010	0.000
100-200	0.000	0.001	0.006	0.038	0.000
200-300	0.000	0.000	0.000	0.000	0.000
> 300	0.000	0.000	0.000	0.000	0.000

Step 45

Because the contribution of the distance bins greater than 100 km in Table C.48 ~~contains~~ does account for more than 5% of the total hazard for the average of 1 and 2.5 Hz, the controlling earthquake for the spectral average of 1 and 2.5 Hz will be calculated using magnitude-distance bins for distance greater than 100 km. Table C.610 shows $P_{>100}(m,d)$, for the average of 1-2.5 Hz.

Table C.610

$P_{>100}(m,d)$, for Average Spectral Accelerations 1 and 2.5 Hz
Corresponding to the Reference Probability

Distance Range of Bin (km)	Magnitude Range of Bin				
	5 - 5.5	5.5 - 6	6 - 6.5	6.5 - 7	>7
100-200	0.000	0.007	0.147	0.826	0.000
200-300	0.000	0.000	0.002	0.018	0.000
> 300	0.000	0.000	0.000	0.000	0.000

Figures C.1 to C.3 show the above information in terms of the relative percentage contribution.

Steps 56 and 67

To compute the controlling magnitudes and distances at 1-2.5 Hz and 5-10 Hz for the example site, the values of $P_{>100}(m,d)_1$ and $P(m,d)_2$ are used with m and d values corresponding to the mid-point of the magnitude of the bin (5.25, 5.75, 6.25, 6.75, 7.3) and centroid of the ring area (10, 20.4, 38.9, 77.8, 155.6, 253.3, and somewhat arbitrarily 350 km). Note that the mid-point of the last magnitude bin may change because this value is dependent on the maximum magnitudes used in the hazard analysis. For this example site, the controlling earthquake characteristics (magnitudes and distances) are given in Table C.711.

Table C.711

Magnitudes and Distances of Controlling Earthquakes from the LLNL Probabilistic Analysis

1-2.5 Hz	5 - 10 Hz
M_c and D_c 100 km	M_c and D_c
6.7 and 157 km	5.7 and 17 km

Step 78

The SSE response spectrum is determined by the procedures described in Appendix F.

C.4 SITES NOT IN THE CEUS

The determination of the controlling earthquakes and the seismic hazard information base for sites not in the CEUS is also carried out using the procedure described in Section C.2 of this appendix. However, because of differences in seismicity rates and ground motion attenuation at these sites, alternative magnitude-distance bins may have to be used. In addition, as discussed in Appendix B, an alternative reference probability may also have to be developed, particularly for sites in the active plate margin region and for sites at which a known tectonic structure dominates the hazard.

Total Median Hazard Curves

1--1 1Hz 2--2 2.5Hz 3--3 5Hz 4--4 10Hz





Figure C.1 Total median Hazard Curves

1--1 1 Hz, 2--2 2.5 Hz, 3--3 5 Hz, 4--4 10 Hz

1 Hz Median Hazard Curve for
Distance-bin 25-50 km & Magnitude-bin 6-6.5



1 Figure C.2 1 Hz Median Hazard Curve for
2 Distance-bin 25-50 km & Magnitude-bin 6-6.5





Figure C.43 Full Distribution for Average of 5 and 10 Hz



Renormalized av 1-2.5 Hz D>100 kn




Figure C.35 Renormalized Hazard Distribution for Distances >100 km for average of 1 and 2.5 Hz

1 REFERENCES

2 C.1 P. Sobel, "Revised Livermore Seismic Hazard Estimates for Sixty-Nine
3 Nuclear Power Plant Sites East of the Rocky Mountains," NUREG-1488,
4 USNRC, April 1994.¹

5 C.2 J.B. Savy et al., "Eastern Seismic Hazard Characterization Update,"
6 UCRL-ID-115111, Lawrence Livermore National Laboratory, June 1993
7 (Accession number 9310190318 in NRC's Public Document Room).

8 ¹Copies are available for inspection or copying for a fee from the NRC
9 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
10 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
11 (202)634-3343. Copies may be purchased at current rates from the U.S.
12 Government Printing Office, P.O. Box 37082, Washington, DC 20402-9328
13 (teléfono (202)512-2249); or from the National Technical Information Service
14 by writing NTIS at 5285 Port Royal Road, Springfield, VA 22161.

APPENDIX D

GEOLOGICAL, SEISMOLOGICAL, AND GEOPHYSICAL INVESTIGATIONS TO CHARACTERIZE SEISMIC SOURCES

D.1 INTRODUCTION

As characterized for use in probabilistic seismic hazard analyses (PSHA)²⁻⁵, seismic sources are areas/zones within which future earthquakes are likely to occur at similar/the same recurrence rates. Geological, seismological, and geophysical investigations provide the information needed to identify and characterize source parameters, such as size and geometry, and to estimate earthquake recurrence rates and maximum magnitudes. The amount of data available about earthquakes and their causative sources varies substantially between the Western United States (west of the Rocky Mountain front) and the Central and Eastern United States (CEUS), or stable continental region (SCR) (east of the Rocky Mountain front). Furthermore, there are variations in the amount and quality of data within these regions. In active tectonic regions the focus will be on the identification of there are both capable tectonic sources and seismogenic sources, and because of their relatively high activity rate they may be more readily identified. In the CEUS, identifying seismic sources is less certain because of the difficulty in correlating earthquake activity with known tectonic structures, and the lack of adequate knowledge about earthquake causes, and the relatively lower activity rate.

In the CEUS, several significant tectonic structures exist and some of these have been interpreted as potential seismogenic sources (e.g., New Madrid fault zone, Nemaha Ridge, and Meers fault). There is no single recommended procedure to follow to characterize maximum magnitude associated with such candidate seismogenic sources; therefore, it is most likely that the determination of the properties of the seismic source will be inferred rather than demonstrated by strong correlations with seismicity or geologic data. Moreover, it is not generally known what relationships exist between observed tectonic structures in a seismic source within the CEUS and the current earthquake activity that may be associated with that source. Generally, the observed tectonic structure resulted from ancient tectonic forces that are no

1 longer present, ~~thus a structure's extent may not be a very meaningful~~
2 ~~indicator of the size of future earthquakes associated with the source.~~ The
3 historical seismicity record, the results of regional and site studies, and
4 judgment play key roles. If, on the other hand, strong correlations and data
5 exist suggesting a relationship between seismicity and seismic sources,
6 approaches used for more active tectonic regions can be applied.

7 The primary objective of geological, seismological, and geophysical
8 investigations is to develop an up-to-date, site-specific earth science data
9 base that supplements existing information (Ref. D.1). In the CEUS the
10 results of these investigations will also be used to assess whether new data
11 and their interpretation are consistent with the information used as the basis
12 for accepted probabilistic seismic hazard studies. If the new data are
13 consistent with the existing earth science data base, ~~development of new~~
14 ~~seismic sources~~ modification of the hazard analysis is not required. For
15 sites in the CEUS where there is significant new information (see Appendix E)
16 provided by the site investigation, and for sites in the Western United
17 States, site-specific seismic sources are to be determined. It is anticipated
18 that for most sites in the CEUS, new information will have been adequately
19 bounded by existing seismic source interpretations.

20 The following is a general list of characteristics to be determined for
21 a seismic source for site-specific source interpretations:

- 22 • Source zone geometry (location and extent, both surface and subsurface).
- 23 ~~• Description of Quaternary (last 2 million years) displacements (sense of~~
24 ~~slip on the fault, fault length and width, area of the fault plane, age~~
25 ~~of displacements, estimated displacement per event, estimated magnitude~~
26 ~~per offset, and displacement history or uplift rates of seismogenic~~
27 ~~folds).~~
- 28 • Historical and instrumental seismicity associated with each source.
- 29 • Paleoseismicity.
- 30 • Relationship of the potential seismic source to other potential seismic
31 sources in the region.

- 1 • ~~Seismic potential~~ ~~Maximum magnitude earthquake that can be generated by~~
2 ~~of the seismic source, based on the source's known characteristics,~~
3 ~~including seismicity.~~
- 4 • Recurrence model (Frequency of earthquake occurrence versus magnitude).
- 5 • Other factors that will be evaluated, depending on the geologic setting
6 of a site, such as:
 - 7 • Quaternary (last 2 million years) displacements (sense of slip on
8 faults, fault length and width, area of the fault plane, age of
9 displacements, estimated displacement per event, estimated
10 magnitude per offset, segmentation, orientations of regional
11 tectonic stresses with respect to faults, and displacement history
12 or uplift rates of seismogenic folds).
 - 13 • Effects of human activities such as withdrawal of fluid from or
14 addition of fluid to the subsurface, extraction of minerals, or
15 the construction of dams and reservoirs.
 - 16 • Volcanism. Volcanic hazard is not addressed in this regulatory
17 guide. It will be considered on a case-by-case basis in regions
18 where this hazard exists.
 - 19 • ~~Other factors that can contribute to characterization of seismic~~
20 ~~sources such as strike and dip of tectonic structures,~~
21 ~~orientations of regional and tectonic stresses, fault segmentation~~
22 ~~(along both strike and downdip), etc.~~

23 D.2. INVESTIGATIONS TO EVALUATE SEISMIC SOURCES

24 D.2.1 General

25 Investigations of the site and region around the site are necessary to
26 identify both seismogenic sources and capable tectonic sources and to
27 determine their potential for generating earthquakes and causing surface
28 deformation. If it is determined that surface deformation need not be taken

1 into account at the site, sufficient data to clearly justify the determination
2 should be presented in the application for early site review, construction
3 permit, operating license, or combined license. Generally any tectonic
4 deformation at the earth's surface within 40 km (25 miles) of the site will
5 require ~~adequate~~ **detailed** examination to determine its significance.
6 Potentially active tectonic deformation within the seismogenic zone beneath a
7 site will have to be assessed using geophysical and seismological methods to
8 determine its significance.

9 Engineering solutions are generally available to mitigate the potential
10 vibratory effects of earthquakes through design. However, ~~adequate~~ engineering
11 solutions cannot always be demonstrated ~~to be adequate~~ for mitigation of the
12 effects of permanent ground displacement phenomena such as surface faulting or
13 folding, subsidence, or ground collapse. For this reason, it is prudent to
14 select an alternative site when the potential for permanent ground
15 displacement exists at the proposed site (Ref. D.2).

16 In most of the CEUS, as determined from instrumentally ~~determined~~ **located**
17 earthquake hypocenters, tectonic structures at seismogenic depths ~~often~~ **seldom**
18 bear ~~no~~ **any** relationship to geologic structures exposed at the ground surface.
19 Possible geologically young fault displacements either do not extend to the
20 ground surface or there is insufficient geologic material of the appropriate
21 age available to date the faults. Capable tectonic sources are not always
22 exposed at ~~the~~ ground surface in the Western United States **(WUS)** as
23 demonstrated by the buried (blind) reverse causative faults of the 1983
24 Coalinga, 1988 Whittier Narrows, 1989 Loma Prieta, and 1994 Northridge
25 earthquakes. These factors emphasize the need to ~~not only~~ conduct thorough
26 investigations ~~not only~~ at the ground surface but also in the subsurface to
27 identify structures ~~at~~ seismogenic depths.

28 The level of detail for investigations should be governed by knowledge
29 of the current and late Quaternary tectonic regime and the geological
30 complexity of the site and region. The investigations should be based on
31 increasing the amount of detailed information as they proceed from the
32 regional level down to the site area (e.g., 320 km to 8 km distance from the
33 site). Whenever faults or other structures are encountered at a site
34 (including sites in the CEUS) ~~in~~ either ~~in~~ outcrop or excavations, it is
35 necessary to perform many of the investigations described below to determine
36 whether or not they are capable tectonic sources.

1 The investigations for determining seismic sources should be divided
2 into three levels, Regional, Site Vicinity, and Site Area. Regional
3 investigations should extend to a distance of 320 km (200 mi) from the site,
4 ~~and data should be presented at a scale of 1:500,000 or smaller.~~ Site
5 vicinity investigations should be conducted to a distance of 40 km (25 mi)
6 from the site. Investigations of the site area should extend out to a radius
7 of 8 km (5 mi). The specific site should be investigated in detail to a
8 distance of at least 1 km (0.65 mi).

9 The regional investigations [within a radius of 320 km (200 mi) of the
10 site], should be planned to identify seismic sources and describe the
11 Quaternary tectonic regime. The data should be presented at a scale of
12 1:500,000 or smaller. The investigations are not expected to be extensive or
13 in detail, but should include a comprehensive literature review supplemented
14 by focused geological reconnaissances based on the results of the literature
15 study (including topographic, geologic, aeromagnetic, and gravity maps, and
16 airphotos). Some detailed investigations at specific locations within the
17 region may be necessary if potential capable tectonic sources, or seismogenic
18 sources that may be significant for determining the SSE, are identified.

19 The large size of the area for the regional investigations is
20 recommended because of the possibility that all significant seismic sources,
21 or alternate configurations, may not have been enveloped by the LLNL/EPRI data
22 base. Thus, it will increase the chances of: (1) identifying evidence for
23 unknown seismic sources that might extend close enough for earthquake ground
24 motions generated by that source to affect the site; and (2) ~~increase the~~
25 ~~likelihood of~~ confirming the PSHA's database. Furthermore, because of the
26 relatively aseismic nature of the CEUS, the area should be large enough to
27 include as many historical and instrumentally recorded earthquakes for
28 analysis as reasonably possible. The specified area of study is expected to
29 be large enough to incorporate any previously identified sources that could be
30 analogous to sources that may underlie or be relatively close to the site. In
31 past licensing activities of sites in the CEUS, it has often been necessary,
32 because of the absence of datable horizons overlying bedrock, to extend
33 investigations out many tens or hundreds of kilometers from the site along a
34 structure, or to an outlying analogous structure, in order to locate overlying
35 datable strata or unconformities so that geochronological methods could be
36 applied. This procedure has also been used to estimate the size of a an

1 undatable seismic source in the site vicinity by relating its time of last
2 activity to that of a similar, previously evaluated structure, or a known
3 tectonic episode, the evidence of which may be many tens or hundreds of miles
4 away.

5 In the WUS it is also often necessary to extend the investigations to
6 great distances (up to hundreds of kilometers) to characterize a major
7 tectonic structure, such as the San Gregorio-Hosgri Fault Zone, the Juan de
8 Fuca Subduction Zone, etc. On the other hand, in the WUS, it is not usually
9 necessary to extend the regional investigations that far in all directions.
10 For example, for a site such as Diablo Canyon, which is near the San Gregorio-
11 Hosgri Fault, it would not be necessary to extend the regional investigations
12 to the farther east beyond the dominant San Andreas Fault, which is about
13 75 km (45 mi) from the site; nor to the west beyond the Santa Lucia Banks
14 Fault, which is about 45 km (27 mi). Justification for using lesser distances
15 should be provided.

16 Reconnaissance level investigations, which may need to be supplemented
17 at specific locations by more detailed explorations such as geologic mapping,
18 geophysical surveying, borings, and trenching, should be conducted in the site
19 vicinity to a distance of 40 km (25 mi) from the site; the data should be
20 presented at a scale of 1:50,000 or smaller.

21 Detailed investigations should be carried out in the site area within a
22 radius of 8 km (5 mi) from the site, and the resulting data should be
23 presented at a scale of 1:5000 or smaller. The level of investigations in the
24 site vicinity should delineate the geologic regime and the potential for
25 tectonic deformation at or near the ground surface. The investigations should
26 use the methods described in subsections D.2.2 and D.2.3 that are appropriate
27 for the tectonic regime to characterize seismic sources.

28 The site vicinity and site area investigations may be asymmetrical and
29 may cover a larger area than those described above in regions of late
30 Quaternary activity, regions with high rates of historical seismic activity
31 (felt or instrumentally recorded data), or sites that are located near a
32 capable tectonic source such as a fault zone.

33 Data from investigations at the site (approximately 1 square kilometer)
34 should be presented at a scale of 1:500 or smaller. Important aspects of the
35 site investigations are the excavation and logging of exploratory trenches and
36 the mapping of the excavations for the plant structures, particularly these
37 plant structures that are characterized as Seismic Category I. In addition to

1 geological, geophysical, and seismological investigations, considerable
2 detailed geotechnical engineering investigations as described in Regulatory
3 Guide 1.132 (Ref. D.3) should be conducted at the site.

4 The investigations needed to assess the integrity suitability of the
5 site with respect to effects of potential ground motions and surface
6 deformation should include determination of (1) the lithologic, stratigraphic,
7 geomorphic, hydrologic, geotechnical, and structural geologic characteristics
8 of the site and the area surrounding the site, including its seismicity and
9 geological history, (2) geological evidence of fault offset or other
10 distortion such as folding at or near ground surface within the site area (8
11 km radius), and (3) whether or not any faults or other tectonic structures,
12 any part of which are within a radius of 8 km (5 mi) from the site, are
13 capable tectonic sources. This information will be used to evaluate tectonic
14 structures underlying the site area, whether buried or expressed at the
15 surface, with regard to their potential for generating earthquakes and for
16 causing surface deformation at or near the site. This part of the evaluation
17 should also consider the possible effects caused by human activities such as
18 withdrawal of fluid from or addition of fluid to the subsurface, extraction of
19 minerals, or the loading effects of dams and reservoirs.

20 D.2.2 Reconnaissance Investigations, Literature Review, and Other Sources of 21 Preliminary Information

22 Regional literature and reconnaissance-level investigations can be
23 planned based on reviews of available documents and the results of previous
24 investigations. Possible sources of information may include universities,
25 consulting firms, and government agencies. A detailed list of possible
26 sources of information is given in Regulatory Guide 1.132 (Ref. D.3).

27 D.2.3 Detailed Site Vicinity and Site Area Investigations

28 The following methods are suggested but they are not all-inclusive and
29 investigations should not be limited to them. Some procedures will not be
30 applicable to every site, and situations will occur that require
31 investigations that are not included in the following discussion. It is
32 anticipated that new technologies will be available in the future that will be
33 applicable to these investigations.

1 D.2.3.1 Surface Investigations

2 Surface exploration needed to assess the neotectonic regime and the
3 geology of the area around the site is dependent on the site location and may
4 be carried out with the use of any appropriate combination of the following
5 geological, geophysical, seismological, and geotechnical engineering
6 techniques summarized in the following paragraphs and Ref. D.3, but. However,
7 not all of these methods will must be carried out at a given site.

8 D.2.3.1.1. Geological interpretations of aerial photographs and other
9 remote-sensing imagery, as appropriate for the particular site conditions, to
10 assist in identifying rock outcrops, faults and other tectonic features,
11 fracture traces, geologic contacts, lineaments, soil conditions, and evidence
12 of landslides or soil liquefaction.

13 D.2.3.1.2. Mapping of topographic, geologic, geomorphic, and hydrologic
14 features at scales and with contour intervals suitable for analysis,
15 stratigraphy (particularly Quaternary), surface tectonic structures such as
16 fault zones, and Quaternary geomorphic features. For offshore sites, coastal
17 sites, or sites located near lakes or rivers, this includes topography,
18 geomorphology (particularly mapping marine and fluvial terraces), bathymetry,
19 geophysics (such as seismic reflection), and hydrographic surveys to the
20 extent needed for evaluation.

21 D.2.3.1.3. Identification and evaluation of vertical crustal movements
22 by (1) geodetic land surveying to identify and measure short-term crustal
23 movements (Refs. D.4 and D.5) and (2) geological analyses such as analysis of
24 regional dissection and degradation patterns, marine and lacustrine terraces
25 and shorelines, fluvial adjustments such as changes in stream longitudinal
26 profiles or terraces, and other long-term changes such as elevation changes
27 across lava flows (Ref. D.6).

28 D.2.3.1.4. Analysis of offset, displaced, or anomalous landforms such
29 as displaced stream channels or changes in stream profiles or the upstream
30 migration of knickpoints (Refs. D.7 - D.12); abrupt changes in fluvial
31 deposits or terraces; changes in paleochannels across a fault (Refs. D.11 and

D.12); or uplifted, downdropped, or laterally displaced marine terraces (Ref. D.12).

D.2.3.1.5. Analysis of Quaternary sedimentary deposits within or near tectonic zones, such as fault zones, including (1) fault-related or fault-controlled deposits including sag ponds, graben fill deposits, and colluvial wedges formed by the erosion of a fault paleoscarp and (2) non-fault-related, but offset, deposits including alluvial fans, debris cones, fluvial terrace, and lake shoreline deposits.

D.2.3.1.6. Identification and analysis of deformation features caused by vibratory ground motions, including seismically induced liquefaction features (sand boils, explosion craters, lateral spreads, settlement, soil flows), mud volcanoes, landslides, rockfalls, deformed lake deposits or soil horizons, shear zones, cracks or fissures (Refs. D.13 and D.14).

D.2.3.1.7. ~~Estimation of the ages of~~ Analysis of fault displacements, such as by analysis the interpretation of the morphology of topographic fault scarps associated with or produced by surface rupture. Fault scarp morphology is useful in estimating age of last displacement (in conjunction with the appropriate geochronological methods described in Subsection D.2.4, approximate size of the earthquake, recurrence intervals, slip rate, and the nature of the causative fault at depth (Refs. D.15 - D.18).

D.2.3.2 Seismological Investigations

D.2.3.2.1. Listing of all historically reported earthquakes having Modified Mercalli Intensity (MMI) greater than or equal to IV or magnitude greater than or equal to 3.0 that can reasonably be associated with seismic sources, any part of which is within a radius of 320 km (200 miles) of the site (the site region). The earthquake descriptions should include the date of occurrence and measured or estimated data on the highest intensity, magnitude, epicenter, depth, focal mechanism, and stress drop. Historical seismicity includes both historically reported and instrumentally recorded data. For pre-instrumentally recorded data, intensity should be converted to magnitude, the procedure used to convert it to magnitude should be clearly documented, and epicenters should be determined based on intensity

1 distributions. Methods to convert intensity values to magnitudes in the CEUS
2 are described in References D.1, D.19, D.20, and D.21.

3 D.2.3.2.2. Seismic monitoring in the site area should be established as
4 soon as possible after site selection. For sites in both the CEUS and WUS, a
5 single large dynamic range, broad-band seismograph, and a network of short
6 period instruments to locate events should be deployed around the site area.
7 ~~may be adequate. For sites in the Western United States WUS, a network of at~~
8 ~~least five such seismographs would be deployed within 25 km (15 mi)~~
9 ~~surrounding the site.~~

10 ~~The primary purposes of seismic monitoring are to obtain data from~~
11 ~~distant earthquakes, to determine site response, The data obtained by~~
12 ~~monitoring current seismicity will be used, along with the much larger data~~
13 ~~base acquired from site investigations, to evaluate site response and to~~
14 ~~provide information about whether there are assurance that there are no~~
15 ~~significant sources of earthquakes within the site vicinity, or to provide~~
16 ~~data by which an existing source can be characterized. For sites in the~~
17 ~~Western United States seismic monitoring could help locate any ongoing~~
18 ~~seismicity that may indicate capable faulting within the site vicinity.~~

19 Monitoring should be initiated as soon as practicable at the site,
20 preferably at least up to five years prior to construction of a nuclear unit
21 at a site, and should continue for at least five years following initiation of
22 plant operation at least until the free field seismic monitoring strong ground
23 motion instrumentation described in Regulatory Guide 1.12 is operational.

24 D.2.3.3 Subsurface Investigations

25 Ref. D.6 describes geological, geotechnical, and geophysical
26 investigation techniques that can be applied to explore the subsurface beneath
27 the site and in the region around the site. Subsurface investigations in the
28 site area and within the site vicinity to identify and define seismogenic
29 sources and capable tectonic sources may include the following investigations.

30 D.2.3.3.1. Geophysical investigations that have been useful in the past
31 include, but are not limited to: such as air magnetic and gravity surveys,
32 seismic reflection and seismic refraction surveys, borehole geophysics,
33 electrical surveys, and ground-penetrating radar surveys.

1 D.2.3.3.2. Core borings to map subsurface geology and obtain samples
2 for testing such as ~~examining~~determining the properties of the subsurface
3 soils and rocks and geochronological analysis.

4 D.2.3.3.3. Excavating and logging of trenches across geological
5 features as part of the neotectonic investigation and to obtain samples for
6 the geochronological analysis of those features.

7 At some sites, deep soil, bodies of water, or other material may obscure
8 geologic evidence of past activity along a tectonic structure. In such cases,
9 the analysis of evidence elsewhere along the structure can be used to evaluate
10 its characteristics in the vicinity of the site (Refs. D.12 and D.22).

11 D.2.4 Geochronology

12 An important part of the geologic investigations to identify and define
13 potential seismic sources is the geochronology of geologic materials. ~~The NRC~~
14 ~~is currently supporting a research project to develop a data base on which to~~
15 ~~base a future regulatory guide on geochronological methods. This guide will~~
16 ~~contain an up to date bibliography of state of the art documents on~~
17 ~~geochronology. The availability of this guide will be published in the~~
18 ~~Federal Register.~~ An acceptable classification of dating methods is based on
19 the rationale described in Reference D.23. The following techniques, which
20 are presented according to that classification, are useful in dating
21 Quaternary deposits.

22 D.2.4.1 Sidereal Dating Methods

- 23 • Dendrochronology - tree-ring analysis - age range is from modern
24 times to several thousand years (Refs. D.24 and D.25).
- 25 • Varve chronology - 0 to 10,000 years (Ref. D.26).

26 D.2.4.2 Isotopic Dating Methods

- 27 • Radiocarbon for dating organic materials - 100 to 40,000 (up to
28 100,000 years using AMS) (Refs. D.27 and D.28).

- Potassium argon for dating volcanic rocks ranging in age from about 100,000 to 10 million years (Refs. D.27 and D.29).
- Argon 39 - Argon 40, for dating relatively unweathered igneous and metamorphic rocks - 100,000 to unlimited upper limit (Ref. D.30)
- Uranium series uses the relative properties of various decay products of ^{238}U or ^{235}U . Ages range from 10,000 to 350,000 years (Ref. D.27). $^{235}\text{U}/^{238}\text{U}$ can yield between 40,000 and 1,000,000 years (Ref. D.31).
- Uranium Trend - for relatively undisturbed soils ranging in age from 100,000 to 900,000 years (Ref. D.32).

D.2.4.3 Cosmogenic Isotopes - for dating surficial rocks and soils. Nuclides ^{36}Cl , ^{10}Be , ^{21}Pb , and ^{26}Al - age range varies within the Quaternary according to isotope tested (Refs. D.33 and D.34).

D.2.4.4 Radiogenic Dating Methods

- Thermoluminescence (TL) - for dating fine-grained eolian and lacustrine, and possibly alluvium and colluvium as well - age range is from 1,000 to 1,000,000 years (Refs. D.27 and D.35).
- Electron spin resonance (ESR) is used for sediments, shells, carbonates, bones, and possibly to date quartz that formed in fault gouge during the fault event - age range is from 50,000 to 500,000 years (Ref. D.36).
- Fission Track - for dating minerals such as zircon and apatite, with fissionable uranium in volcanic rocks - 100 to several million years (Refs. D.27 and D.37).

D.2.4.5 Chemical and Biological Dating Methods

- Obsidian and Tephra Hydration - age range is from 200 to several million years (Ref. D.38).
- Amino Acid Racemization - for fossils, shells, and bones - age range is from 100 to 1,000,000 years (Refs. D.39 and D.40).
- Rock varnish chemistry - cation ratio of manganese, iron, and clay coatings on desert stones - age range is 1,000 to 40,000 years

(Ref. D.41). The results of this method are controversial and its use is not recommended pending further validation.

D.2.4.6 Geomorphic Dating Methods

- Soil profile development - for analysis of the upper few meters of stable soils - age range is from 1,000 to 1,000,000 years (Refs. D.27, D.42 through D.47).
- Rock and mineral weathering - for measuring the progression of weathering, such as thicknesses of weathering rind development on the margins of clasts, hornblende etching, limestone solutioning, etc. - age range, depending on material - 10 to 1,000,000 (Ref. D.27).
- Geomorphic position - fluvial and marine terraces, and glacial moraines - 1,000 to 1,000,000 years (Ref. D.48).
- Rate of deposition - lacustrine, playa, and sometimes alluvial deposits - tens to millions of years (Ref. D.26)
- Scarp degradation - works best in coarse unconsolidated alluvium - age range is from 2,000 to 20,000 years (Refs. D.15 and D.49).

D.2.4.7 Correlation Dating Methods

- Lithostratigraphy - correlation of distinctive geologic units between sites - age range is from 0 to 4.5 billion years (Ref. D.50)
- Tephrochronology - volcanic ash layers interbedded with sedimentary deposits - age range is from zero to several million years (Refs. D.51 and D.38).
- Paleomagnetism - most igneous and sedimentary rocks containing hematite and magnetite - age range is from 0 to 5,000,000 years (Ref. D.27).
- Archeology - deposits associated with archeological materials (Ref. D.52).
- Paleontology (marine and terrestrial) - fossil-bearing rocks or soils - age range is from 0 to 1 billion years (Ref. D.53).

- Lichenometry - used to estimate ages from sizes of lichens growing on gravel or boulders (such as glacial deposits) (Ref. D.54).

in the CEUS, it may not be possible to reasonably demonstrate the age of last activity of a tectonic structure. In such cases the NRC staff will accept association of such structures with geologic structural features or tectonic processes that are geologically old (at least pre-Quaternary) as an age indicator in the absence of conflicting evidence.

These investigative procedures should also be applied, where possible, to characterize offshore structures (faults or fault zones, and folds, uplift, or subsidence related to faulting at depth) for coastal sites or those sites located adjacent to landlocked bodies of water. Investigations of offshore structures will rely heavily on seismicity, geophysics, and bathymetry rather than conventional geologic mapping methods that ~~can~~ normally can be used effectively onshore. However, it is often useful to investigate similar features onshore to learn more about the significant offshore features.

D.2.5 Distinction Between Tectonic and Nontectonic Deformation

At a site, both ~~N~~nontectonic deformation, ~~like~~ and tectonic deformation, ~~at a site~~ can pose a substantial hazard to nuclear power plants, but there are likely to be differences in the approaches used to resolve the issues raised by the two types of phenomena. Therefore, nontectonic deformation should be distinguished from tectonic deformation at a site. In past nuclear power plant licensing activities, surface displacements caused by phenomena other than tectonic phenomena have been confused with tectonically induced faulting. Such features include faults on which the last displacement was induced by glaciation or deglaciation; collapse structures, such as found in karst terrain; and growth faulting, such as occurs in the Gulf Coastal Plain or in other deep soil regions subject to extensive subsurface fluid withdrawal.

Glacially induced faults generally do not represent a deep-seated seismic or fault displacement hazard because the conditions that created them are no longer present. However, residual stresses from Pleistocene glaciation may still be present in glaciated regions, although they are of less concern than active tectonically induced stresses. These features should be investigated with respect to their relationship to current in situ stresses.

1 The nature of faults related to collapse features can usually be defined
2 through geotechnical investigations and can either be avoided or, if feasible,
3 adequate engineering fixes can be provided.

4 Large, naturally occurring growth faults as found in the coastal plain
5 of Texas and Louisiana can pose a surface displacement hazard, even though
6 offset most likely occurs at a much less rapid rate than that of tectonic
7 faults. They are not regarded as having the capacity to generate damaging
8 ~~vibratory ground motion-earthquakes~~, can often be identified and avoided in
9 siting, and their displacements can be monitored. Some growth faults and
10 antithetic faults related to growth faults are not easily identified;
11 therefore, investigations described above with respect to capable faults and
12 fault zones should be applied in regions where growth faults are known to be
13 present. Local human-induced growth faulting can be monitored and controlled
14 or avoided.

15 If questionable features cannot be demonstrated to be of non-tectonic
16 origin, they should be treated as tectonic deformation.

REFERENCES

- 1 D.1 Electric Power Research Institute, "Seismic Hazard Methodology for the
2 Central and Eastern United States," EPRI NP-4726, All Volumes, 1988
3 through 1991.
- 4 D.2 International Atomic Energy Agency, "Earthquakes and Associated Topics
5 in Relation to Nuclear Power Plant Siting," Safety Series No. 50-SG-S1,
6 Revision 1, 1991.
- 7 D.3 USNRC, "Site Investigations for Foundations of Nuclear Power Plants,"
8 Regulatory Guide 1.132.¹
- 9 D.4 R. Reilinger, M. Bevis, and G. Jurkowski, "Tilt from Releveling: An
10 Overview of the U.S. Data Base," Tectonophysics, Volume 107, pp. 315-
11 330, 1984.
- 12 D.5 R.K. Mark et al., "An Assessment of the Accuracy of the Geodetic
13 Measurements that Led to the Recognition of the Southern California
14 Uplift," Journal of Geophysical Research, Volume 86 pp. 2783-2808,
15 1981.
- 16 D.6 T.K. Rockwell et al., "Chronology and Rates of Faulting of Ventura River
17 Terraces, California," Geological Society of America Bulletin, Volume
18 95, pp. 1466-1474, 1984.

19 ¹Copies are available for inspection or copying for a fee from the NRC
20 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
21 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
22 (202)634-3343. Copies may be purchased at current rates from the U.S.
23 Government Printing Office, P.O. Box 37082, Washington, DC 20492-9328
24 (telephone (202)512-2249); or from the National Technical Information Service
25 by writing NTIS at 5285 Port Royal Road, Springfield, VA 22161.
26 Single copies of regulatory guides, both active and draft guides, may be
27 obtained free of charge by writing the Office of Administration, Attn:
28 Distribution and Services Section, U.S. Nuclear Regulatory Commission,
29 Washington, DC; 20555, or by fax at (301)415-2260. Copies are also available
30 for inspection or copying for a fee from the NRC Public Document Room at 2120
31 L Street NW., Washington, DC; the PDR's mailing address is Mail Stop LL-6,
32 Washington, DC; 20555; telephone (202)634-3343.

- 1 D.7 K.E. Sieh, "Lateral Offsets and Revised Dates of Prehistoric Earthquakes
2 at Pallett Creet, Southern California," Journal of Geophysical Research,
3 Volume 89, No. 89, pp. 7641-7670, 1984.
- 4 D.8 K.E. Sieh and R.H. Jahns, "Holocene Activity of the San Andreas Fault at
5 Wallace Creek, California," Geological Society of America Bulletin,
6 Volume 95, pp. 883-896, 1984.
- 7 D.9 K.E. Sieh, M. Stuiver, and D. Brillinger, "A More Precise Chronology of
8 Earthquakes Produced by the San Andreas Fault in Southern California,"
9 Journal of Geophysical Research, Volume 94, pp. 603-623, 1989.
- 10 D.10 R.J. Weldon, III, and K.E. Sieh, "Holocene Rate of Slip and Tentative
11 Recurrence Interval for Large Earthquakes on the San Andreas Fault,
12 Cajon Pass, Southern California," Geological Society of America
13 Bulletin, Volume 96, pp. 793-812, 1985.
- 14 D.11 F.H. Swan, III, D.P. Schwartz, and L.S. Cluff, "Recurrence of Moderate
15 to Large Magnitude Earthquakes Produced by Surface Faulting on the
16 Wasatch Fault Zone," Bulletin of the Seismological Society of America,
17 Volume 70, pp. 1431-1462, 1980.
- 18 D.12 Pacific Gas and Electric Company, "Final Report of the Diablo Canyon
19 Long Term Seismic Program; Diablo Canyon Power Plant," Docket Nos. 50-
20 275 and 50-323, 1988.²
- 21 D.13 S.F. Obermeier et al., "Geologic Evidence for Recurrent Moderate to
22 Large Earthquakes Near Charleston, South Carolina," Science, Volume 227,
23 pp. 408-411, 1985.
- 24 D.14 D. Amick et al., "Paleoliquefaction Features Along the Atlantic
25 Seaboard," U.S. Nuclear Regulatory Commission, NUREG/CR-5613, October
26 1990.¹

27 ²Copies are available for inspection or copying for a fee from the NRC
28 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
29 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
30 (202)634-3343.

- 1 D.15 R.E. Wallace, "Profiles and Ages of Young Fault Scarps, North-Central
2 Nevada," Geological Society of America Bulletin, Volume 88, pp. 1267-
3 1281, 1977.
- 4 D.16 R.E. Wallace, "Discussion--Nomographs for Estimating Components of Fault
5 Displacement from Measured Height of Fault Scarp," Bulletin of the
6 Association of Engineering Geologists, Volume 17, pp. 39-43, 1980.
- 7 D.17 R.E. Wallace, "Active Faults, Paleoseismology, and Earthquake Hazards:
8 Earthquake Prediction--An International Review," Maurice Ewing Series 4,
9 American Geophysical Union, pp. 209-216, 1981.
- 10 D.18 A.J. Crone and S.T. Harding, "Relationship of Late Quaternary Fault
11 Scarps to Subjacent Faults, Eastern Great Basin, Utah," Geology, Volume
12 12, pp. 292-295, 1984.
- 13 D.19 O.W. Nuttli, "The Relation of Sustained Maximum Ground Acceleration and
14 Velocity to Earthquake Intensity and Magnitude, State-of-the-Art for
15 Assessing Earthquake Hazards in the Eastern United States," U.S. Army
16 Corps of Engineers Misc. Paper 5-73-1, Report 16, 1979.
- 17 D.20 R.L. Street and F.T. Turcotte, "A Study of Northeastern North America
18 Spectral Moments, Magnitudes and Intensities," Bulletin of the Seismo-
19 logical Society of America, Volume 67, pp. 599-614, 1977.
- 20 D.21 R.L. Street and A. Lacroix, "An Empirical Study of New England Seis-
21 micity," Bulletin of the Seismological Society of America, Volume 69,
22 pp. 159-176, 1979.
- 23 D.22 H. Rood et al., "Safety Evaluation Report Related to the Operation of
24 Diablo Canyon Nuclear Power Plant, Units 1 and 2," USNRC, NUREG-0675,
25 Supplement No. 34, June 1991.¹
- 26 D.23 S.M. Colman, K.L. Pierce, and P.W. Birkeland, "Suggested Terminology for
27 Quaternary Dating Methods," Quaternary Research, Volume 288, pp. 314-
28 319, 1987.

- 1 D.24 R. Page, "Dating Episodes of Faulting From Tree Rings: Effects of the
2 1958 Rupture of the Fairweather Fault on the Tree Growth," Geological
3 Society of America Bulletin, Volume 81, pp. 3085-3094, 1970.
- 4 D.25 B.F. Atwater and D.K. Yamaguchi, "Sudden, Probably Coseismic
5 Submergences of Holocene Trees and Grass in Coastal Washington State,"
6 Geology, Volume 19, pp. 706-709, 1991.
- 7 D.26 J.r. Bradbury, W.E. Dean, and R.Y. Anderson, "Holocene Climatic and
8 Limnologic History of the North-Central United States as Recorded in the
9 Varved Sediments of Elk Lake, Minnesota: A Synthesis," in J.P. Bradbury
10 and W.E. Dean, editors, Elk Lake, Minnesota: Evidence for Rapid Climate
11 Change in the North-Central United States: Boulder Colorado, Geological
12 Society of America Special Paper 276, 1993.
- 13 D.27 J.F. Callender, "Tectonics and Seismicity," Chapter 4 in "Techniques for
14 Determining Probabilities of Events and Processes Affecting the Perfor-
15 mance of Geologic Repositories," NUREG/CR-3964 (SAND 86-0196), Volume 1,
16 Edited by R. L. Hunter and C. J. Mann, pp. 89-125, June 1989.¹
- 17 D.28 D.J. Donahue, T.W. Linick, and A.J.T. Jull, "Isotope-ratio and
18 Background Corrections for Accelerator Mass Spectrometry Radiocarbon
19 Measurements," Radiocarbon, Volume 32, pp. 135-142, 1990.
- 20 D.29 G.B. Dalrymple and M.A. Lamphere, "Potassium-Argon Dating," San
21 Francisco, W.H. Freeman and Co., 1969.
- 22 D.30 I. McDougall and T.M. Harrison, "Geochronology by the $^{40}\text{Ar}/^{39}\text{Ar}$ Method,"
23 New York, Oxford University Press, 1988.
- 24 D.31 D.R. Muhs and B.J. Szabo, "Uranium-Series Age of the Eel Point Terrace,
25 San Clemente Island, California," Geology, Volume 10, pp. 23-26, 1982.
- 26 D.32 M. Ivanovich, A.G. Latham, and T.L. Ku, "Uranium-Series Disequilibrium
27 Applications in Geochronology," in M. Ivanovich and R.S. Harmon,
28 Editors, Uranium-Series Disequilibrium, Applications to Earth, Marine

1 and Environmental Sciences, 2nd Edition, Oxford University Press,
2 pp. 63-94, 1992.

3 D.33 M.G. Zreda et al., "Cosmogenic ^{36}Cl Production Rates in Terrestrial
4 Rocks," Earth and Planetary Science Letters, Volume 105, pp. 4-109,
5 1991.

6 D.34 K. Nishizumi et al., "Production of ^{10}Be and ^{26}Al by Cosmic Rays in
7 Terrestrial Quartz in situ and Implications for Erosion Rates," Nature,
8 Volume 319, pp. 134-136, 1986.

9 D.35 S.L. Forman, "Applications and Limitations of Thermoluminescence To Date
10 Quaternary Sediments," Quaternary International, Volume 1, pp. 47-59,
11 1989.

12 D.36 M. Ikeya, T. Miki, and K. Tanaka, "Dating of a Fault by Electron Spin
13 Resonance on Intrafault Materials," Science, Volume 215, pp. 1392-1393,
14 1982.

15 D.37 N.D. Naeser and C.W. Naeser, "Fission-Trace Dating," in W.C. Mahney,
16 editor, Quaternary Dating Methods, New York, Elsevier, pp. 87-100, 1984.

17 D.38 S. Self and R.J.S. Sparks, editors, "Tephra Studies," Proceedings of the
18 NATO Advanced Studies Institute, Tephra Studies as a Tool in Quaternary
19 Research, D. Reidel Publishing Co., Dordrecht, Holland, 1981.

20 D.39 J.L. Bada and P. M. Helfman, "Amino Acid Racemization Dating of Fossil
21 Bones," World Archeology, 1975.

22 D.40 J.L. Bada and R. Protsch, "Racemization Reaction of Aspartic Acid and it
23 Use in Dating Fossil Bones," Proceedings of the National Academy of
24 Science, Volume 70, pp. 1331-1334, 1973.

25 D.41 R.I. Dorn and D.H. Krinsley, "Cation-Leaching Sites in Rock Varnish,"
26 Geology, Volume 19, pp. 1077-1080, November 1991.

- 1 D.42 M.N. Machette, "Dating Quaternary Faults in the Southwestern United
2 States by Using Buried Calcic Paleosols," U.S. Geological Survey Journal
3 of Research, Volume 6, pp. 369-381, 1978.
- 4 D.43 M.N. Machette, "Soil Dating Techniques, Western Region (United States),"
5 Open-file Report OFR-82-840, U.S. Geological Survey, pp. 137-140, 1982.
- 6 D.44 L.D. McFadden and J. C. Tinsley, "Soil Profile Development in Xeric
7 Climates: A Summary," in J. C. Tinsley, J. C. Matti, and L. D.
8 McFadden, eds., Guidebook, Field Trip No. 12, Geological Society of
9 America, Cordillera Section, pp. 15-19, 1982.
- 10 D.45 J.W. Hardin, "A Quantitative Index of Soil Development from Field
11 Descriptions: Examples from a Chronosequence in Central California,"
12 Geoderma, Volume 28, pp. 2-18, 1982.
- 13 D.46 J. C. Matti et al., "Holocene Faulting History as Recorded by Alluvial
14 Stratigraphy Within the Cucamonga Fault Zone; A Preliminary View,"
15 in J. C. Tinsley, J. C. Matti, and L. D. McFadden, eds., Guidebook,
16 Field Trip No. 12, Geological Society of America, Cordillera Section,
17 pp. 29-44, 1982.
- 18 D.47 O.A. Chadwick, S. Hecker, and J. Fonseca, "A Soils Chronosequence at
19 Terrace Creek: Studies of Late Quaternary Tectonism in Dixie Valley,
20 Nevada," Open-file Report 84-0090, U.S. Geological Survey, 1984.
- 21 D.48 E.A. Keller and T.K. Rockwell, "Tectonic Geomorphology, Quaternary
22 Chronology and Paleoseismicity," in J.E. Costa, editor, Developments and
23 Applications of Geomorphology, Springer-Verlag, New York, pp. 203-239,
24 1984.
- 25 D.49 R.C. Bucknam and R.E. Anderson, "Estimation of Fault-Scarp Ages from a
26 Scarp-Height-Slope-Angle Relationship," Geology, volume 7, pp. 11-14,
27 1979.
- 28 D.50 K.L. Pierce, "Dating Methods," Active Tectonics, National Academy of
29 Sciences, Washington, DC, pp. 195-214, 1986.

- 1 D.51 P.D. Sheets and D.K. Grayson, editors, Volcanic Activity and Human
2 Ecology, Academic Press, New York, 1979.
- 3 D.52 R.T. Saucier, "Geoarchaeological Evidence of Strong Prehistoric
4 Earthquakes in the New Madrid (Missouri) Seismic Zone," Geology, Volume
5 19, No. 4. pp. 296-289, 1991.
- 6 D.53 P.C. Valentine, "Zoogeography of Holocene Ostracoda off Western North
7 America and Paleoclimatic Implications," U.S. Geological Survey
8 Professional Paper 916, 1976.
- 9 D.54 W.W. Locke, J.T. Andrews, and P.J. Webber, "A Manual for Lichenometry,"
10 Technical Bulletin 26, British Geomorphological Research Group, Norwich,
11 University of East Anglia, 1979.

APPENDIX E

PROCEDURE FOR THE EVALUATION OF NEW GEOSCIENCES INFORMATION OBTAINED FROM THE SITE-SPECIFIC INVESTIGATIONS

E.1 INTRODUCTION

This appendix provides methods acceptable to the NRC staff for assessing the impact of new information obtained during site-specific investigations on the database used for the probabilistic seismic hazard analysis (PSHA).

Regulatory Position 4 in this guide describes acceptable PSHA analyses that were developed by Lawrence Livermore National Laboratories (LLNL) and the Electric Power Research Institute (EPRI) to characterize the seismic hazard for nuclear power plants estimate the controlling earthquakes and to develop the Seismic Shutdown Earthquake ground motion (SSE). The procedure to determine the SSE outlined in this Draft Regulatory Guide 1.165 DG-1032 relies primarily on LLNL and EPRI PSHA results for the Central and Eastern United States (CEUS).

It is necessary to evaluate the geological, seismological, and geophysical data obtained from the site-specific investigations to demonstrate that these data are consistent with the PSHA data bases of these two methodologies. If significant differences in information are identified by the site-specific investigations, the results that are validated by a strong technical basis and the differences are identified and differences would result in a significant increase in the hazard estimate for a site, and this new information is validated by a strong technical basis, the PSHA may have to be modified to incorporate the new technical information. Using sensitivity studies, it may also be possible to justify a lower hazard estimate with an exceptionally strong technical basis. However, it is expected that large uncertainties in estimating seismic hazard in the CEUS will continue to exist in the future, and substantial delays in the licensing process will result in trying to address them with respect to a specific site.

In general, major recomputations of the LLNL and EPRI data base are planned periodically (approximately every ten years), or when there is an important new finding or occurrence. The overall revision of the data base

1 will also require a reexamination of the reference probability discussed in
2 Appendix B.

3 E.2 POSSIBLE SOURCES OF NEW INFORMATION THAT COULD AFFECT THE SSE

4 Types of new data that could affect the PSHA results can be put in three
5 general categories: seismic sources, earthquake recurrence models or rates of
6 deformation, and ground motion models.

7 E.2.1 Seismic Sources

8 There are several possible sources of new information from the site-
9 specific investigations that could affect the seismic hazard. Continued
10 recording of small earthquakes, including microearthquakes, may indicate the
11 presence of a localized seismic source. Paleoseismic evidence, such as
12 paleoliquefaction features or displaced Quaternary strata, may indicate the
13 presence of a previously unknown tectonic structure or a larger amount of
14 activity on a known structure than was previously considered. Future
15 geophysical studies (aeromagnetic, gravity, and seismic
16 reflection/refraction) ~~will probably~~ may identify crustal structures that
17 suggest the presence of previously unknown seismic sources. In situ stress
18 measurements and the mapping of tectonic structures in the future may indicate
19 potential seismic sources.

20 Detailed local site investigations often reveal faults or other tectonic
21 structures that were unknown, or reveal additional characteristics of known
22 tectonic structures. Generally, based on past licensing experience in the
23 CEUS, the discovery of such features will not require a modification of the
24 seismic sources provided in the LLNL and EPRI studies. However, initial
25 evidence regarding a newly discovered tectonic structure in the CEUS is often
26 equivocal with respect to activity, and additional detailed investigations are
27 required. By means of these detailed investigations, and based on past
28 licensing activities, previously unidentified tectonic structures can usually
29 be shown to be inactive or otherwise insignificant to the seismic design basis
30 of the facility, and a modification of the seismic sources provided by the
31 LLNL and EPRI studies will not be required. On the other hand, if the newly
32 discovered features are relatively young, possibly associated with historical

1 earthquakes that were large and close to ~~could~~ impact the hazard for the
2 proposed facility, a modification may be required.

3 Of particular concern is the possible existence of previously unknown,
4 potentially active tectonic structures that could ~~localize~~ have moderately-
5 sized, but potentially damaging, near-field earthquakes or could cause surface
6 displacement. Also of concern is the presence of structures that could
7 generate larger earthquakes within the region.

8 Investigations to determine whether there is a possibility for permanent
9 ground displacement are especially important in view of the provision to allow
10 for a combined licensing procedure under 10 CFR Part 52 as an alternative to
11 the two-step procedure of the past (Construction Permit and Operating
12 License). In the past at numerous nuclear power plant sites, potentially
13 significant faults were identified when excavations were made during the
14 construction phase prior to the issuance of an operating license, and
15 extensive additional investigations of those faults had to be carried out to
16 properly characterize them.

17 E.2.2 Earthquake Recurrence Models

18 There are three elements of the source zone's recurrence models that
19 could be affected by new site-specific data: (1) the rate of occurrence of
20 earthquakes, (2) their maximum magnitude, and (3) the form of the recurrence
21 model, for example, a change from truncated exponential to a characteristic
22 earthquake model. Among the new site-specific information that is most likely
23 to have a significant impact on the hazard is the discovery of paleoseismic
24 evidence such as extensive soil liquefaction features, which would indicate
25 with reasonable confidence that much larger estimates of the maximum
26 earthquake ~~would ensue~~ than those predicted by the previous studies ~~would~~
27 ~~ensue~~. The paleoseismic data could also be significant even if the maximum
28 magnitudes of the previous studies are consistent with the paleoseismic
29 earthquakes if there are sufficient data to develop return period estimates
30 significantly shorter than those previously used in the probabilistic
31 analysis. The paleoseismic data could also indicate that a characteristic
32 earthquake model would be more applicable than a truncated exponential model.

33 In the future, expanded earthquake catalogs will become available that
34 will differ from the catalogs used by the previous studies. Generally, these
35 new catalogues have been shown to have only minor impacts on estimates of the

1 parameters of the recurrence models. Cases that might be significant include
2 the discovery of records that ~~place~~ indicate earthquakes in a region that had
3 no seismic activity in the previous catalogs, the occurrence of an earthquake
4 larger than the largest historic earthquakes, re-evaluating the largest
5 historic earthquake to a significantly larger magnitude, or the occurrence of
6 one or more moderate to large earthquakes (magnitude 5.0 or greater) in the
7 CEUS.

8 Geodetic measurements, particularly satellite-based networks, may
9 provide data and interpretations of rates and styles of deformation in the
10 CEUS that can have implications for earthquake recurrence. New hypotheses
11 regarding present-day tectonics based on new data or reinterpretation of old
12 data may be developed that were not considered or given high weight in the
13 EPRI or LLNL PSHA. Any of these cases could have an impact on the estimated
14 maximum earthquake if the result is larger than the values provided by LLNL
15 and EPRI.

16 E.2.3 Ground Motion Attenuation Models

17 Alternative ground motion models may be used to determine the site-
18 specific spectral shape as discussed in Regulatory Position 4 and Appendix F
19 of this regulatory guide. If the ground motion models used are a major
20 departure from the original models used in the hazard analysis and are likely
21 to have impacts on the hazard results of many sites, a reevaluation of the
22 reference probability may be needed using the procedure discussed in Appendix
23 B. Otherwise, a periodic (e.g., every ten years) reexamination of PSHA and
24 the associated data base is considered appropriate to incorporate new
25 understanding regarding ground motion models.

26 E.3 PROCEDURE AND EVALUATION

27 The EPRI and LLNL studies provided a wide range of interpretations of
28 the possible seismic sources for most regions of the CEUS, as well as a wide
29 range of interpretations for all the key parameters of the seismic hazard
30 model. The first step in comparing the new information with those
31 interpretations is determining whether the new information is consistent with
32 the following LLNL and EPRI parameters: (1) the range of seismogenic sources
33 as interpreted by the seismicity experts or teams involved in the study, (2)

1 the range of seismicity rates for the region around the site as interpreted by
2 the seismicity experts or teams involved in the studies, and (3) the range of
3 maximum magnitudes determined by the seismicity experts or teams. The new
4 information is considered not significant and no further evaluation is needed
5 if it is consistent with the assumptions used in the PSHA, no additional
6 alternative seismic sources or seismic parameters are needed, or it supports
7 maintaining or decreasing the site median seismic hazard.

8 An example is an additional nuclear unit sited near an existing nuclear
9 power plant site that was recently investigated by state-of-the-art
10 geosciences techniques and evaluated by current hazard methodologies.
11 Detailed geological, seismological, and geophysical site-specific
12 investigations would be required to update existing information regarding the
13 new site, but it is very unlikely that significant new information would be
14 found that would invalidate the previous PSHA.

15 On the other hand, after evaluating the results of the site-specific
16 investigations, if there is still uncertainty about whether the new
17 information will affect the estimated hazard, it will be necessary to evaluate
18 the potential impact of the new data and interpretations on the median of the
19 range of the input parameters. Such new information may indicate the addition
20 of a new seismic source, a change in the rate of activity, a change in the
21 spatial patterns of seismicity, an increase in the rate of deformation, or the
22 observation of a relationship between tectonic structures and current
23 seismicity. The new findings should be assessed by comparing them with the
24 specific input of each expert or team that participated in the PSHA.
25 Regarding a new source, for example, the specific seismic source
26 characterizations for each expert or team (such as tectonic feature being
27 modeled, source geometry, probability of being active, maximum earthquake
28 magnitude, or occurrence rates) should be assessed in the context of the
29 significant new data and interpretations.

30 Usually It is expected that the new information will be within the range
31 of interpretations in the existing data base, and the data will not result in
32 an increase in overall seismicity rate or increase in the range of maximum
33 earthquakes to be used in the probabilistic analysis. It can then be
34 concluded that the current LLNL or EPRI results apply. It is possible that
35 the new data may necessitate a change in some parameter. In this case,
36 appropriate sensitivity analyses should be performed to determine whether the

1 new site-specific data could affect the ground motion estimates at the
2 reference probability level.

3 An example is a consideration of the seismic hazard near the Wabash
4 River Valley (Ref. E.1). Geological evidence found recently within the Wabash
5 River Valley and several of its tributaries indicated that an earthquake much
6 larger than any historic event had occurred several thousand years ago in the
7 vicinity of Vincennes, Indiana. A review of the inputs by the experts and
8 teams involved in the LLNL and EPRI PSHA's revealed that many of them had made
9 allowance for this possibility in their tectonic models by assuming the
10 extension of the New Madrid Seismic Zone northward into the Wabash Valley.
11 Several experts had given strong weight to the relatively high seismicity of
12 the area, including the number of magnitude 5 historic earthquakes that have
13 occurred, and thus had assumed the larger event. This analysis of the source
14 characterizations of the experts and teams resulted in the conclusion by the
15 analysts that a new PSHA would not be necessary for this region because an
16 event similar to the prehistoric earthquake had been considered in the
17 existing PSHAs.

18 A third step would be required if the site-specific geosciences
19 investigations revealed significant new information that would substantially
20 affect the estimated hazard. Modification of the seismic sources would more
21 than likely be required if the results of the detailed local and regional site
22 investigations indicate that a previously unknown seismic source is identified
23 in the vicinity of the site. A hypothetical example would be the recognition
24 of geological evidence of recent activity on a fault near a nuclear power
25 plant site in the stable continental region (SCR) similar to the evidence
26 found on the Meers Fault in Oklahoma (Ref. E.2). If such a source is
27 identified, the same approach used in the active tectonic regions of the
28 Western United States should be used to assess the largest earthquake expected
29 and the rate of activity. If the resulting maximum earthquake and the rate of
30 activity are higher than those provided by the LLNL or EPRI experts or teams
31 regarding seismic sources within the region in which this newly discovered
32 tectonic source is located, it may be necessary to modify the existing
33 interpretations by introducing the new seismic source and developing modified
34 seismic hazard estimates for the site. The same would be true if the current
35 ground motion models are a major departure from the original models. These
36 occurrences would likely require performing a new PSHA using the updated data

- 1 base, and may require determining the appropriate reference probability in
- 2 accordance with the procedure described in Appendix B.

1 REFERENCES

2 E.1 Memorandum from J. Murphy, NRC, to L. Shao, NRC, Subject: Summary of a
3 Public Meeting on the Revision of Appendix A, "Seismic and Geologic
4 Siting Criteria for Nuclear Power Plants," to 10 CFR Part 100;
5 Enclosure (Viewgraphs): NUMARC, "Development and Demonstration of
6 Industry's Integrated Seismic Siting Decision Process,"
7 February 23, 1993.¹

8 E.2 A.R. Ramelli, D.B. Slemmons, and S.J. Brocoum, "The Meers Fault:
9 Tectonic Activity in Southwestern Oklahoma," NUREG/CR-4852, US NRC,
10 March 1987.²

11 ¹Copies are available for inspection or copying for a fee from the NRC
12 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
13 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
14 (202)634-3343.

15 ²Copies are available for inspection or copying for a fee from the NRC
16 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
17 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
18 (202)634-3343. Copies may be purchased at current rates from the U.S.
19 Government Printing Office, P.O. Box 37082, Washington, DC 20402-9328
20 (teléfono (202)512-2249); or from the National Technical Information Service
21 by writing NTIS at 5285 Port Royal Road, Springfield, VA 22161.

APPENDIX F

PROCEDURE TO DETERMINE THE SAFE SHUTDOWN EARTHQUAKE GROUND MOTION

F.1 INTRODUCTION

This appendix elaborates on Step 4 of Regulatory Position 4 of ~~Draft Regulatory Guide DG-1032~~ this guide, which describes an acceptable procedure to determine the Safe Shutdown Earthquake Ground Motion (SSE). The SSE is defined in terms of the horizontal and vertical free-field ground motion response spectra at the free ground surface. It is developed with consideration of local site effects and site seismic wave transmission effects. The SSE response spectrum ~~is~~ can be determined by scaling a site-specific spectral shape determined for the controlling earthquakes or by scaling a standard broad-band spectral shape to envelope the average of the ground motion levels for 5 and 10 Hz ($S_{a,5-10}$), and 1 and 2.5 Hz ($S_{a,1-2.5}$) as determined in Step C.2 of Appendix C to this guide.

It is anticipated that a regulatory guide will be developed that provides guidance on assessing site-specific effects and determining smooth design response spectra, taking into account recent developments in ground motion modeling and site amplification studies (e.g., Ref. F.1).

F.2 DISCUSSION

For engineering purposes, it is essential that the design ground motion response spectrum be a broad-band smooth response spectrum with adequate energy in the frequencies of interest. In the past, it was general practice to select a standard broad-band spectrum, such as the spectrum in Regulatory Guide 1.60 (Ref. F.2), and anchor scale it to by a peak ground motion parameter (usually peak ground acceleration (PGA)), which is derived based on the size of the controlling earthquake. During the licensing review this spectrum was checked against site-specific spectral estimates derived using Standard Review Plan 2.5.2 procedures to be sure that the SSE design spectrum adequately enveloped the site-specific spectrum. These past practices to define the SSE are still valid and, based on this consideration, the following three possible situations are depicted in Figures F.1 to F.3.

Figure F.1 depicts a situation in which a site is to be used for a

1 certified design with an established SSE (for instance, an Advanced Light
2 Water Reactor with 0.3g PGA SSE). In this example, the certified design SSE
3 spectrum compares favorably with the site-specific response spectra determined
4 in Step 2 or 3 of Regulatory Position 4.

5 Figure F.2 depicts a situation in which a standard broad-band shape is
6 selected and its amplitude is scaled so that the design SSE envelopes the
7 site-specific spectra.

8 Figure F.3 depicts a situation in which a specific smooth shape for the
9 design SSE spectrum is developed to envelope the site-specific spectra. In
10 this case, it is particularly important to be sure that the SSE contains
11 adequate energy in the frequency range of engineering interest and is
12 sufficiently broad-band.




Figure F.1 Use of SSE Spectrum of a Certified Design




Figure F.2 Use of a Standard Shape for SSE




Figure F.3 Development of a Site-Specific SSE Spectrum

(Note: The above figures illustrate situations for a rock site. For other site conditions the SSE spectra are compared at free-field after performing site amplification studies as discussed in Step 4 of Regulatory Position 4.)

1 REFERENCES

- 2 F.1 Electric Power Research Institute, "Guidelines for Determining Design
3 Basis Ground Motions," EPRI Report TR-102293, Volumes 1-4, May 1993.
- 4 F.2 USNRC, "Design Response Spectra for Seismic Design of Nuclear Power
5 Plants," Regulatory Guide 1.60.¹

6 ¹Copies are available for inspection or copying for a fee from the NRC
7 Public Document Room at 2120 L Street NW., Washington, DC; the PDR's mailing
8 address is Mail Stop LL-6, Washington, DC 20555; telephone (202)634-3273; fax
9 (202)634-3343. Copies may be purchased at current rates from the U.S.
10 Government Printing Office, P.O. Box 37082, Washington, DC 20402-9328
11 (teléfono (202)512-2249); or from the National Technical Information Service
12 by writing NTIS at 5285 Port Royal Road, Springfield, VA 22161.

1 REGULATORY ANALYSIS

2 A separate regulatory analysis was not prepared for this regulatory
3 guide. The ~~draft~~ regulatory analysis, "~~Proposed~~ Revision of 10 CFR Part 100
4 and 10 CFR Part 50," was prepared for the ~~proposed~~ amendments, and it provides
5 the regulatory basis for this guide and examines the costs and benefits of the
6 rule as implemented by the guide. A copy of the ~~draft~~ regulatory analysis is
7 available for inspection and copying for a fee at the NRC Public Document
8 Room, 2120 L Street NW. (Lower Level), Washington, DC, as ~~Enclosure 2 to~~
9 ~~Secy 94-194~~ LATER.

ATTACHMENT 11

SRP SECTION 2.5.1, REVISION 3

(BASIC GEOLOGIC AND SEISMIC INFORMATION)

1 U.S. NUCLEAR REGULATORY COMMISSION
2 STANDARD REVIEW PLAN 2.5.1
3 BASIC GEOLOGIC AND SEISMIC INFORMATION
4 ~~PROPOSED REVISION 3~~

February 1995
Contact: A.J. Murphy
(301) 415-6010

6 REVIEW RESPONSIBILITIES

7 Primary - Civil Engineering and Geosciences Branch (ECGB)

8 Secondary - None

9 I. AREAS OF REVIEW

10 ECGB reviews the geological, seismological, and geophysical information
11 submitted in the applicant's early site evaluation report (ESR) or safety
12 analysis report (SAR), Sections 2.5.1, 2.5.2 and 2.5.3. The technical
13 information presented in these sections of the SAR or ESR results largely from
14 surface and subsurface geological, seismological, geophysical, and
15 geotechnical investigations performed in progressively greater detail toward
16 the site, within each of the areas described by radii of 320 km (200 mi), 40
17 km (25 mi), 8 km (5 mi), and in the site area 1 km (0.6 mi) around the site.
18 The following specific subjects are addressed: 1. tectonic and seismic
19 information, nontectonic deformation information, and conditions caused by
20 human activities, with respect to Regional Geology (Subsection 2.5.1.1), and
21 Site Geology (Subsection 2.5.1.2).

This standard review plan is being issued in draft form to involve the public in the early stages of its development. It has not received complete staff review and does not represent an official NRC staff position.

Public comments are being solicited on this draft standard review plan, which is part of a group of drafts of regulatory guides and standard review plan sections on meeting proposed amendments to the regulations on siting nuclear power plants (59 FR 52255). Comments should be accompanied by appropriate supporting data. Written comments may be submitted to the Rule Review and Directives Branch, DFIRS, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Copies of comments received may be examined at the NRC Public Document Room, 2120 L Street NW, Washington, DC. Comments will be most helpful if received by May 12, 1995.

Requests for single copies of this standard review plan (which may be reproduced) will be filled while supplies last. Requests should be in writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Office of Administration, Distribution and Mail Services Section.

1 Because there is a strong overlap among these areas of review and those of
2 geotechnical engineering and geohydrology, the reviewers of these sections of
3 the SARs should also carefully review SRP Section 2.5.4 and Section 2.4.12,
4 and closely coordinate their reviews and findings with those of the
5 geotechnical engineering and the geohydrology reviewers. For example,
6 coordination with geotechnical engineers is required when verification of
7 geological processes affecting the site, such as the preloading history of the
8 plant's soil foundations by means of glacial and other geologic processes, can
9 be determined through various geotechnical testing methodologies.

10
11 References 1 through 8 (regulations and regulatory guides) provide guidance to
12 the ECGB reviewers in evaluating potential nuclear facility sites. The
13 principal regulation that will be used by ECGB in the future to determine the
14 scope and adequacy of the submitted geological, seismological, and geophysical
15 information for new nuclear facility sites is 10 CFR Part 100, ~~Proposed~~
16 Section 100.23, "Seismic and Geologic Siting Factors" (Ref. 2). Specific
17 guidance for implementing this regulation can be found in ~~Draft~~ Regulatory
18 Guide ~~RG-1032~~ 165, "Identification and Characterization of Seismic Sources
19 and Determination of Safe Shutdown Earthquake Ground Motions" (Ref. 3).
20 Guidance regarding the geotechnical engineering aspects is found in Regulatory
21 Guide 1.132, "Site Investigations for Foundations of Nuclear Power Plants"
22 (Ref. 4). Additional guidance is provided to the ECGB reviewers through
23 information published in the scientific literature. As the state of the art
24 in the geosciences is advancing rapidly, it is the responsibility of the
25 reviewers to stay abreast of changes by reviewing the current scientific
26 literature on a regular basis, attending professional meetings, etc.

~~This standard review plan is being issued in draft form to involve the public in the early stages of its development. It has not received complete staff review and does not represent an official NRC staff position.~~

~~Public comments are being solicited on this draft standard review plan, which is part of a group of drafts of regulatory guides and standard review plan sections on siting proposed amendments to the regulations on siting nuclear power plants (E.O. 12255). Comments should be accompanied by appropriate supporting data. Written comments may be submitted to the Rules Review and Directives Branch, DFIRS, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Copies of comments received may be examined at the NRC Public Document Room, 2120 L Street NW, Washington, DC. Comments will be most helpful if received by May 12, 1995.~~

~~Requests for single copies of this standard review plan (which may be reproduced) will be filled while supplies last. Requests should be in writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Office of Administration, Distribution and Mail Services Section.~~

1 Using the knowledge derived from these activities and the geosciences
2 reviewers' own aggregate academic backgrounds and experience, ECGB judges the
3 adequacy of the geological, seismological, and geophysical information cited
4 in support of the applicant's conclusions concerning the suitability of the
5 plant site.

6 The geological, seismological, and geophysical information that must be
7 provided by applicants for the site review to proceed is divided into the
8 following three basic categories:

- 9 1. Tectonic or seismic information. Information regarding tectonics,
10 (particularly Quaternary tectonics), seismicity, correlation of
11 seismicity with tectonic structure, characterization of seismic sources,
12 and ground motion. Seismicity and vibratory ground motions are primary
13 review responsibilities addressed in SRP Section 2.5.2. However, the
14 review and acceptance of the applicant's basic data-gathering processes
15 and findings that are presented in support of these topics, and their
16 completeness, are also integral parts of the review responsibilities
17 covered in this section. There must be close coordination among
18 geologists, geophysicists, and seismologists in reviewing these
19 sections.

20 Sufficient information must be provided to estimate the potential for
21 strong earthquake ground motions or surface deformation at the site,
22 such as the proximity and nature of potential seismic sources,
23 Quaternary geological evidence for faulting, folding, prehistoric
24 earthquakes (i.e., paleoliquefaction features), and other seismically
25 induced features. A complete presentation, including supporting basic
26 data, of the characteristics of the subsurface materials beneath the
27 site must be provided (or cross-referenced with Standard Review Plan
28 [SRP] Section 2.5.4) and reviewed by the staff so that an assessment of
29 the potential for amplification of vibratory ground motion or ground
30 failure under dynamic loading can be made. Potential ground failure
31 modes may include liquefaction, excessive settlement, differential
32 settlement, and those caused by high tectonic stresses. Additionally,
33 for sites adjacent to large bodies of water, information pertinent to

1 estimating tsunami and seiche hazards must be provided, or cross-
2 referenced to SRP Section 2.4.12.

3 2. Nontectonic deformation information. Adequate information must be
4 provided for an assessment of other nontectonic geological hazards, such
5 as landsliding and other mass-wasting phenomena, subsidence (including
6 differential subsidence), growth faulting, glacially induced
7 deformation, chemical weathering, the potential for collapse or
8 subsidence in areas underlain by carbonate rocks, evidence of
9 preconsolidation, etc.

10 3. Conditions caused by human activities. Information on changes in
11 groundwater conditions caused by the withdrawal or injection of fluids,
12 subsidence or collapse caused by withdrawal of fluids, mineral
13 extraction, induced seismicity and fault movement caused by reservoir
14 impoundment, fluid injection or withdrawal must be included in the SAR
15 or ESR and evaluated by the ECGB staff.

16 Acceptance Criteria related to the above conditions are presented in SAR
17 Subsections 2.5.1.1 (Regional Geology) and 2.5.1.2 (Site Geology). This
18 information should be reviewed in terms of the regional and site tectonics,
19 with emphasis on the Quaternary period, structural geology, physiography,
20 geomorphology, stratigraphy, and lithology. In addition, with specific
21 reference to site geology, the following subjects should be reviewed as they
22 relate to the above-mentioned conditions: topography, slope stability, fluid
23 injection or withdrawal, mineral extraction, faulting, solutioning, jointing,
24 seismicity, and fracturing.

25 The information provided should be documented by appropriate references to all
26 relevant published and unpublished materials. Illustrations such as maps and
27 cross sections should include but should not be limited to structural,
28 tectonic, physiographic, topographic, geologic, gravity, and magnetic maps;
29 structural and stratigraphic sections; boring logs; and aerial photographs.
30 Some sites may require maps of subsidence, irregular weathering conditions,
31 landslide potential, hydrocarbon extraction (oil or gas wells), faults,
32 joints, and karst features. Some site characteristics must be documented by

reference to seismic reflection or refraction profiles or to maps produced by various remote sensing techniques.

Maps should include superimposed plot plans of the plant facilities. Other documentation should show the relationship of all Seismic Category I facilities (clearly identified) to subsurface geology. Core boring logs, logs and maps of trenches, aerial photographs, satellite imagery, and geophysical data should be presented for evaluation. In addition, plot plans showing the locations of all plant structures, borings, trenches, profiles, etc., should be included.

The review can be brought to an earlier conclusion if the ESR or SAR contains sufficient data to allow the reviewers to make an independent assessment of the applicant's conclusions. The reviewers should be led in a logical manner from the data and premises given to the conclusions that are drawn without having to make an extensive independent literature search. A literature search will be conducted by the staff at the appropriate level of detail, depending on the completeness of the SAR or ESR. All pertinent data, including that which is controversial, should be presented and evaluated. The geologic terminology used should conform to standard reference works (Refs. 9 and 10).

The primary purposes for conducting the site and regional investigations are to determine the geological and seismological suitability of the site and to provide the bases for the design of the plant. A secondary goal is to determine whether there is significant new tectonic or ground motion information that could impact the seismic design bases as determined by a probabilistic seismic hazard analysis (PSHA) (Refs. 11, 12, and 13). The objective of Section 2.5.1 of the SAR is to present the results of these investigations and to describe geologic and seismic features as they affect the site under review; all data, information, discussions, interpretations, and conclusions should be directed to this objective.

11. ACCEPTANCE CRITERIA

The applicable rules and basic acceptance criteria pertinent to the areas of this section of the SRP are given below:

1. 10 CFR Part 50, Appendix A, "General Design Criteria for Nuclear Power Plants," General Design Criterion (GDC) 2, "Design Bases for Protection Against Natural Phenomena." - The criterion requires that safety-related portions of the structures, systems, and components important to safety be designed to withstand the effects of earthquakes, tsunami, and seiche without loss of capability to perform their safety functions (Ref. 1).

2. 10 CFR Part 100, Proposed Section 100.23, "Geologic and Seismic Siting Factors" (59 FR 52255) - This proposed section of Part 100 would require that the geological, seismological, geophysical, and geotechnical engineering characteristics of a site and its environs be investigated in sufficient scope and detail to permit an adequate evaluation of the proposed site, to provide sufficient information to support evaluations performed to arrive at estimates of the Safe Shutdown Earthquake ground motion (SSE), to preclude sites with potential surface or near-surface tectonic deformation, and to permit adequate engineering solutions to actual or assumed geologic and seismic effects at the proposed site. It would require the determination of the SSE, the potential for surface tectonic and nontectonic deformations, the design bases for seismically induced floods and water waves, and other design conditions (Ref. 2).

The following regulatory guides provide information, recommendations, and guidance, and in general, describe a basis acceptable to the staff for implementing the requirements of GDC 2, Part 100 50, and Section 100.23 of Part 100.

a. Draft Regulatory Guide DG-10321.165, "Identification and Characterization of Seismic Sources and Determination of Safe Shutdown Earthquake Ground Motions" (Ref.3) - This proposed guide describes acceptable methods to: (1) conduct geological, seismological, and geophysical investigations of the site and region around the site, (2) identify and characterize seismic sources, (3) perform probabilistic seismic hazard analyses (PSHA), and (4) determine the SSE for the site (see SRP Section 2.5.2.6 and Ref. 14).

1 b. Regulatory Guide 1.132, "Site Investigations for Foundations of
2 Nuclear Power Plants" - This guide describes ~~programs~~ of site
3 investigations related to geotechnical aspects that would normally
4 meet the needs for evaluating the safety of the site from the
5 standpoint of the performance of foundations under anticipated
6 loading conditions, including earthquakes. It provides general
7 guidance and recommendations for developing site-specific
8 investigation programs as well as specific guidance for conducting
9 subsurface investigations, including borings, sampling, and
10 geophysical explorations (Ref. 4).

11 c. Regulatory Guide 4.7, "General Site Suitability Criteria for
12 Nuclear Power Stations" - This guide discusses the major site
13 characteristics related to public health and safety that the NRC
14 staff considers in determining the suitability of sites for
15 nuclear power stations (Ref. 5).

16 The information in the SAR or ESR must be complete and thoroughly documented,
17 and it must be consistent with the requirements of Reference 2 and should
18 conform to the format suggested in Reference 6. Information from varied
19 sources, including the United States Geological Survey (USGS) and other
20 Federal or State agencies' published and open file papers, maps, aerial
21 photographs, geophysical data, and similar data from nongovernmental sources
22 covering the region in which the site is located, are used to establish the
23 staff's conclusions as to the completeness and acceptability of the SAR or
24 ESR.

25 The ECGB reviewers must ensure that investigations, as described in ~~Draft~~
26 Regulatory Guide ~~DC-1032~~ 1.165 and Regulatory Guide 1.132, are conducted with
27 the appropriate level of thoroughness within the 4 areas designated in ~~Draft~~
28 Regulatory Guide 1.165 ~~DC-1032~~, based on distances from the site: 320 km (200
29 mi), 40 km (25 mi), 8 km (5 mi), and 1 km (0.6 mi). There must be sufficient
30 information presented in the ESR or SAR on which to base a comparison between
31 the new data derived from the regional and site investigations and that used
32 in the tectonic and ground motion models of the probabilistic seismic hazard
33 analysis (Ref. 3).

Specific criteria necessary to meet the relevant requirements of General Design Criterion 2, of Part 100, ~~Appendix A~~, and ~~Proposed~~ Section 100.23 are as follows:

Subsection 2.5.1.1, "Regional Geology." In meeting the requirements of References 1 and 2, the subsection will be considered acceptable if a complete and documented discussion is presented of all geological, seismological, and geophysical features, as well as conditions caused by human activities. This subsection should contain a review of the regional tectonics, with emphasis on the Quaternary period, structural geology, seismology, paleoseismology, physiography, geomorphology, stratigraphy, and geologic history within a distance of 320 km (200 mi) (site region) from the site, to provide a framework within which the safety significance can be evaluated of the geology, seismology, and conditions brought about by human activities.

Subsection 2.5.1.2, "Site Geology." In meeting the requirements of References 1 and 2, and the regulatory positions of References 4 and 5 and certain recommendations of Reference 7, the subsection will be judged acceptable if it contains a description and evaluation of site-related geologic features, seismic conditions, and conditions caused by human activities, at appropriate levels of detail (defined by the distances of 40 km (25 mi) (site subregion), 8 km (5 mi) (site vicinity), and 1 km (site area) of the site). This subsection should contain the following general site information:

1. The structural geology of the site, specifically the identification and characterization of local seismic sources and their relationship to the regional structural geology and seismic sources.
2. The seismicity of the site, including historical and instrumentally recorded earthquakes, and whether there is a relationship to tectonic structure.
3. The geological history, particularly the Quaternary period, of the site and its relationship to the regional history.
4. Evidence of paleoseismicity or lack of it.

1 all interpretations are founded on sound geological and seismological practice
2 and do not exceed the limits of validity of the applicant's data or of other
3 data, such as that published in the scientific literature.

4 At the beginning of this phase of the review, the staff usually seeks
5 assistance from the U.S. Geological Survey (USGS) and decides to what extent
6 consultants should be involved. The necessary information is then made
7 available to the USGS advisors and consultants. Advisors from the USGS and
8 consultants are asked to perform such varied tasks as reviewing the tectonic
9 setting of plants in regions of complex geology, evaluating the potential for
10 surface displacement, verifying an applicant's mineral identifications and
11 geochronology, or providing advice on the proper level of earthquake ground
12 motion in the seismic evaluation of selected sites.

13 A review of relevant references is conducted by the staff, USGS advisors, and
14 consultants. Pertinent references, such as published geological reports,
15 professional papers, open-file material, university theses, physiographic and
16 geological maps, and aeromagnetic and gravity maps, are ordered from the
17 appropriate sources and reviewed. Several basic general references used in
18 the past by the staff are References 9, 15, and 16. GeoRef database (Ref. 17)
19 and other databases, such as References 18 and 19, are used to identify
20 specific references.

21 As publication usually lags behind the completion of research or construction
22 investigation projects by months or years, the reviewers should not rely
23 entirely on information submitted by the applicant or in the published
24 literature. The reviewers should make an effort to identify any pertinent
25 studies that may be under way in the site region and any preliminary findings
26 of these studies. This may be accomplished by contacting the U.S. Geological
27 Survey or other Federal agencies, State geological surveys, universities, and
28 industry, to obtain current information about the site. Some pertinent
29 information may be of a proprietary nature, and special provisions may be
30 required to examine the data.

31 The staff members will conduct a geological reconnaissance of the site and
32 region around the site as part of the second phase of the review to examine
33 geological features, soil and rock samples from core borings or test pits,

1 trenches excavated across the site, and actual excavations for the plant
2 facilities, if present at this stage. This site reconnaissance is especially
3 important in view of the revised requirement of 10 CFR Part 52 (Ref. 8), which
4 allows for a combined license as an alternative to the previous two-step
5 requirement of a construction permit followed by an operating license. In the
6 previous procedure, many geologic features, such as faults (as at North Anna,
7 Summer, Byron, Catawba, Seabrook, Watts Bar, etc.) that had the potential to
8 impact the safety of the plant were not identified until the actual
9 construction excavations for the plant were made. Additionally, unanticipated
10 engineering problems have occurred during and after construction (as at North
11 Anna, WNP-2, Nine Mile Point-2). For example, larger-than-expected
12 settlements have frequently occurred in engineered backfill, even though the
13 design had been approved by the staff during the construction permit review.
14 Under 10 CFR Part 52 ~~it is possible that~~ the construction excavations for a
15 plant will not be made until after the staff ~~has prepared~~ the site SER.

16
17 During the second phase of the review, questions and comments are developed
18 from items that have not been adequately addressed by the applicant, those
19 which become apparent during the detailed review, or those which develop from
20 the additional information provided as a result of the acceptance review.
21 These first round questions usually require the applicant to conduct
22 additional investigations or to supply clarifying information. Questions may
23 result from the reviewer's discovery of references not cited by the applicant
24 that contain conclusions that are in conflict with those made by the
25 applicant. When the applicant provides insufficient data to support its
26 interpretations and conclusions and there are reasonable, technically
27 supported, and more conservative alternative interpretations in the
28 literature, the staff will request additional investigations, or require that
29 the applicant adopt the more conservative interpretation. This phase of the
30 review will usually involve public meetings with the applicant to clarify
31 questions and allow the applicant to present new data to justify its position.
32 The applicant's response to questions are reviewed and any remaining issues
33 are settled either by a second round of questions or by staff positions.

34 The third review phase is the staff evaluation of the applicant's responses to
35 questions raised in the second phase. At the end of the third phase, the
36 staff takes positions on all safety-related issues, either concurring with the

1 applicant's positions or taking more conservative positions as may be
2 necessary in the staff's view to assure the required degree of safety.

3 A staff position is usually in the form of a requirement to provide
4 confirmatory information or to design for a specific condition in a way that
5 the staff considers to be sufficiently conservative and consistent with the
6 requisites of Reference 2. When all safety issues have been resolved, the
7 staff provides its input to the safety evaluation report (SER).

8 A staff position that has characterized licensing during the past two decades
9 is that all Category 1 excavations are required to be geologically mapped by
10 the applicant and examined by the staff before backfill is placed or concrete
11 poured. These activities were usually accomplished before the SER was made
12 final. This procedure should continue in the future regarding sites that are
13 licensed under the 10 CFR Part 50 two-phase, Construction Permit and Operating
14 Licensing, procedure.

15 However, Under the new 10 CFR Part 52 combined licensing procedure (COL), as
16 described above, geological features such as faults that were are not
17 discovered until after the construction excavations are made, and therefore
18 after the SER has been prepared issued, would will not have been assessed by
19 the staff. Likewise, unanticipated engineering problems such as the presence
20 of liquefiable materials, excessive settlement, heave, or groundwater flow
21 that occurred during or following construction would will not have been
22 evaluated by the staff. For these reasons, there must be a commitment in the
23 site specific portion of the SAR for a facility: (1) notify the staff
24 immediately if previously unknown geologic features that could represent a
25 hazard to the plant are encountered during excavation; (2) geologically map
26 all excavations for Category 1 structures, as a minimum; and (3) notify the
27 staff when the excavations are open for its examination and evaluation.
28 ~~conditions should be included in the SER that the staff should conduct a~~
29 ~~followup site review when the excavations for the Seismic Category 1~~
30 ~~facilities structures are open to confirm tentative the conclusions that the~~
31 ~~site parameters are within the envelope of the certified design, presented in~~
32 ~~the SER., and that final conclusions by the staff are pending the results of~~
33 ~~this site review unless there is reasonable certainty that such occurrences~~
34 ~~are unlikely.~~

IV. EVALUATION FINDINGS

If the evaluation by the staff, on completion of the review of the geological and seismological aspects of the plant site and region, confirms that the applicant has met the requirements of applicable portions of References 1 and 2, and the guidance contained in References 3, 4, 5, and 6, the conclusion in the SER states that the information provided and investigations performed support the applicant's conclusions regarding the geological and seismological integrity of the proposed nuclear power plant site. Licensing conditions instituted by the staff to resolve ~~Staff reservations about~~ any significant deficiency ~~presented~~ identified in the applicant's SAR or ESR are stated in sufficient detail to make clear the precise nature of concern and required resolution.

The evaluation determinations with respect to the geological and seismological suitability of the site are made by the staff after the early site, construction permit, or operating license reviews. A conclusion regarding an Operating License will include an evaluation of the excavations for Category 1 structures. A similar conclusion regarding the geological and seismological suitability of a site following a combined license review will be made when the applicant has committed to mapping excavations for Category 1 facilities and notifying the staff of their availability for examination. ~~should not be tentative finalized until after~~ The staff will conduct this examination at the appropriate time after licensing ~~es the excavations for the seismic category 1 facilities and to confirm~~ determines that there are no previously unknown features, such as potentially active faults, evidence for strong ground motions such as late Quaternary seismically induced paleoliquefaction features, unsuitable soil zones, or cavities in the excavations. There may be additional questions that arise because of this examination. However, documentation of the staff's final conclusions should be made as soon after the excavation examination as possible.

This final staff visit, in addition to determining whether there is any new information since the combined licensing review, ensures that the staff recommendations or ~~positions~~ conditions formulated by the staff during the combined licensing review have been implemented.

1 A typical staff finding at the conclusion of the combined licensing review
2 follows:

3 In its review of the geological and seismological aspects of the plant,
4 the staff has considered pertinent information gathered in support of
5 the application for a combined license. The information reviewed
6 includes data from site and near-site investigations, as well as a
7 geological reconnaissance of the site and region, an independent review
8 of recently published literature, and discussions with knowledgeable
9 scientists with the USGS and other Federal agencies, the State
10 Geological Survey, local universities, consulting firms, etc.

11 Based on its review, the staff concludes that:

12 (1) The results of geological, geophysical and seismological
13 investigations, and other information provided by the applicant
14 and required by the Proposed Section 100.23 of 10 CFR Part
15 100, the staff's independent review of the data and other sources
16 of information, and including a geological reconnaissance of the
17 site and region and examination of excavations for Seismic
18 Category I structures at the site by the staff, provide an
19 adequate basis to establish that no capable tectonic sources or
20 seismogenic sources exist in the plant site area that have the
21 potential of causing near-surface displacement or earthquakes to
22 be centered there.

23 (2) Based on the results of the applicant's regional and site
24 geological, seismological, and geophysical investigations, and the
25 staff's independent evaluation (which is conducted primarily by
26 the reviewer of Section 2.5.2 but supported by the reviewer of
27 this section), the staff concludes that all seismic sources
28 significant to determining the SSE for the site have been
29 identified and appropriately characterized by the applicant in
30 accordance with Draft Regulatory Guide DG-10321.165 and SRP
31 Section 2.5.2.

1 (3) Based on the applicant's geological, geophysical, and geotechnical
2 investigations of the site vicinity and site area, the staff
3 concludes that the site lithology, stratigraphy, geological
4 history, structural geology, and characteristics of the subsurface
5 soils and rocks have been properly characterized.

6
7 (4) There is no potential for the occurrence of other geological
8 events (such as landsliding, collapse or subsidence caused by
9 carbonate solutioning, differential settlement) that could
10 compromise the safety of the site; or the applicant has mitigated
11 such occurrences and has adequately supported the engineering
12 solutions in the SAR.

13 (5) There is no potential for the effects of human activity, such as
14 subsidence caused by withdrawal or injection of fluids or collapse
15 due to mineral extraction, that compromises the safety of the
16 site; or the applicant has taken steps to prevent such occurrences
17 and has adequately supported these actions in the SAR.

18 (6) If this is a combined license review, ~~the staff states that the~~
19 ~~conclusions stated under (1) above are pending until will be~~
20 ~~confirmed after by the staff, after based on~~ a detailed
21 examination of the walls and floors of the excavations for the
22 seismic category 1 facilities and the applicant's geological map
23 of these exposures; and an examination by the staff of the
24 applicant's engineering solutions to mitigate any nontectonic
25 geological hazard.

26 The information reviewed for the proposed nuclear power plant is discussed in
27 Sections 2.5.1, 2.5.2, and 2.5.3.

28 The staff concluded that the site is acceptable from a geological and
29 seismological standpoint and meets the requirements of (1) 10 CFR Part 50,
30 Appendix A (General Design Criterion 2) and (2) 10 CFR Part 100, Proposed
31 Section 100.23. This conclusion is based on the following:

32 1. The applicant has met the requirements of:

- a. Appendix A (General Design Criterion 2) of 10 CFR Part 50
with respect to protection against natural phenomena such as
earthquakes, faulting, and collapse.
- b. ~~Proposed~~ Section 100.23 (Geologic and Seismic Siting Factors) to
10 CFR Part 100, with respect to obtaining the geologic and
seismic information necessary to determine (1) site suitability
and (2) the appropriate design of the plant. In complying with
this regulation the applicant also meets the staff's guidance
described in ~~Draft~~ Regulatory Guide ~~DC-10321.165~~, "Identification
and Characterization of Seismic Sources and Determination of Safe
Shutdown Earthquake Ground Motion"; Regulatory Guide 1.132, "Site
Investigations for Foundations of Nuclear Power Plants"; and
Regulatory Guide 4.7, "General Site Suitability Criteria for Nuclear
Power Stations."

V. IMPLEMENTATION

The following is intended to provide guidance to applicants and licensees
regarding the NRC staff's plans for using this SRP section.

Except in those cases in which the applicant proposes an acceptable
alternative method for complying with specified portions of the Commission's
regulations, the method described herein will be used by the staff in its
evaluation of conformance with Commission regulations.

Implementation schedules for conformance to parts of the method discussed
herein are contained in the referenced regulatory guides.

The provisions of this SRP section apply to reviews of construction permits
(CP), operating licenses (OL), early site permits, and combined license
(CP/OL) applications docketed pursuant to ~~the proposed~~ Section 100.23 ~~to~~ of
10 CFR Part 100.

VI. REFERENCES

1. 10 CFR Part 50, Appendix A, General Design Criterion 2, "Design Bases for Protection Against Natural Phenomena."
2. 10 CFR Part 100, ~~Proposed~~ Section 100.23, "Geologic and Seismic Siting Factors" (~~59 FR 52255~~).
3. US NRC, "Identification and Characterization of Seismic Sources and Determination of Safe Shutdown Earthquake Ground Motions," ~~Draft~~ Regulatory Guide ~~DG-1032~~ 1.165.
4. US NRC, Regulatory Guide 1.132, "Site Investigations for Foundations of Nuclear Power Plants."
5. US NRC, "General Site Suitability Criteria for Nuclear Power Stations," Regulatory Guide 4.7 (~~Proposed Revision 2, DG 4004~~).
6. US NRC, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)," Regulatory Guide 1.70.
7. US NRC, "Report of Siting Policy Task Force," NUREG-0625, August 1979.
8. 10 CFR Part 52, "Early Site Permits, Standard Design Certifications; and Combined Licenses for Nuclear Power Plants."
9. R.L. Bates and J. Jackson, editors, "Glossary of Geology," Second Edition, American Geological Institute, Falls Church, Virginia, 1980.
10. S.M. Colman, K. L. Pierce, and P. W. Birkeland, "Suggested Terminology for Quaternary Dating Methods," Quaternary Research, Volume 288, pp. 314-319, 1987.
11. J.B. Savy et al., "Eastern Seismic Hazard Characterization Update," Lawrence Livermore National Laboratory, UCRL-ID-115111, June 1993.
12. US NRC, "Revised Livermore Seismic Hazard Estimates for Sixty-Nine Nuclear Power Plant Sites East of the Rocky Mountains," NUREG-1488, April 1994.

- 1 13. Electric Power Research Institute, "Probabilistic Seismic Hazard
2 Evaluation of Nuclear Power Plant Sites in the Central and Eastern
3 United States," Volumes I through 10, NP-4726A, 1989.
- 4 14. Electric Power Research Institute, "Guidelines for Determining Design
5 Basis Ground Motions," EPRI Report TR-102293, Vols. 1-4, May 1993.
- 6 15. A.L. Odom and R. D. Hatcher, Jr., "A Characterization of Faults in the
7 Appalachian Foldbelt," U.S. Nuclear Regulatory Commission, NUREG/CR-
8 1621, 1980.
- 9 16. G.V. Cohee (Chairman) et al., "Tectonic Map of the United States," U.S.
10 Geological Survey and American Association of Petroleum Geologists 1962.
- 11 17. GeoRef Data Base, American Geological Institute, Falls Church, Virginia.
- 12 18. American Petroleum Institute data base, accessible through RECON system.
- 13 19. RECON/Energy Data base, Department of Energy.

14

ATTACHMENT 12

**SRP SECTION 2.5.2, REVISION 3
(VIBRATORY GROUND MOTION)**

1 U.S. NUCLEAR REGULATORY COMMISSION

2 STANDARD REVIEW PLAN 2.5.2

3 VIBRATORY GROUND MOTION

4 SECOND PROPOSED REVISION 3

February 1995

Contact: A.J. Murphy

(301)415-6010

5 REVIEW RESPONSIBILITIES

6 Primary - Civil Engineering and Geosciences Branch (ECGB)

7 Secondary - None

8 AREAS OF REVIEW

9 The Civil Engineering and Geosciences Branch review covers the seismological,
10 and geological, geophysical, and geotechnical investigations carried out to
11 establish ~~determine~~ the ~~acceleration~~ for the safe shutdown earthquake ~~ground~~
12 ~~motion~~ (SSE) and the operating basis earthquake (OBE) for the site. The safe
13 shutdown earthquake is that earthquake that is based upon an evaluation of the
14 maximum earthquake potential considering the regional and local geology and
15 seismology and specific characteristics of local subsurface material. It is
16 that earthquake that produces the maximum vibratory ground motion for which
17 safety related structures, systems, and components are designed to remain
18 functional. The operating basis earthquake is that earthquake that,
19 considering the regional and local geology, seismology, and specific charac-
20 teristics of local subsurface material, could reasonably be expected to affect
21 the plant site during the operating life of the plant; i.e., that earthquake

This standard review plan is being issued in draft form to involve the public in the early stages of its development. It has not received complete staff review and does not represent an official NRC staff position.

Public comments are being solicited on this draft standard review plan, which is part of a group of drafts of regulatory guides and standard review plan sections on meeting proposed amendments to the regulations on licensing nuclear power plants (50 FR 52355). Comments should be accompanied by appropriate supporting data. Written comments may be submitted to the Rules Review and Directive Branch, DFPS, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Copies of comments received may be examined at the NRC Public Document Room, 2120 L Street, NW, Washington, DC. Comments will be most helpful if received by May 12, 1995.

Requests for single copies of this standard review plan (which may be reproduced) will be filled while supplies last. Requests should be in writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Office of Administration, Distribution and Mail Services Section.

1 ~~that produces the vibratory ground motion for which those features of the~~
2 ~~nuclear power plant necessary for continued operation without undue risk to~~
3 ~~the health and safety of the public are designed to remain functional. The~~
4 ~~SSE represents the potential for design earthquake ground motion at the site~~
5 ~~and is the vibratory ground motion for which certain structures, systems, and~~
6 ~~components are designed to remain functional. The SSE is based upon a~~
7 ~~detailed evaluation of earthquake potential, taking into account regional and~~
8 ~~local geology, Quaternary tectonics, seismicity, and specific geotechnical~~
9 ~~characteristics of the site's subsurface material. The SSE is defined as the~~
10 ~~free-field horizontal and vertical ground response spectra at the plant site.~~

11 The principal regulation used by the staff in determining the scope and
12 adequacy of the submitted seismologic and geologic information and attendant
13 procedures and analyses is Section 100.23 of 10 CFR Part 100 (Ref. 1).
14 Additional guidance information (regulations, regulatory guides, and reports)
15 is provided to the staff through References 2 through 8 9.

16 Guidance on seismological and geological investigations is ~~being developed~~
17 ~~provided in Draft Regulatory Guide DG-1032 1.165, "Identification and~~
18 ~~Characterization of Seismic Sources and Determination of Safe Shutdown~~
19 ~~Earthquake Ground Motion."~~ These investigations describe the seismicity of
20 the site region and the correlation of earthquake activity with seismic
21 sources. Seismic sources are identified and characterized, including the
22 rates of occurrence of earthquakes associated with each seismic source. All
23 Seismic sources that have any part within 320 km (200 miles) of the site must
24 be identified. More distant sources that have a potential for earthquakes
25 large enough to affect the site must also be identified. Seismic sources can
26 be capable tectonic sources or seismogenic sources; a seismotectonic province
27 is a type of seismogenic source.

28 Specific areas of review include seismicity (Subsection 2.5.2.1), geologic and
29 tectonic characteristics of the site and region (Subsection 2.5.2.2), correla-
30 tion of earthquake activity with ~~geologic structure or tectonic provinces~~
31 ~~seismic sources~~ (Subsection 2.5.2.3), ~~maximum earthquake potential~~
32 ~~probabilistic seismic hazard analysis~~ (PSHA) and controlling earthquakes
33 (Subsection 2.5.2.4), seismic wave transmission characteristics of the site
34 (Subsection 2.5.2.5), and safe shutdown earthquake ground motion (Subsection

2.5.2.6), ~~and operating basis earthquake (Subsection 2.5.2.7).~~

The geotechnical engineering aspects of the site and the models and methods employed in the analysis of soil and foundation response to the ground motion environment are reviewed under SRP Section 2.5.4. The results of the geosciences review are used in SRP Sections 3.7.1 and 3.7.2.

II. ACCEPTANCE CRITERIA

The applicable regulations (Refs. 1, 2, and 3) and regulatory guides (Refs. 4, 5, 6, ~~and 9~~) and basic acceptance criteria pertinent to the areas of this section of the Standard Review Plan are:

1. 10 CFR Part 100, "Reactor Site Criteria" (Ref. 3). This part describes general criteria that guide the evaluation of the suitability of proposed sites for nuclear power and testing reactors.

~~Proposed Section 100.23 10 CFR Part 100, "Geologic and Seismic Siting Factors," Appendix A, "Seismic and Geologic Siting Criteria for Nuclear Power Plants." These criteria describes the kinds of geologic and seismic information needed to determine site suitability and identify geologic and seismic factors required to be taken into account in the siting and design of nuclear power plants (Ref. 1).~~

2. 10 CFR Part 50, Appendix A, "General Design Criteria for Nuclear Power Plants"; General Design Criterion 2, "Design Bases for Protection Against Natural Phenomena" (Ref. 2). This criterion requires that safety-related portions of the structures, systems, and components important to safety ~~shall~~ be designed to withstand the effects of earthquakes, tsunamis, and seiches without loss of capability to perform their safety functions.

- ~~3. 10 CFR Part 100, "Reactor Site Criteria" (Ref. 3). This part describes criteria that guide the evaluation of the suitability of proposed sites for nuclear power and testing reactors.~~

1 4 3. Regulatory Guide 1.132, "Site Investigations for Foundations of Nuclear
2 Power Plants." This guide describes programs of site investigations
3 related to geotechnical aspects that would normally meet the needs for
4 evaluating the safety of the site from the standpoint of the performance
5 of foundations under anticipated loading conditions, including
6 earthquakes. It provides general guidance and recommendations for
7 developing site-specific investigation programs as well as specific
8 guidance for conducting subsurface investigations, including the spacing
9 and depth of borings as well as sampling intervals (Ref. 4).

10 5 4. Regulatory Guide 4.7 (~~Proposed Revision 2, DG-4004~~), "General Site
11 Suitability Criteria for Nuclear Power Stations." This guide discusses
12 the major site characteristics related to public health and safety which
13 that the NRC staff considers in determining the suitability of sites for
14 nuclear power stations (Ref. 5).

15 6 5. Regulatory Guide 1.60, "Design Response Spectra for Seismic Design of
16 Nuclear Power Plants." ~~This guide gives one method acceptable to the~~
17 ~~NRC staff for defining the response spectra corresponding to the~~
18 ~~expected maximum ground acceleration (Ref. 6). See also Smoothed~~
19 ~~response spectra are generally used for design purposes - for example, a~~
20 ~~standard spectral shape that has been used in the past is presented in~~
21 ~~Regulatory Guide 1.60 (Ref. 6). These smoothed spectra are still~~
22 ~~acceptable when the smoothed design spectra compare favorably with site-~~
23 ~~specific response spectra derived from the ground motion estimation~~
24 ~~procedures discussed in Subsection 2.5.2.6.~~

25 6. ~~Draft Regulatory Guide DG-1032 (Ref. 9)~~ 165, "Identification and
26 Characterization of Seismic Sources and Determination of Safe Shutdown
27 Earthquake Ground Motion," describes acceptable methodologies for
28 determining the controlling earthquakes and SSE ground motion for
29 nuclear power plant sites. (Ref. 9)

30 The principal geologic and seismic consideration for site suitability and
31 geologic and primary required investigations are described in 10 CFR Part 100,
32 in Section IV(a) of Appendix A (Ref. 1) The acceptable procedures for
33 determining the seismic design bases are given in Sections V(a) and Section

1 ~~1(a) of the appendix. In the proposed Section 100.23 of 10 CFR Part 100.~~
2 ~~Draft Regulatory Guide DG-1032 1.165 (Ref. 9) is being developed to provides~~
3 ~~more detailed guidance on investigations. The seismic design bases are~~
4 ~~predicated on a reasonable, conservative determination of the SSE and the OBE.~~
5 ~~As defined in Section 111 of Appendix A (Ref. 1) to 10 CFR Part 100, the The~~
6 ~~SSE and OBE are~~ is based on consideration of the regional and local geology
7 and seismology and on the characteristics of the subsurface materials at the
8 site. ~~and are described in terms of the vibratory ground motion that they~~
9 ~~would produce at the site. No comprehensive definitive rules can be~~
10 promulgated regarding the investigations needed to establish the seismic
11 design bases; the requirements vary from site to site.

12 2.5.2.1 Seismicity. In ~~to~~ meeting the requirements of ~~proposed in~~
13 Reference 1, this subsection is accepted when the complete historical record
14 of earthquakes in the region is listed and when all available parameters are
15 given for each earthquake in the historical record. The listing should
16 include all earthquakes having Modified Mercalli Intensity (MMI) greater than
17 or equal to IV or magnitude greater than or equal to 3.0 that have been
18 reported in all tectonic provinces ~~for all seismic sources~~, any parts of which
19 are within 320 km (200 miles) of the site. ~~Other large earthquakes outside of~~
20 ~~this area, but which would impact the SSE, should be reported.~~ A regional-
21 scale map should be presented showing all listed earthquake epicenters and
22 should be supplemented by a larger-scale map showing earthquake epicenters of
23 all known events within 80 km (50 miles) of the site. The following
24 information concerning each earthquake is required whenever it is available:
25 epicenter coordinates, depth of focus, date, origin time, highest intensity,
26 magnitude, seismic moment, source mechanism, source dimensions, distance from
27 the site, and any strong-motion recordings (sources from which the information
28 was obtained should be identified). All magnitude designations such as m_b ,
29 M_L , M_s , M_w should be identified. In the Central and Eastern United States,
30 relatively little information is available on magnitudes for the larger
31 historic earthquakes; hence, it may be appropriate to rely on intensity
32 observations (descriptions of earthquake effects) or the dimensions of the
33 area in which the event was felt to estimate magnitudes of historic events
34 (e.g., Refs. ~~34 and 35~~ 10 and 11). In addition, any reported earthquake-
35 induced geologic failure, such as liquefaction (including paleoseismic
36 evidence of large prehistoric earthquakes), landsliding, landspreading, and

lurching should be described completely, including the estimated level of strong motion that induced failure and the physical properties of the materials. The completeness of the earthquake history of the region is determined by comparison to published sources of information (e.g., Refs. 9 through 13). When conflicting descriptions of individual earthquakes are found in the published references, the staff should determine which is appropriate for licensing decisions.

2.5.2.2 Geologic and Tectonic Characteristics of Site and Region. In meeting the requirements of References 1, 2, and 3, this subsection is accepted when all geologic structures within the region and tectonic activity seismic sources that are significant in determining the earthquake potential of the region are identified, or when an adequate investigation has been carried out to provide reasonable assurance that all significant tectonic structures seismic sources have been identified. For the CEUS sites, when the SSE is determined using the results of the LLNL or EPRI PSHA methodology and Regulatory Guide 1.165 (Ref.9), in meeting the requirements of References 1, 2, and 3, this subsection is acceptable when adequate information is provided to demonstrate: (1) that a thorough investigation has been conducted to identify seismic sources that could be significant in estimating the seismic hazard of the region if they exist; and (2) that existing sources (in the PSHA) are consistent with the results of site and regional investigations, or the sources have been updated in accordance with Appendix E of Regulatory Guide 1.165.

For sites where LLNL or EPRI methods and database have not been used, and it is necessary to identify and characterize seismic sources in meeting the requirements of References 1, 2, and 3, this subsection is acceptable when adequate information is provided to demonstrate that all seismic sources that are significant in determining the earthquake potential of the region are identified, or that an adequate investigation has been carried out to provide reasonable assurance that there are no unidentified significant seismic sources.

Information presented in Section 2.5.1 of the applicant's safety analysis report (SAR) and information from other sources (e.g., Refs. 9 and 14 through 18) dealing with the current tectonic regime should be developed into a

1 coherent, well-documented discussion to be used as the basis for
2 characterizing the earthquake-generating potential of seismic sources, the
3 identified geologic structures. Specifically, each tectonic province seismic
4 source, any part of which is within 320 km (200 miles) of the site, must be
5 identified. In the CEUS the seismic sources will most likely be seismogenic
6 sources with large regions of diffuse seismicity, each characterized by the
7 same recurrence model (more specifically referred to as seismotectonic
8 provinces). The staff interprets seismotectonic provinces to be regions of
9 assumed uniform earthquake potential (seismotectonic provinces) seismicity
10 (same frequency of occurrence) distinct from the seismicity of the surrounding
11 area. The proposed seismotectonic provinces may be based on seismicity
12 studies, differences in geologic history, differences in the current tectonic
13 regime, or other tectonic considerations etc.

14 The staff considers that the most important factors for the determination of
15 seismic sources tectonic provinces include both (1) development and
16 characteristics of the current tectonic regime of the region that is most
17 likely reflected in the neotectonics (Post Miocene or about 5 in the
18 Quaternary period (approximately the last 2 million years and younger geologic
19 history) and (2) the pattern and level of historical seismicity. Those
20 characteristics of geologic structure, tectonic history, present and past
21 stress regimes, and seismicity that distinguish the various seismic sources
22 tectonic provinces and the particular areas within those sources provinces
23 where historical earthquakes have occurred should be described. Alternative
24 regional tectonic models derived from available literature sources, including
25 previous SARs and NRC staff Safety Evaluation Reports (SERs), should be
26 discussed. The model that best conforms to the observed data is accepted. In
27 addition, in those areas where there are capable faults tectonic sources, the
28 results of the additional investigative requirements described in 10 CFR Part
29 100, Appendix A, Section IV(a)(8) (Ref. 1), SER Section 2.5.1 must be
30 presented. The discussion should be augmented by a regional-scale map showing
31 the tectonic provinces seismic sources, earthquake epicenters, locations of
32 geologic structures and other features that characterize the seismic sources.
33 , and the locations of any capable faults.

34 2.5.2.3 Correlation of Earthquake Activity with Seismic Sources

35 Geologic Structure or Tectonic Provinces. In meeting To meet the requirements

1 proposed in of Reference 1, acceptance of this subsection is based on the
2 development of the relationship between the history of earthquake activity and
3 ~~the geologic structures or tectonic provinces~~ seismic sources of a region.
4 For the CEUS sites, when the SSE is determined using LLNL or EPRI PSHA
5 methodology and Regulatory Guide 1.165, in meeting the requirements of
6 Reference 1, this subsection is acceptable when adequate information is
7 provided to demonstrate: (1) that a thorough investigation has been conducted
8 to assess the seismicity and identify seismic sources that could be
9 significant in estimating the seismic hazard of the region if they exist; and
10 (2) that existing sources (in the PSHA) are consistent with the results of
11 site and regional investigations, or the sources have been updated in
12 accordance with the Appendix E of Regulatory Guide 1.165.

13 For sites where LLNL or EPRI methods are not used, and it is necessary to
14 identify and characterize seismic sources in meeting the requirements of
15 Reference 1, this subsection is acceptable when adequate information is
16 provided to demonstrate that all seismic sources that are significant in
17 determining the earthquake potential of the region are identified, or that an
18 adequate investigation has been carried out to provide reasonable assurance
19 that there are no unidentified significant seismic sources.

20 The applicant's presentation is accepted when the earthquakes discussed in
21 Subsection 2.5.2.1 of the SAR are shown to be associated with either geologic
22 ~~structure or tectonic province~~ seismic sources. Whenever an earthquake
23 hypocenter or concentration of earthquake hypocenters can be reasonably
24 correlated with geologic structures, the rationale for the association should
25 be developed considering the characteristics of the geologic structure
26 (including geologic and geophysical data, seismicity, and the tectonic
27 history) and the regional tectonic model. The discussion should include
28 identification of the methods used to locate the earthquake hypocenters, an
29 estimation of their accuracy, and a detailed account that compares and
30 contrasts the geologic structure involved in the earthquake activity with
31 other areas within the ~~tectonic province~~ seismotectonic province. Particular
32 attention should be given to determining the capability, recency and level of
33 activity of faults with which instrumentally located earthquake hypocenters
34 are may be associated. ~~The presentation should be augmented by regional maps,~~
35 ~~all of the same scale, showing the tectonic provinces, the earthquake~~

1 ~~epicenters, and the locations of geologic structures and measurements used to~~
2 ~~define provinces. Acceptance of the proposed tectonic provinces seismic~~
3 ~~sources (those identified by the investigations) is based on the staff's~~
4 ~~independent review of the geologic and seismic information presented by the~~
5 ~~applicant and available in the scientific literature.~~

6 2.5.2.4 Maximum Earthquake Potential Probabilistic Seismic Hazard
7 Analysis (PSHA) and Controlling Earthquakes (CE). In meeting the requirements
8 of Reference 1, this subsection is accepted when the vibratory ground motion
9 due to the maximum credible earthquake associated with each geologic structure
10 or the maximum historic earthquake associated with each tectonic province has
11 been assessed and when the earthquake that would produce the maximum vibratory
12 ground motion at the site has been determined. The maximum credible
13 earthquake is the largest earthquake that can reasonably be expected to occur
14 on a geologic structure in the current tectonic regime. Geologic or
15 seismological evidence may warrant a maximum earthquake larger than the
16 maximum historic earthquake. Earthquakes associated with each geologic
17 structure or tectonic province must be identified. Where an earthquake is
18 associated with a geologic structure, the maximum credible earthquake that
19 could occur on that structure should be evaluated, taking into account
20 significant factors, for example, the type of the faulting, fault length,
21 fault slip rate, rupture length, rupture area, moment, and earthquake history
22 (e.g., Refs. 19 through 22).

23 In order to determine the maximum credible earthquake that could occur on
24 those faults that are shown or assumed to be capable, the staff accepts
25 conservative values based on historic experience in the region and specific
26 considerations of the earthquake history and geologic history of movement on
27 the faults. Where the earthquakes are associated with a tectonic province,
28 the largest historic earthquake within the province should be identified.
29 Isoseismal maps should also be presented for the most significant earthquakes.
30 The ground motion at the site should be evaluated assuming appropriate seismic
31 energy transmission effects and assuming that the maximum earthquake
32 associated with each geologic structure or with each tectonic province occurs
33 at the point of closest approach of the structure or province to the site.
34 (Further description is provided in Subsection 2.5.2.6.)

~~The earthquake(s) that would produce the most severe vibratory ground motion at the site should be defined. If different potential earthquakes would produce the most severe ground motion in different frequency bands, these earthquakes should be specified. The description of the potential earthquake(s) is to include the maximum intensity or magnitude and the distance from the assumed location of the potential earthquake(s) to the site. The staff independently evaluates the site ground motion produced by the largest earthquake associated with each geologic structure or tectonic province.~~

~~Acceptance of the description of the potential that would produce the largest ground motion at the site is based on the staff's independent analysis.~~

For the CEUS sites relying on LLNL or EPRI methods and databases, the staff will review the applicant's probabilistic seismic hazard analysis, including the underlying assumptions and how the results of the site investigations and findings of Sections 2.5.2.2 and 2.5.2.3 are used to update the existing sources in the probabilistic seismic hazard analysis, how they are used to develop additional sources, or how they are used to develop a new data base.

The staff will review the controlling earthquakes and associated ground motions at the site derived from the applicant's probabilistic hazard analysis to be sure that they are either consistent with the controlling earthquakes/ground motions used in licensing of (a) other licensed facilities at the site, (b) nearby plants, or (c) plants licensed in similar seismogenic regions, or the reasons they are not consistent are understood. For the CEUS, a comparison of the PSHA results can be made with the information included as Table 1, which is a very general representation based on technical information developed over the past two decades of licensing nuclear power plants.

The applicant's probabilistic analysis, including the derivation of controlling earthquakes, is considered acceptable if it follows the procedures proposed in DG-1032 Regulatory Guide 1.165 and its Appendix C (Ref. 9). The incorporation of results of site investigations into the probabilistic analysis is considered acceptable if it follows the procedure outlined in Appendix E of DG-1032 Regulatory Guide 1.165 and is consistent with the review findings of Sections 2.5.2.2 and 2.5.2.3.

For the sites not using LLNL or EPRI methods and databases, the staff will review the applicant's PSHA or other methods used to derive controlling earthquakes. The staff will particularly review the approaches used to address uncertainties. The staff will perform an independent evaluation of the earthquake potential associated with each seismic source that could affect the site. The staff will evaluate the applicant's controlling earthquakes based on historical and paleo-seismicity. In this evaluation, the controlling earthquakes for each source are at least as large as the maximum historic earthquake associated with the source.

TABLE 1
Controlling Earthquakes

SEISMIC SOURCE	LLNL Magnitude	LLNL Distance (KM)	EPRI Magnitude	EPRI Distance (KM)
Northern New England	5.6 - 5.7	15	5.7 - 5.8	18
Piedmont - New England	5.5 - 5.7	14	5.7	19
Southern Valley and Ridge	5.6 - 5.7	14	5.4 - 5.7	18, 19
Atlantic Coastal Plain	5.5 - 5.6	15-16	5.4 - 5.5	19, 21
Gulf Coast	5.3	16-18	5.3	23, 39
Central Stable Region	5.4 - 5.5	15-20	5.3 - 5.5	19, 20 21, 30
Charleston	7.5 Ms	Site- Specific		
New Madrid	8.5 Ms	Site- Specific		

2.5.2.5 Seismic Wave Transmission Characteristics of the Site.

In the PSHA procedure described in DG-1032 Regulatory Guide 1.165 (Ref. 9), the controlling earthquakes are determined for actual or hypothetical rock conditions. The site amplification studies are performed in a distinct separate step as a part of the determination of the SSE. In this section the

1 applicant's site amplification studies are reviewed in conjunction with the
2 geotechnical and structural engineering reviews.

3 ~~In meeting the requirements of Reference 1, this subsection is accepted when~~
4 ~~To be acceptable,~~ the seismic wave transmission characteristics (amplification
5 or deamplification) of the materials overlying bedrock at the site are
6 described as a function of the significant frequencies (Ref. 12). The
7 following material properties should be determined for each stratum under the
8 site: thickness, seismic compressional and shear wave velocities, bulk
9 densities, soil index properties and classification, shear modulus and damping
10 variations with strain level, and water table elevation and its variation
11 (Ref. 13). In each case, methods used to determine the properties should be
12 described in Subsection 2.5.4 of the SAR and cross-referenced in this
13 subsection. ~~For the maximum earthquake determined in Subsection 2.5.2.4, the~~
14 ~~free field ground motion (including significant frequencies) must be~~
15 ~~determined, and an analysis should be performed to determine the site effects~~
16 ~~on different seismic wave types in the significant frequency bands. If~~
17 ~~appropriate, the analysis should consider the effects of site conditions and~~
18 ~~material property variations upon wave propagation and frequency content.~~

19 ~~The free field ground motion (also referred to as control motion) should be~~
20 ~~defined to be on a ground surface and should be based on data obtained in the~~
21 ~~free field. Two cases are identified, depending on the soil characteristics~~
22 ~~at the site and subject to availability of appropriate recorded ground motion~~
23 ~~data. When data are available, for example, for relatively uniform sites of~~
24 ~~soil or rock with smooth variation of properties with depth, the control point~~
25 ~~(location at which the control motion is applied) should be specified on the~~
26 ~~soil surface at the top of the finished grade. The free field ground motion~~
27 ~~or control motion should be consistent with the properties of the soil~~
28 ~~profile. For sites composed of one or more thin soil layers overlying a~~
29 ~~competent material, or in case of insufficient recorded ground motion data,~~
30 ~~the control point is specified on an outcrop or a hypothetical outcrop at a~~
31 ~~location on the top of the competent material. The control motion specified~~
32 ~~should be consistent with the properties of the competent material.~~

33 Where vertically propagating shear waves may produce the maximum ground
34 motion, a one-dimensional equivalent-linear analysis (e.g., Ref. 23 or 24 14

1 or 15) or nonlinear analysis (e.g., Refs. 25, 26, and 27 16, 17, or 18) may be
2 appropriate and is reviewed in conjunction with geotechnical and structural
3 engineering. Where horizontally propagating shear waves, compressional waves,
4 or surface waves may produce the maximum ground motion, other methods of
5 analysis (e.g., Refs. 28 and 29 19 and 20) may be more appropriate. However,
6 since some of the variables are not well defined and the techniques are still
7 in the developmental stage, no generally agreed-upon procedures can be
8 promulgated at this time. Hence, the staff must use discretion in reviewing
9 any method of analysis. To ensure appropriateness, site response
10 characteristics determined from analytical procedures should be compared with
11 historical and instrumental earthquake data, when available.

12 2.5.2.6 Safe Shutdown Earthquake Ground Motion. ~~In meeting the~~
13 ~~requirements of Reference 1, this subsection is accepted when the vibratory~~
14 ~~ground motion specified for the SSE is described in terms of the free field~~
15 ~~response spectrum and is at least as conservative as that which would result~~
16 ~~at the site from the maximum earthquake determined in Subsection 2.5.2.4,~~
17 ~~considering the site transmission effects determined in Subsection 2.5.2.5.~~
18 ~~If several different maximum potential earthquakes produce the largest ground~~
19 ~~motions in different frequency bands (as noted in Subsection 2.5.2.4), the~~
20 ~~vibratory ground motion specified for the SSE must be as conservative in each~~
21 ~~frequency band as that for each earthquake.~~

22 In this subsection, the staff review the applicant's procedure to determine
23 the SSE, including the procedure used to derive spectral shape from the
24 controlling earthquakes as described in Reference 9.

25 As a part of the review to judge the adequacy of the SSE proposed by the
26 applicant, the staff performs an independent evaluation of ground motion
27 estimates, as required. ~~In these independent estimates, the staff may~~
28 ~~consider effects on ground motion from the controlling earthquakes discussed~~
29 ~~in Subsection 2.5.2.4 by assuming the controlling earthquake for each seismic~~
30 ~~source (geological structures or seismotectonic provinces) to be at its~~
31 ~~closest approach to the site.~~

32 The staff reviews the free field response spectra of engineering significance
33 (at appropriate damping values). ~~Ground motion may vary for different founda-~~

tion conditions at the site. When the site effects are significant, this review is made in conjunction with the review of the design response spectra in Section 2.7.1 to ensure consistency with the free field motion. The staff normally evaluates response spectra on a case-by-case basis. The staff considers compliance with the following conditions acceptable in the evaluation of the SSE. In all these procedures, the proposed free field response spectra shall be considered acceptable if they equal or exceed the estimated 84th percentile ground motion spectra from the maximum or controlling earthquake described in Subsection 2.5.2.4.

The following procedures (in descending order of preference) should be used to develop the site-specific spectral shapes for controlling earthquakes. The staff will also use these procedures are also used to make its independent ground motion estimates when the probabilistic methods are not used. In the following procedures, 84th percentile response spectra are used for both spectral shape as well as ground motion estimates.

The following steps summarize the staff review of the SSE.

1. Both horizontal and vertical component site-specific response spectra should be developed statistically from response spectra of recorded strong motion records that are selected to have similar source, propagation path, and recording site properties as the controlling earthquakes. It must be ensured that the recorded motions represent free-field conditions and are free of or corrected for any soil-structure interaction effects that may be present because of locations and/or housing of recording instruments. Important source properties include magnitude and, if possible, fault type, and tectonic environment. Propagation path properties include distance, depth, and attenuation. Relevant site properties include shear velocity profile and other factors that affect the amplitude of waves at different frequencies. A sufficiently large number of site-specific time-histories or response spectra or both should be used to obtain an adequately broadband spectrum to encompass the uncertainties in these parameters. An 84th percentile response spectrum for the records should be presented for each damping value of interest, and compared to the SSE free field and design response spectrum (e.g., Refs. 30, 31, 32, and 33).

21, 22, 23, and 24). The staff considers direct estimates of spectral ordinates preferable to scaling of spectra to peak accelerations. ~~In the Eastern United States, relatively little information is available on magnitudes for the larger historic earthquakes; hence, it may be appropriate to rely on intensity observations (descriptions of earthquake effects) to estimate magnitudes of historic events (e.g., refs. 34 and 35).~~ If the data for site-specific response spectra were not obtained under geologic conditions similar to those at the site, corrections for site effects should be included in the development of the site-specific spectra.

2. Where a large enough ensemble of strong-motion records is not available, response spectra may be approximated by scaling that ensemble of strong-motion data that represent the best estimate of source, propagation path, and site properties (e.g., Ref. 36 25). Sensitivity studies should show the effects of scaling.

3. If strong-motion records are not available, site-specific peak ground acceleration, velocity, and displacement (if necessary) should be determined for appropriate magnitude, distance, and foundation conditions. Then response spectra may be determined by scaling the acceleration, velocity, and displacement values by appropriate amplification factors (e.g., Ref. 37 26). ~~Where only estimates of peak ground acceleration are available, it is acceptable to select a peak acceleration and use this peak acceleration as the high frequency asymptote to standardized response spectra such as described in Regulatory Guide 1.50 (Ref. 6) for both the horizontal and vertical components of motion with the appropriate amplification factors.~~ For each controlling earthquake, the peak ground motions should be determined using current relations between acceleration, velocity, and, if necessary, displacement, earthquake size (magnitude or intensity), and source distance. Peak ground motion should be determined from state-of-the-art relationships. Relationships between magnitude and ground motion are found, for example, in References 12 and 27. ~~Due to~~ Because of the limited data for high intensities greater than Modified Mercalli Intensity (MMI) VIII, the available empirical relationships between intensity and peak ground motion may not be suitable for determining the appropriate reference

1 acceleration for seismic design.

2 4. Response Spectra developed by theoretical-empirical modeling of ground
3 motion may be used to supplement site-specific spectra if the input
4 parameters and the appropriateness of the model are thoroughly
5 documented (e.g., Refs. 19, 44, 45, and 46 12, 27, and 28). Modeling is
6 particularly useful for sites near capable faults tectonic seismic
7 sources or for deeper structures that may experience ground motion that
8 is different in terms of frequency content and wave type from ground
9 motion caused by more distant earthquakes.

10 ~~5. Probabilistic estimates of seismic hazard should be calculated (e.g.,~~
11 ~~Refs. 41 and 47) and the underlying assumptions and associated~~
12 ~~uncertainties should be documented to assist in the staff's overall~~
13 ~~deterministic approach. The probabilistic studies should highlight~~
14 ~~which seismic sources are significant to the site. Uniform hazard~~
15 ~~spectra (spectra that have a uniform probability of exceedance over the~~
16 ~~frequency range of interest) showing uncertainty should be calculated~~
17 ~~for 0.01, 0.001, and 0.0001 annual probabilities of exceedance at the~~
18 ~~site. The probability of exceeding the SSE response spectra should also~~
19 ~~be estimated and comparison of results made with other probabilistic~~
20 ~~studies.~~

21 The SSE ground motion response spectra proposed by the applicant are
22 considered acceptable if they meet Regulatory Position 4 and Appendix F of
23 Reference 9. If the independent staff estimates of ground motion are
24 significantly different than those proposed by the applicant, the staff will
25 review the reasons for differences and resolve them as appropriate.

26
27 The time duration and number of cycles of strong ground motion are required
28 for analysis of site foundation liquefaction potential and for design of many
29 plant components. The adequacy of the time history for structural analysis is
30 reviewed under SRP Section 3.7.1. The time history is reviewed in this SRP
31 section to confirm that it is compatible with the seismological and geological
32 conditions in the site vicinity and with the accepted SSE model. At present,
33 models for deterministically computing the time history of strong ground
34 motion from a given source-site configuration may be are limited. It is

1 ~~therefore acceptable to use an ensemble of ground motion time histories from~~
2 ~~earthquakes with similar size, site source characteristics, and spectral~~
3 ~~characteristics or results of a statistical analysis of such an ensemble.~~
4 Total duration of the motion is acceptable when it is as conservative as
5 values determined using current studies such as References 48, 49, 50, and 51
6 29, 30, 31, and 32.

7 For evaluation of the liquefaction potential at the site, the time duration
8 and number of cycles of strong ground motion are more critical parameters and
9 require additional consideration. If the controlling earthquakes for the site
10 have magnitudes of less than 6, the time history selected for the evaluation
11 of liquefaction potential must have duration and number of strong motion
12 cycles corresponding to at least an event of magnitude 6.

13 ~~2.5.2. Operating Basis Earthquake.~~ In meeting the requirements of
14 Reference 1, this subsection is acceptable when the vibratory ground motion
15 for the OBE is described and the response spectrum (at appropriate damping
16 values) at the site specified. Probability calculations (e.g., Refs. 41, 47,
17 and 52) should be used to estimate the probability of exceeding the OBE during
18 the
19 operating life of the plant. The maximum vibratory ground motion of the OBE
20 should be at least one half the maximum vibratory ground motion of the SSE
21 unless a lower OBE can be justified on the basis of probability calculations.
22 It has been staff practice to accept the OBE if the return period is on the
23 order of hundreds of years (e.g., Ref. 31).

24 III. REVIEW PROCEDURES

25 Upon receiving the applicant's SAR, an acceptance review is conducted to
26 determine compliance with the ~~proposed~~ investigative requirements of 10 CFR
27 Part 100, Section 100.23 Appendix A (Ref. 1). The reviewer also identifies
28 any site-specific problems, the resolution of which could result in extended
29 delays in completing the review.

30 After SAR acceptance and docketing, ~~those areas are identified where the~~
31 ~~reviewer identifies areas that need additional information is required to~~

1 support the review of the applicant's seismic design ~~determine the earthquake~~
2 ~~hazard~~. These are transmitted to the applicant as ~~draft~~ requests for
3 additional information.

4 A site visit may be conducted, during which the reviewer inspects the geologic
5 conditions at the site and the region around the site as shown in outcrops,
6 borings, geophysical data, trenches, and those geologic conditions exposed
7 during construction ~~if the review is for an operating license~~. The reviewer
8 also discusses the questions with the applicant and his consultants so that it
9 is clearly understood what additional information is required by the staff to
10 continue the review. ~~Following the site visit, a revised set of requests for~~
11 ~~additional information, including any additional questions that may have been~~
12 ~~developed during the site visit, is formally transmitted to the applicant.~~

13 The reviewer evaluates the applicant's response to the questions, prepares
14 requests for ~~any~~ additional clarifying information, and formulates positions
15 that may agree or disagree with those of the applicant. These are formally
16 transmitted to the applicant.

17 The Safety Analysis Report and amendments responding to the requests for
18 additional information are reviewed to determine that the information
19 presented by the applicant is acceptable according to the criteria described
20 in Section II (Acceptance Criteria) above. Based on information supplied by
21 the applicant ~~and information~~ obtained from site visits, ~~or from staff~~
22 consultants, or literature sources, the reviewer independently identifies ~~and~~
23 ~~evaluates~~ the relevant ~~seismotectonic provinces~~ seismic sources, including
24 ~~their~~ ~~evaluates the capability of faults in the region,~~ and determines the
25 earthquake potential for each province and each capable fault or tectonic
26 structure using procedures noted in Section II (Acceptance Criteria) above.
27 The reviewer evaluates the vibratory ground motion that the potential
28 earthquakes ~~controlling earthquakes~~ could produce at the site and ~~defines~~
29 ~~compares that ground motion to the SSE used for design.~~ safe shutdown
30 earthquake and operating basis earthquake.

31 IV. EVALUATION FINDINGS

1 ~~if the evaluation by the staff,~~ On completion of the review of the geologic
2 and seismologic aspects of the plant site, ~~if the evaluation by the staff~~
3 confirms that the applicant has met the requirements or guidance of applicable
4 portions of References 1 through 6 ~~and 9~~, the conclusion in the SER states
5 that the information provided and investigations performed support the
6 applicant's conclusions regarding the seismic ~~integrity~~ ~~characterization~~ of
7 the subject nuclear power plant site. In addition to the conclusion, this
8 section of the SER includes ~~an evaluation of~~ (1) ~~definitions of tectonic~~
9 ~~provinces seismic sources~~, (2) ~~evaluations of the capability of geologic~~
10 ~~structures in the region~~, (3) ~~determinations of the SSE earthquake(s) and~~
11 ~~controlling earthquakes and associated free-field response spectra based on~~
12 ~~evaluation of the potential earthquakes~~, (4) the SSE, and (5) ~~4~~ the time
13 history of strong ground motion, ~~and (5) determinations of the OBE free-field~~
14 ~~response spectra~~. Staff reservations about any significant deficiency
15 presented in the applicant's SAR are stated in sufficient detail to make clear
16 the precise nature of the concern. ~~In addition, the staff will also note the~~
17 ~~results of its independent analyses, if performed, and discuss how these~~
18 ~~results were used in the safety evaluation~~. The above evaluations
19 ~~determinations or redeterminations~~ are made by the staff during both the con-
20 struction permit (CP), ~~and~~ operating license (OL), combined license (COL), or
21 early site permit phases of review as appropriate.

22 OL and combined license applications are reviewed for any new information
23 developed subsequent to the CP ~~safety evaluation report~~ SER ~~or the early site~~
24 ~~evaluation~~. The review will also determine whether the CP recommendations
25 made following the CP or early site review have been implemented.

26 A typical combined license or OL-stage summary finding for this section of the
27 SER follows:

28 In our review of the seismologic aspects of the plant site, we have
29 considered pertinent information gathered since our initial seismologic
30 review ~~which that~~ was made in conjunction with ~~an early site review or~~
31 the issuance of the Construction Permit. This new information includes
32 data gained from both site and near-site investigations as well as from
33 a review of recently published literature.

1 As a result of our recent review of the seismologic information, we have
2 determined that our earlier conclusion regarding the safety of the plant
3 from a seismological standpoint remains valid. These conclusions can be
4 summarized as follows:

5 1. Seismologic information provided by the applicant and required by
6 ~~Appendix A~~ Section 100.23 ~~to~~ of 10 CFR Part 100 provides an
7 adequate basis to establish that no ~~capable faults~~ seismic sources
8 exist in the plant site area ~~which that~~ would cause earthquakes to
9 be centered there.

10 2. The response spectrum proposed for the safe shutdown earthquake is
11 the appropriate free-field response spectrum in conformance with
12 ~~Appendix A~~ Section 100.23 of ~~to~~ 10 CFR Part 100.

13 The new information reviewed for the proposed nuclear power plant is
14 discussed in Safety Evaluation Report Section 2.5.2.

15 The staff concludes that the site is acceptable from a seismologic
16 standpoint and meets the requirements of (1) 10 CFR Part 50, Appendix A
17 (General Design Criterion 2), (2) 10 CFR Part 100, and (3) 10 CFR Part
18 100, ~~Appendix A~~ Section 100.23. This conclusion is based on the
19 following:

20 1. The applicant has met the requirements of:

21 a. 10 CFR Part 50, Appendix A, General Design Criterion 2 with
22 respect to protection against natural phenomena such as
23 faulting.

24 b. 10 CFR Part 100, Reactor Site Criteria, with respect to the
25 identification of geologic and seismic information used in
26 determining the suitability of the site.

27 c. 10 CFR Part 100, ~~Appendix A (Seismic and Geologic Siting~~
28 ~~Criteria for Nuclear Power Plants)~~ Section 100.23 (Ref. 1)
29 with respect to obtaining the geologic and seismic

1 information necessary to determine (1) site suitability and
2 (2) the appropriate design of the plant. Guidance for
3 complying with this regulation is contained in Regulatory
4 Guide 1.132, "Site Investigations for Foundations of Nuclear
5 Power Plants" (Ref. 4); ~~Draft Regulatory Guide DG-1032~~
6 ~~1.165, "Identification and Characterization of Seismic~~
7 ~~Sources and Safe Shutdown Earthquake Ground Motion" (Ref.~~
8 ~~9); and Regulatory Guide 4.7, "General Site Suitability~~
9 ~~Criteria for Nuclear Power Stations" (Proposed Revision 2)~~
10 ~~(Ref. 5); and Regulatory Guide 1.60, "Design Response~~
11 ~~Spectra for Seismic Design of Nuclear Power Plants" (Ref.~~
12 ~~6).~~

13 V. IMPLEMENTATION

14 The following is intended to provide guidance to applicants and licensees
15 regarding the NRC staff's plans for using this SRP section.

16 Except in those cases in which the applicant or licensee proposes an
17 acceptable alternative method for complying with specific portions of the
18 Commission's regulations, the methods described herein will be used by the
19 staff in its evaluation of conformance with Commission regulations.

20 Implementation schedules for conformance to parts of the method discussed
21 herein are contained in the referenced regulatory guides and NUREGs (Refs. 4
22 through 8 9).

23 The provisions of this SRP section apply to reviews of construction permits
24 (CP), operating licenses (OL), ~~early site permits, preliminary design approval~~
25 ~~(PDA), final design approval (FDA),~~ and combined license (CP/OL) applications
26 docketed ~~pursuant to the proposed Section 100.23 to 10 CFR Part 100, after the~~
27 ~~date of issuance of this SRP section.~~

28 VI. REFERENCES

- 29 1. 10 CFR Part 100, ~~Proposed Section 100.23, "Geologic and Seismic~~
30 ~~Siting Factors," Appendix A, "Seismic and Geologic Siting Criteria~~

- 1 ~~for Nuclear Power Plants."~~
- 2 2. 10 CFR Part 50, Appendix A, General Design Criterion 2, "Design
3 Bases for Protection Against Natural Phenomena."
- 4 3. 10 CFR Part 100, "Reactor Site Criteria."
- 5 4. USNRC, "Site Investigations for Foundations of Nuclear Power
6 Plants," Regulatory Guide 1.132.
- 7 5. USNRC, "General Site Suitability Criteria for Nuclear Power
8 Stations," Regulatory Guide 4.7 (~~Proposed Revision 2, DG-4004~~
9 Date).
- 10 6. USNRC, "Design Response Spectra for Seismic Design of Nuclear
11 Power Plants," Regulatory Guide 1.60.
- 12 7. US NRC, "Standard Format and Content of Safety Analysis Reports
13 for Nuclear Power Plants (LWR Edition)," Regulatory Guide 1.70.
- 14 8. USNRC, "Report of Siting Policy Task Force," NUREG-0625, August
15 1979.
- 16 9. ~~-----~~ N. L. Barstow et al., "An Approach to Seismic Zonation for Siting
17 Nuclear Electric Power Generating Facilities in the Eastern United
18 States," prepared by Roundout Associates, Inc., for the USNRC,
19 NUREG/CR 1577, May 1981.
- 20 9. USNRC, "Identification and Characterization of Seismic Sources and
21 Determination of Safe Shutdown Earthquake Ground Motion," Draft
22 Regulatory Guide ~~CG-10321~~.165.
- 23 10. ~~-----~~ C. W. Stever et al., "Seismicity Maps of the States of the U.S.,"
24 Geological Survey Miscellaneous Field Studies Maps, 1973-1981.
- 25 10 34. R. L. Street and F. T. Turcotte, "A Study of Northeastern North
26 American Spectral Moments, Magnitudes, and Intensities," Bulletin

1 of the Seismological Society of America, Vol. 67, pp. 599-614,
2 1977.

3 ~~11. "Earthquake History of the United States," Publication 41-1,
4 National Oceanic and Atmospheric Administration, U.S. Department
5 of Commerce, 1982.~~

6 **11 35.** O. W. Nuttli, G. A. Bollinger, and D. W. Griffiths, "On the
7 Relation Between Modified Mercalli Intensity and Body-Wave
8 Magnitude," Bulletin of the Seismological Society of America, Vol.
9 69, pp. 893-909, 1979.

10 ~~12. T. R. Topozada, C. R. Real, S. P. Bezore, and D. L. Parke,
11 "Compilation of Pre 1900 California Earthquake History, Annual
12 Technical Report Fiscal Year 1978-79, Open File Report 79-6-SAC
13 (Abridged Version)," California Division of Mines and Geology,
14 1979.~~

15 **12.** Electric Power Research Institute, "Guidelines for Determining
16 Design Basis Ground Motions," EPRI Report TR-102293, Vols. 1-4,
17 May 1993.

18 ~~13. P. W. Basham, D. H. Weichert, and M. J. Berry, "Regional
19 Assessment of Seismic Risk in Eastern Canada," Bulletin of the
20 Seismological Society of America, Vol. 65, pp. 1567-1602, 1979.~~

21 **13.** USNRC, "Laboratory Investigations of Soils for Engineering
22 Analysis and Design of Nuclear Power Plants," Regulatory Guide
23 1.138.

24 ~~14. P. B. King, "The Tectonics of North America - A Discussion to
25 Accompany the Tectonic Map of North America, Scale 1:5,000,000,"
26 Professional Paper 628, U.S. Geological Survey, 1969.~~

27 **14 23.** P. B. Schnabel, J. Lysmer, and H. B. Seed, "SHAKE-A Computer
28 Program for Earthquake Response Analysis of Horizontally Layered
29 Sites," Report No. EERC 72-12, Earthquake Engineering Research

Center, University of California, Berkeley, 1972.

~~15. A. J. Eardley, "Tectonic Divisions of North America," Bulletin of the American Association of Petroleum Geologists, Vol. 35, 1951.~~

15 24. E. Faccioli and J. Ramirez, "Earthquake Response of Nonlinear Hysteretic Soil Systems," International Journal of Earthquake Engineering and Structural Dynamics, Vol. 4, pp. 261-276, 1976.

~~16. J. B. Bradley and J. F. Devine, "Seismotectonic Map of the Eastern United States," Publication MF 620, U.S. Geological Survey, 1974.~~

16 25. I. V. Constantopoulos, "Amplification Studies for a Nonlinear Hysteretic Soil Model," Report No. R73-46, Department of Civil Engineering, Massachusetts Institute of Technology, 1973.

~~17. M. L. Sbar and L. R. Sykes, "Contemporary Compressive Stress and Seismicity in Eastern North America: An Example of Intra Plate Tectonics," Bulletin of the Geological Society of America, Vol. 84, 1973.~~

17 26. V. L. Streeter, E. B. Wylie, and F. E. Richart, "Soil Motion Computation by Characteristics Methods," Proceedings of the American Society of Civil Engineers, Journal of the Geotechnical Engineering Division, Vol. 100, pp. 247-263, 1974.

~~18. R. B. Smith and M. L. Sbar, "Contemporary Tectonics and Seismicity of the Western United States with Emphasis on the Intermountain Seismic Belt," Bulletin of the Geological Society of America, Vol. 85, 1974.~~

18 27. W. B. Joyner and A. T. F. Chen, "Calculations of Nonlinear Ground Response in Earthquakes," Bulletin of the Seismological Society of America, Vol. 65, pp. 1315-1336, 1975.

~~19. USNRC, "Safety Evaluation Report (Geology and Seismology) Related~~

1 ~~to the Operation of San Onofre Nuclear Generating Station, Units 2~~
2 ~~and 3," NUREG-0712, February 1981.~~

3 19 28. T. Udaka, J. Lysmer, and H. B. Seed, "Dynamic Response of
4 Horizontally Layered Systems Subjected to Traveling Seismic
5 Waves," Proceedings of the Second U.S. National Conference on
6 Earthquake Engineering, 1979.

7 20. ~~D. B. Slemmons, "Determination of Design Earthquake Magnitudes for~~
8 ~~Microzonation," Proceedings of the Third International Earthquake~~
9 ~~Microzonation Conference, 1982.~~

10 20 29. I. A. Drake, "Love and Raleigh Waves in an Irregular Soil Layer,"
11 Bulletin of the Seismological Society of America, Vol. 70, pp.
12 571-582, 1980.

13 21. ~~M. G. Bonilla, R. K. Mark, and J. J. Lienkaemper, "Statistical~~
14 ~~Relations Among Earthquake Magnitude, Surface Rupture, Length and~~
15 ~~Surface Fault Displacement," Bulletin of the Seismological Society~~
16 ~~of America, Vol. 74, pp. 2379-2411, 1984.~~

17 21 30. USNRC, "Development of Site-Specific Response Spectra," NUREG/CR-
18 4861, March 1987.

19 22. ~~T. C. Hanks and H. Kanamori, "A Moment Magnitude Scale," Journal~~
20 ~~of Geophysical Research, Vol. 84, pp. 2348-2350, 1979.~~

21 22 31. USNRC, "Safety Evaluation Report Related to Operation of the
22 Sequoyah Nuclear Plant, Units 1 and 2," NUREG-0011, 1979.

23 23 32. USNRC, "Safety Evaluation Report Related to the Operation of
24 Midland Plant, Units 1 and 2," NUREG-0713, May 1982.

25 24 33. USNRC, "Safety Evaluation Report Related to the Operation of
26 Enrico Fermi Atomic Power Plant, Unit No. 2," NUREG-0847, July
27 1981.

- 1 25 36. T. H. Heaton, F. Tajima, and A. W. Mori, "Estimating Ground
2 Motions Using Recorded Accelerograms," Surveys in Geophysics, Vol.
3 8, pp. 25-83, 1986.
- 4 26 37. USNRC, "Development of Criteria for Seismic Review of Selected
5 Nuclear Power Plants," NUREG/CR-0098, June 1978.
- 6 27. J.B. Savy et al., "Eastern Seismic Hazard Characterization
7 Update," Lawrence Livermore National Laboratory, UCRL-ID-115111,
8 June 1993.
- 9 28. USNRC, "Safety Evaluation Report Related to the Operation of
10 Diablo Canyon Nuclear Power Plant, Units 1 and 2," NUREG-0675,
11 Supplement No. 34, June 1991.
- 12 29 48. R. Dobry, I. M. Idriss, and E. Ng, "Duration Characteristics of
13 Horizontal Components of Strong-Motion Earthquake Records,"
14 Bulletin of the Seismological Society America, Vol. 68, pp. 1487-
15 1520, 1978.
- 16 30 49. B. A. Bolt, "Duration of Strong Ground Motion," Proceedings of the
17 Fifth World Conference on Earthquake Engineering, 1973.
- 18 31 50. W. W. Hays, "Procedures for Estimating Earthquake Ground Motions,"
19 Professional Paper 1114, U.S. Geological Survey, 1980.
- 20 32 51. H. Bolton Seed et al., "Representation of Irregular Stress Time
21 Histories by Equivalent Uniform Stress Series in Liquefaction
22 Analysis," National Science Foundation, Report EERC 75-29, October
23 1975.
- 24 ~~38. W. B. Joyner and O. M. Boore, "Peak Horizontal Acceleration and~~
25 ~~Velocity from Strong Motion Records Including Records from the~~
26 ~~1979 Imperial Valley, California Earthquake," Bulletin of the~~
27 ~~Seismological Society of America, Vol. 71, 2011-2038, 1981.~~
- 28 39. ~~K. W. Campbell, "Near Source Attenuation of Peak Horizontal~~

1 ~~Acceleration," Bulletin of the Seismological Society of America,~~
2 ~~Vol. 71, pp. 2039-2070, 1981.~~

3 40. ~~_____ O. W. Nuttli and R. B. Herrmann, "Consequences of Earthquakes in~~
4 ~~the Mississippi Valley," Preprint 81-519, American Society of~~
5 ~~Civil Engineers Meeting, 1981.~~

6 41. ~~_____ D. L. Bernreuter et al., "Seismic Hazard Characterization of 69~~
7 ~~Nuclear Plant Sites East of the Rocky Mountains," NUREG/CR 5250,~~
8 ~~January 1989.~~

9 42. ~~_____ M. D. Trifunac and A. G. Brady, "On the Correlation of Seismic~~
10 ~~Intensity Scales with Peaks of Recorded Strong Ground Motion,"~~
11 ~~Bulletin of the Seismological Society of America, Vol. 65, 1975.~~

12 43. ~~_____ J. R. Murphy and L. J. O'Brien, "Analysis of a Worldwide Strong~~
13 ~~Motion Data Sample To Develop an Improved Correlation Between Peak~~
14 ~~Acceleration, Seismic Intensity and Other Physical Parameters,"~~
15 ~~prepared by Computer Sciences Corporation for the USNRC, NUREG-~~
16 ~~0402, January 1978.~~

17 44. ~~_____ USNRC, "Safety Evaluation Report Related to Operation of Virgil C.~~
18 ~~Summer Nuclear Station, Unit No. 1," NUREG 0717, 1981.~~

19 45. ~~_____ USNRC, "State of the Art Study Concerning Near Field Earthquake~~
20 ~~Ground Motion," NUREG/CR 1340, August 1980.~~

21 46. ~~_____ H. J. Swanger et al., "State of the Art Study Concerning Near-~~
22 ~~Field Earthquake Ground Motion," NUREG/CR 1978, March 1981.~~

23 47. ~~_____ "Seismic Hazard Methodology for the Central and Eastern United~~
24 ~~States," Electric Power Research Institute, Report NP 4726, 1986.~~

25 52. ~~_____ S. T. Algermissen et al., "Probabilistic Estimate of Maximum~~
26 ~~Acceleration and Velocity in Rock in the Contiguous United~~
27 ~~States," U. S. Geological Survey Open File Report 82-1033, 1982.~~

ATTACHMENT 13

SRP SECTION 2.5.3, REVISION 3

(SURFACE FAULTING)

三三三

1 U.S. NUCLEAR REGULATORY COMMISSION

2 STANDARD REVIEW PLAN 2.5.3

3 SURFACE FAULTING

4 PROPOSED REVISION 3

February 1995

Contact: A.J. Murphy

(301) 415-6010

5 REVIEW RESPONSIBILITIES

6 Primary - Civil Engineering and Geosciences Branch (ECGB)

7 Secondary - None

8 1. AREAS OF REVIEW

9 ECGB reviews information in the applicant's Safety Analysis Report (SAR) or
10 Early Site Evaluation Report (ESR) that addresses the existence of a potential
11 for surface deformation that could affect the site. The technical
12 information presented in this section of the SAR or ESR results largely from
13 detailed surface and subsurface geological, seismological, and geophysical
14 investigations performed in progressively greater detail within each of the
15 areas described by radii of the site subregion ([40 km or (25 mi), from the
16 site]), site vicinity ([8 km or (5 mi)], and in the site area ([within 1 km
17 or (0.6 mi)] of around the site]). The following specific subjects are
18 addressed: the geological, seismological, and geophysical
19 investigations structural and stratigraphic conditions of the site subregion,
20 site vicinity, and site area (subsection 2.5.3.1), geological evidence, or
21 absence of evidence for surface deformation any evidence of fault offset,
22 including near surface folding, uplift, or subsidence that reflects faulting

This standard review plan is being issued in draft form to involve the public in the early stages of its development. It has not received complete staff review and does not represent an official NRC staff position.

Public comments are being solicited on this draft standard review plan, which is part of a group of drafts of regulatory guides and standard review plan sections on the proposed amendments to the regulations on siting nuclear power plants (50 FR 52255). Comments should be accompanied by appropriate supporting data. Written comments may be submitted to the Rule Review and Directives Branch, DEIRS, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Copies of comments received may be examined at the NRC Public Document Room, 2120 L Street NW, Washington, DC. Comments will be most helpful if received by May 12, 1995.

Requests for single copies of this standard review plan (which may be reproduced) will be filled while supplies last. Requests should be in writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Office of Administration, Distribution and Mail Services Section.

1 ~~at depth, or evidence demonstrating the absence of faulting within these areas~~
2 ~~(subsection 2.5.3.2), correlation of earthquakes with capable tectonic sources~~
3 ~~earthquakes associated with tectonic structures within these areas (subsection~~
4 ~~2.5.3.3), areas of most recent deformations determination of the age of most~~
5 ~~recent movement on faults or other near surface tectonic deformation~~
6 ~~(subsection 2.5.3.4), relationship of tectonic structures in the site area to~~
7 ~~regional tectonic structures determination of structural relationships of site~~
8 ~~area faults to regional faults (subsection 2.5.3.5), identification and~~
9 ~~characterization of capable tectonic sources (subsection 2.5.3.6),~~
10 ~~designations of zones of Quaternary deformation in the site region that require~~
11 ~~detailed fault investigations (subsection 2.5.3.7), and results of studies in~~
12 ~~zones requiring the potential for surface tectonic deformation at the site~~
13 ~~identified during the detailed Quaternary faulting investigations (subsection~~
14 ~~2.5.3.8).~~

15 References 1 through 87 (regulations and regulatory guides) provide guidance
16 to the ECGB reviewers in evaluating potential nuclear power plant sites. The
17 principal regulation that will be used by ECGB in the future to determine the
18 scope and adequacy of the submitted geological, seismological, and geophysical
19 information is Proposed Section 100.23, "Geologic and Seismic Siting
20 Factors," 10 CFR Part 100 (Ref. 2). Specific guidance for implementing this
21 proposed regulation can be found in Draft Regulatory Guide DG-1032 1.165,
22 "Identification and Characterization of Seismic Sources and Determination of
23 Safe Shutdown Earthquake Ground Motion" (Ref. 3). Guidance regarding the
24 geotechnical engineering aspects is found in Regulatory Guide 1.132, "Site
25 Investigations for Foundations of Nuclear Power Plants" (Ref. 4). Additional
26 guidance is provided to the ECGB reviewers through information published in
27 the scientific literature. As the state of the art regarding the geosciences

~~This standard review plan is being issued in draft form to involve the public in the early stages of its development. It has not received complete staff review and does not represent an official NRC staff position.~~

~~Public comments are being solicited on this draft standard review plan, which is part of a group of drafts of regulatory guides and standard review plan sections on meeting proposed amendments to the regulations on siting nuclear power plants (50 FR 52155). Comments should be accompanied by appropriate supporting data. Written comments may be submitted to the Rules Review and Directive Branch, DFIRS, Office of Administration, U.S. Nuclear Regulatory Commission, Washington, DC 20555. Copies of comments received may be examined at the NRC Public Document Room, 2120 L Street NW, Washington, DC. Comments will be most helpful if received by May 12, 1995.~~

~~Requests for single copies of this standard review plan (which may be reproduced) will be filled while supplies last. Requests should be in writing to the U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Office of Administration, Distribution and Mail Services Section.~~

1 is advancing rapidly, it is the responsibility of the reviewers to stay
2 abreast of changes by reviewing the current scientific literature on a regular
3 basis and attending professional meetings.

4 II. ACCEPTANCE CRITERIA

5 ECGB acceptance criteria are based on meeting the requirements of the
6 following regulations:

- 7 1. Appendix A, "General Design Criteria for Nuclear Power Plants", General
8 Design Criterion 2 - "Design Bases for Protection Against Natural
9 Phenomena, 10 CFR Part 50." This criterion requires that safety-related
10 portions of the structures, systems, and components important to safety
11 be designed to withstand the effects of earthquakes, tsunamis, and
12 seiches without loss of capability to perform their safety functions
13 (Ref. 1).
- 14 2. 10 CFR Part 100 ~~Proposed~~ Section 100.23, "Geologic and Seismic Siting
15 Factors." These ~~proposed~~ requirements describe the general nature of
16 the geological, seismological, and geophysical data necessary to
17 determine the site suitability (Ref. 2).

18 The following regulatory guides provide information, recommendations,
19 and guidance and in general describe bases acceptable to the staff for
20 implementing the requirements of General Design Criterion 2, Part 100,
21 and ~~Proposed~~ Section 100.23 of Part 100.

- 22 a. Draft Regulatory Guide DG-1032, 165, "Identification and
23 Characterization of Seismic Sources and Determination of Safe
24 Shutdown Earthquake Ground Motion." This ~~draft~~ guide and its
25 appendices ~~are being developed to~~ describe geological,
26 seismological, and geophysical investigations to determine site
27 suitability: methods to identify and characterize potential
28 seismic sources; acceptable methods to conduct probability
29 seismic hazard analyses; and methods to determine the Safe
30 Shutdown Earthquake ground motion (SSE) (Ref. 3).

1 b. Regulatory Guide 1.132, "Site Investigations for Foundations of
2 Nuclear Power Plants." This guide describes programs of site
3 investigations related to geotechnical aspects that would normally
4 meet the needs for evaluating the safety of the site from the
5 standpoint of the performance of foundations and earthworks under
6 anticipated loading conditions, including earthquakes. It
7 provides general guidance and recommendations for developing site-
8 specific investigation programs as well as specific guidance for
9 conducting subsurface investigations such as borings, sampling,
10 and geophysical explorations (Ref. 4).

11 c. Regulatory Guide 4.7, "General Site Suitability Criteria for
12 Nuclear Power Stations." This guide discusses the major site
13 characteristics related to public health and safety that the NRC
14 staff considers in determining the suitability of sites for
15 nuclear power stations (Ref. 5, also see Ref. 6).

16 The data and analyses presented in the SAR or ESR are acceptable if, as a
17 minimum, they describe and document the information proposed to be required by
18 Reference 2, show that the methods described in Reference 3 or comparable
19 methods were employed, and conform to the format suggested in Reference 7.
20 References 8 and 9 have been used by the staff in past licensing activities as
21 relevant guides to judge whether or not all of the current pertinent
22 references have been consulted. References 10 through 17 are also used by the
23 staff.

24 Specific criteria necessary to meet the relevant requirements of the
25 Commission regulations identified above are described in the following
26 paragraphs. If the information that satisfies these criteria is presented in
27 other sections of Chapter 2.5, it may be cross-referenced and not repeated in
28 this section.

29 Subsection 2.5.3.1 Geological, Seismological, and Geophysical Investigations.

30 In meeting the requirements of References 1 and 2 and the positions of
31 References 3 and 4, this subsection is considered acceptable if the
32 discussions of the Quaternary tectonics, structural geology, stratigraphy,
33 geochronological methods used, paleoseismology, and geological history of the

1 site are complete, compare well with studies conducted by others in the same
2 area, and are supported by detailed investigations performed by the applicant.
3 For coastal and inland sites near large bodies of water, similar detailed
4 investigations are to be conducted, and the information is to be provided in
5 the SAR or ESR regarding offshore geology and seismology as well as onshore.
6 In some instances it may be possible to identify an onshore projection of the
7 offshore fault or fold of concern, or a tectonic structure that is analogous
8 to it at an onshore location. It is acceptable to the staff, along with other
9 investigations of the specific feature, to investigate the more remote,
10 accessible exposure to learn the nature of the potentially hazardous offshore
11 or buried fault and apply it to the local structure (Refs. 3 and 18). Site
12 and regional maps (Ref. 3) and profiles constructed at scales adequate to
13 illustrate clearly the surficial and bedrock geology, structural geology,
14 topography, and the relationship of the safety-related foundations of the
15 nuclear power plant to these features should have been included in the SAR or
16 ESR.

17 Subsection 2.5.3.2 Geological Evidence, or Absence of Evidence for Surface
18 Deformation. In meeting the requirements of References 1, 2, and 3, this
19 subsection is acceptable if sufficient surface and subsurface information is
20 provided and supported by detailed investigations, either to confirm the
21 absence of surface tectonic deformation (i.e., faulting) or, if present, to
22 demonstrate the age of its most recent displacement and ages of previous
23 displacements. If tectonic deformation is present in the site vicinity, it
24 must be defined as to geometry, amount and sense of displacement, recurrence
25 rate, and age of latest movement. In addition to geological evidence that may
26 indicate faulting, linear features interpreted from topographic maps, low and
27 high altitude aerial photographs, satellite imagery, and other imagery should
28 be documented and investigated. In order to expedite the review process, an
29 identification list, index, and duplicates of the remote sensing data used in
30 the linear features study should be provided to and reviewed by the staff.
31 Evidence for the absence of tectonic deformation is obtained by the applicant
32 conducting site surface (geological reconnaissance and mapping, etc.) and
33 subsurface investigations (geophysical, core borings, trenching and logging,
34 etc.) in such detail and areal extent to ensure that undetected offsets or
35 other deformations are not likely to exist.

1 In the Central and Eastern United States (CEUS), except for the New Madrid
2 Seismic Zone, the Meers fault, ~~and possibly the Harlan County fault of~~
3 ~~Nebraska~~ and the Cheraw fault of the Colorado piedmont, earthquake generating
4 faults either do not extend to ground surface or there is insufficient
5 overlying soil or rock of known or of a sufficient age to date those that do.

6 In tectonically active regions such as the Western United States (WUS), many
7 capable tectonic sources are exposed at ground surface and can be
8 characterized as to their seismic potential. However, in these regions many
9 other capable tectonic sources are buried (blind faults), and may be expressed
10 at the surface or near surface by folding, uplift, or subsidence (including
11 faults related to subduction zones). Investigations in these regions should
12 take these phenomena into account. The nature of geological, seismological,
13 and geophysical investigations will vary in detail and extent according to the
14 geological complexity of the specific site.

15 Subsection 2.5.3.3 Correlation of Earthquakes with Capable Tectonic Sources.

16 In meeting the requirements of References 1 and 2, this subsection is
17 acceptable if all historically reported earthquakes within 40 km (25 mi) of
18 the site are evaluated with respect to hypocenter accuracy and source origin,
19 and if all capable tectonic sources that could, based on their orientations,
20 extend to ~~that trend~~ within 8 km (5 mi) of the site are evaluated with
21 respect to their potential for causing surface deformation. In conjunction
22 with these discussions, a plot of the earthquake epicenters superimposed on a
23 map showing the local capable tectonic sources should have been ~~shown~~
24 provided.

25 Subsection 2.5.3.4 Ages of Most Recent Deformations. In meeting the
26 requirements of References 1 and 2, this subsection is acceptable when every
27 fault, or fold associated with a blind fault, any part of which is within 8 km
28 (5 mi) of the site, is investigated in sufficient detail using geological and
29 geophysical techniques of sufficient sensitivity to demonstrate, or allow
30 relatively accurate estimates of the age of most recent movement and identify
31 geological evidence for previous displacements if it exists (Ref. 3). An
32 evaluation of the sensitivity and resolution of the exploratory techniques
33 used should be given.

1 Subsection 2.5.3.5 Relationship of Tectonic Structures in the Site Area to
2 Regional Tectonic Structures. In meeting the requirements of References 1 and
3 2, this subsection is satisfied by a discussion of the structural and
4 genetic relationship between site area faulting or other tectonic deformation
5 and the regional tectonic framework. In regions of active tectonism it may be
6 necessary to conduct detailed geological and geophysical investigations to
7 assess possible structural relationships of site area faults to regional
8 faults known to be seismically active.

9 Subsection 2.5.3.6 Characterization of Capable Tectonic Sources. In meeting
10 the requirements of References 1 and 2, this subsection is acceptable when it
11 has been demonstrated that the investigative techniques used have sufficient
12 sensitivity to identify all potential capable tectonic sources such as faults,
13 or folds associated with blind faults, within 8 km (5 mi) of the site and when
14 the geometry, length, sense of movement, amount of total offset, amount of
15 offset per event, age of latest and any previous displacements, and limits of
16 the zone are given for each capable tectonic source. Investigations are to
17 extend at least 8 km (5 mi) beyond all plant sites boundaries, including those
18 adjacent to large bodies of water such as oceans, rivers, and lakes.

19 Subsection 2.5.3.7 Designation of Zones of Quaternary Deformation in the Site
20 Region. In meeting the requirements of Reference 2, this subsection is judged
21 acceptable if the zone designated by the applicant requiring detailed
22 faulting investigation is of sufficient length and breadth to include all
23 Quaternary deformation significant to the site (Ref. 3).

24 Subsection 2.5.3.8 Potential for Surface Tectonic Deformation at the Site.
25 In meeting the requirements of References 1 and 2, this subsection must be
26 presented by the applicant if the aforementioned investigations reveal that
27 surface displacement must be taken into account. If there is a potential for
28 tectonically induced surface displacement at the site, it would be prudent of
29 the applicant to abandon the site. No commercial nuclear power plant has been
30 constructed on a known capable fault (capable tectonic source) and it is an
31 open question as to whether it is feasible to design for tectonic surface or
32 near-surface displacement with confidence that the integrity of the safety-
33 related features of the plant would remain intact should displacement occur.
34 It is, therefore, staff policy to recommend relocation of plant sites found to

1 be located on capable faults (capable tectonic sources) as determined by the
2 detailed faulting investigations. If in the future it becomes feasible to
3 design for surface faulting, it will be necessary to present the design basis
4 for surface faulting and supporting data in considerable detail.

5 III. REVIEW PROCEDURES

6 The three-phase review procedure described in Section 2.5.1 should be applied
7 to assessing the potential for surface faulting. The first phase consists of
8 an acceptance review to determine the completeness of the ESR or SAR by
9 comparing the contents with the Criteria described in Part II, Acceptance
10 Criteria, of this section. The second phase consists of a detailed review of
11 the applicant's data and other independently derived information, which may
12 result in requests for additional information. The third phase is a final
13 review to resolve open issues and prepare a Safety Evaluation Report (SER).

14 The staff review procedure involves an evaluation to determine that the
15 applicant has performed adequate investigations to fulfill the general
16 requirements of Reference 2. Acceptable methods are described in Reference 3.
17 Consultants or advisors may be called on to assist the staff in reviewing this
18 section of the ESR or SAR on a case-by-case basis. On request, the advisor or
19 consultant provides expertise in numerous earth science disciplines and
20 occasionally is able to provide first-hand knowledge of the site. A
21 literature search is conducted independently by the staff concerning the
22 regional and local geology and seismology. The staff also utilizes the
23 expertise of the U.S. Geological Survey and other Federal agencies, State
24 geological surveys, universities, and private industry to obtain additional,
25 up-to-date geosciences information regarding Quaternary tectonics at the site.

26 ~~The Proposed~~ Section 100.23 of 10 CFR Part 100 ~~would~~ requires that applicants
27 investigate the potential for near-surface deformation, both tectonically
28 induced and that induced by other phenomena (Ref. 2). The steps that
29 applicants may follow in determining the presence and extent of deformation
30 and whether near-surface deformation (if present) represents a hazard are in
31 ~~Draft~~ Regulatory Guide ~~RG-1032~~ 1.165, Appendix D (Ref 3). The site vicinity
32 ~~{[8 km -{5 mi}] from the site}~~ and site area ~~{[1 km -{0.6 mi}] from the site}~~
33 must be investigated by a combination of exploratory methods that should

1 include borings, trenching, seismic profiling and other geophysical methods,
2 geological mapping, and seismic instrumentation. The results of these
3 explorations are cross-compared with other available data and evaluated by the
4 staff. An important part of the staff's review effort is to compare the new
5 information derived from these investigations or other sources with the
6 specific data base used in the probabilistic seismic hazard analysis (PSHA)
7 for the site (Ref. 3).

8 It has been the policy of the staff to encourage applicants to avoid areas
9 that have a possibility for near-surface tectonic deformation. As the
10 question of whether or not a surface tectonic deformation condition exists is
11 so critical in determining site suitability, this consideration is usually
12 addressed very early in the review. The exceptions are cases in which a
13 previously unknown fault is revealed in excavations during construction or is
14 discovered during the course of other investigations in the area. The staff
15 should require early on in the review that it be notified by the applicant
16 when the excavations for Seismic Category I structures are available for NRC
17 inspection and when the detailed geological maps to be used by the staff while
18 examining the excavations will be available. In addition, the staff should
19 require that it be contacted immediately if a fault, not previously identified
20 in the SAR or ESR, is found within 8 km (5 mi) of the plant.

21 10 CFR Part 52 describes an alternative licensing approach that may be used in
22 lieu of the previous current two-step procedure of requiring applicants to
23 obtain a Construction Permit, followed several years later after the plant
24 design bases have been approved by the staff, by application for an Operating
25 License. ~~has been provided with an alternative method, a combined licensing~~
26 ~~procedure, by 10 CFR Part 52.~~ This procedure, called combined licensing,
27 could create a problem for the staff in that the Safety Evaluation Report
28 (SER) will already have been written and the applicant ~~could~~ will already have
29 a license before excavations are started, ~~and~~ Therefore, faults discovered
30 for the first time in the excavations that fall in the category described in
31 the previous paragraph will not have been evaluated by the staff before time
32 for the preparation of the Safety Evaluation Report (SER)
33 . Therefore, ~~It is imperative that~~ To alleviate this potential problem,
34 Section 2.5.3 of the SER ~~be~~ there must be a commitment in the site specific
35 portion of the SAR for a facility to: (1) notify the staff immediately if

1 previously unknown geologic features that could represent a hazard to the
2 plant are encountered in the excavation; (2) geologically map all excavations
3 for Category 1 structures, as a minimum; and (3) notify the staff when the
4 excavations are open for examination and evaluation. ~~staff has carefully~~
5 ~~examined the walls and floors of the excavations for the plant and determined~~
6 ~~that there are no previously unidentified potentially hazardous faults or~~
7 ~~other features beneath the proposed plant. When the staff is satisfied~~
8 ~~regarding this issue, the SER should be finalized as soon as possible. made~~
9 ~~conditional on the demonstrated absence of previously unknown potentially~~
10 ~~hazardous faults beneath the plant as determined by careful examination of the~~
11 ~~excavations by the staff as described in the previous paragraph.~~

12 When faults are identified in the site vicinity or site area, it must be
13 demonstrated that the faults do not have the potential to generate earthquakes
14 ~~at the site (seismogenic source) or cause near-surface ground displacement~~
15 (capable tectonic source) at the site. This is accomplished by determining
16 the ages of the latest displacement on the faults, preferably by stratigraphic
17 methods, that is, identifying strata or a stratum of datable soil or rock
18 overlying the fault that is undeformed by the fault. Other methods include
19 correlating the last faulting event with regional tectonic activity of known
20 ancient age, geomorphic evidence of age, and determining the relationship
21 between the time of the fault rupture event and the ages of marine or fluvial
22 terraces. Geochronological methods are discussed in References 3 and 17.
23 Draft Regulatory Guide DG-1032 1.165 (Ref. 3) provides brief descriptions and
24 a list of references of state-of-the-art methods and their applications, which
25 can be used to estimate the geochronological history of geological materials
26 associated with faults or other features.

27 In cases such as are described in the last previous paragraph, the staff will
28 carry out limited site observations and investigations of its own such as
29 examinations of excavations. In some cases, the staff may select samples from
30 shear zones or other materials for subsequent dating and analysis. In past
31 investigations activities Applicants usually applicants have often excavated
32 trenches in the areas where major facilities are to be located for in situ
33 testing and to reduce the chance for surprises when the construction
34 excavations are made.

1 Subsection 2.5.3.1 Geological, Seismological, and Geophysical Investigations.

2 This subsection is evaluated by conducting an independent literature search
3 and cross-comparing the results with the information submitted in the SAR or
4 ESR. The comparison should show that the conclusions presented by the
5 applicant are based on sound data, are consistent with the published reports
6 of experts who have worked in the area, and are consistent with the
7 conclusions of the staff and its advisors or consultants. If the applicant's
8 conclusions and assumptions conflict with the literature, and the staff
9 disagrees with the applicant's analysis and assumptions, additional
10 investigative results to support those conclusions must be submitted to the
11 staff for review.

12 Subsection 2.5.3.2 Geological Evidence, or Absence of Evidence for Surface
13 Deformation. This subsection is evaluated by first determining through a

14 literature search and comparison with the applicant's data, that all known
15 evidences of tectonic deformation such as fault offset identified in the
16 literature have been considered in the investigation. The results of the
17 applicant's site investigations are studied and cross-compared in detail to
18 see if there is evidence of existing or possible displacements. If such
19 evidence is found, additional investigations such as field mapping,
20 geophysical investigations, borings, or trenching must be carried out to
21 demonstrate that there is no offset or to define the characteristics of the
22 fault if it does exist. It is important to distinguish between tectonically
23 induced near-surface deformation and deformation caused by nontectonic
24 phenomena such as growth faulting, collapse caused by the development of karst
25 terrane, etc. (Ref. 3).

26 Subsection 2.5.3.3 Correlation of Earthquakes with Capable Tectonic Sources

27 This subsection is reviewed in conjunction with the consideration of SRP
28 Section 2.5.2. Historical earthquake data derived from the review of SRP
29 Section 2.5.2 are compared with known local tectonic features and a
30 determination is made as to whether any of these earthquakes can reasonably be
31 associated with the local tectonic structures. This determination includes an
32 evaluation of the hypocentral error estimates of the earthquakes. When
33 available, the earthquake source mechanisms should be evaluated with respect
34 to fault geometry. In addition, applicants and licensees are encouraged to
35 evaluate the relationship of fault parameters to earthquake magnitude. These

parameters may include, but are not limited to, slip rate, recurrence intervals, length, rupture area, and fault type (Ref. 18).

Subsection 2.5.3.4 Ages of Most Recent Deformation This subsection is evaluated to determine whether the geochronological methodologies used by the applicant are based on accepted geological procedures. In some cases unusual or untested age-dating techniques may have been used. When such methods are employed, the staff will require documentation of the technique. The resolution precision of all age dating techniques used in the applicant's analysis should be carefully documented. The staff may require the services of one or more consultants who have expertise in the methods used.

Subsection 2.5.3.5 Relationship of Tectonic Structures in the Site Area to Regional Tectonic Structures This Subsection is evaluated by determining through a literature search that the applicant's evaluation of the regional tectonic framework is consistent with that of recognized experts whose reports appear in the peer reviewed published literature. The conclusions reached by the applicant should be based on sound geological principles and should explain the available geological and geophysical data. When special investigations are made to determine the structural relationship between faults that pass within 8 km (5 mi) of the site and regional faults, the resolution accuracy of the investigative techniques should be given.

Subsection 2.5.3.6 Characterization of Capable Tectonic Sources This subsection is evaluated to determine whether a sufficiently detailed investigation has been made by the applicant to define the specific characteristics of all potential capable tectonic sources any part of which is located within 8 km (5 mi) of the site. The fault structural characteristics that must be defined include length, orientation, geometry, and relationship of the fault or fold to regional structures; the nature, amount, and geological history of displacements along the fault; and the outer limits of the zone established by mapping the extent of Quaternary deformation in all directions. The staff must be satisfied that the investigations cover a large enough area and are in sufficient detail to demonstrate that there is little likelihood of near-surface deformation hazards associated with capable tectonic sources existing undetected near the site.

1 Subsection 2.5.3.7 Designation of Zones of Quaternary Deformation in the Site

2 Region. The zone that ~~needs~~ requires detailed investigations is defined by
3 the area characterized by Quaternary deformation in the site subregion (within
4 a distance of 40 km or 25 miles of the site). The staff reviews the results
5 of the applicant's investigation together with a review of the published
6 literature. The investigative techniques employed by the applicant are
7 evaluated to ascertain that they are consistent with the state of the art. As
8 part of this phase, experts in specific disciplines may be asked to review
9 certain aspects of the investigative program. The results of the
10 investigations are analyzed to determine whether the outer limits of the zone
11 of Quaternary deformation investigation are appropriately conservative.

12 Subsection 2.5.3.8 Potential for Surface Tectonic Deformation of the Site.

13 If the detailed ~~faulting~~ investigations for the proposed commercial nuclear
14 power plant reveal that there is a potential for surface deformation at the
15 site, the staff recommends that an alternative location for the proposed plant
16 be considered. It is not expected that nuclear power plants could be
17 successfully designed for displacement in its foundation at the present time.
18 However, in the future, when it may become feasible to design a
19 commercial nuclear power plant for to accommodate displacements, substantial
20 information would be required to support the design basis for surface ~~faulting~~
21 deformation.

22 While fulfilling the tasks of Subsections 2.5.3.1 through 2.5.3.8, it is
23 important for the staff SAR or ESR reviewer to identify all significant new
24 information, such as a seismic source or a new tectonic model that was not
25 included in the site PSHA, and coordinate that information with the staff PSHA
26 reviewer.

27 IV. EVALUATION FINDINGS

28 If the evaluation by the staff, on completion of the review of the geological
29 and seismological aspects of the plant site, confirms that the applicant has
30 met the requirements of applicable portions of General Design Criterion 2,
31 "Design Bases for Protection Against Natural Phenomena," of Appendix A to 10
32 CFR Part 50; and Proposed 10 CFR Part 100, Section 100.23, "Geologic and
33 Seismic Siting Factors," the conclusion in the SER would state that the

1 investigations performed, and the information and analyses provided, support
2 the applicant's conclusions regarding the geologic and seismic suitability of
3 the subject nuclear power plant site with respect to surface deformation
4 potential. Staff reservations about any significant deficiency, either
5 presented in the applicant's ESR or SAR, and identified by the staff, should
6 be stated in sufficient detail to make clear the precise nature of the
7 concern. The above determinations are made by the staff during the early
8 site, construction permit, operating license, or combined license reviews.

9 The ESR or SAR is also reviewed for any significant new information derived by
10 the site-specific geological, seismological, and geophysical investigations
11 that had not been applied to the tectonic and ground motion models used in the
12 PSHA. Appendix E of ~~Draft~~ Regulatory Guide ~~RG-1032~~ 1.165 (Ref. 3) discusses
13 an acceptable method to address significant new information in the PSHA.

14 A typical finding for this section of the SER follows:

15 In its review of the geological and seismological aspects of the plant
16 site, the staff considered pertinent information gathered during the
17 regional and site-specific geological, seismological, and geophysical
18 investigations. The information includes data gathered from both site
19 and near-site investigations and from an independent review of state-of-
20 the-art, published literature and other sources by the staff.

21 As a result of this review, the staff concludes that the geological,
22 seismological, and geophysical investigations and information provided
23 by the applicant in accordance with ~~the Proposed~~ Section 100.23 of 10
24 CFR Part 100 and ~~Draft~~ Regulatory Guide ~~RG-1032~~ 1.165 provide an
25 adequate basis to establish that no capable tectonic sources exist in
26 the plant site vicinity that would cause surface deformation or localize
27 earthquakes there.

28
29 The information reviewed for the proposed nuclear power plant concerning the
30 potential for near-surface tectonic deformation is summarized in Safety
31 Evaluation Report Section 2.5.3.

1 The staff concludes that the site is suitable from the perspective of tectonic
2 surface deformation and meets the requirements of: (1) 10 CFR Part 50,
3 Appendix A (General Design Criterion 2), and (2) ~~the Proposed~~ Section 100.23
4 of 10 CFR Part 100. This conclusion is based on the following:

5 1. The applicant has met the requirements of:

6 a. 10 CFR Part 50, Appendix A (General Design Criterion 2) with
7 respect to protection against natural phenomena such as faulting.

8 b. ~~The Proposed Section 100.2~~ of 10 CFR Part 100 (Geologic and
9 Seismic Siting Factors) with respect to obtaining the geological
10 and seismological information necessary (1) to determine site
11 suitability, (2) to determine the appropriate design of the plant,
12 and (3) to ascertain that any new information derived from the
13 site-specific investigations does not impact the SSE ground
14 motions derived by a PSHA. In complying with this regulation, the
15 applicant also meets the staff's guidance proposed in Draft
16 Regulatory Guide ~~1032~~ 1.165, "Geologic and Seismic Siting Factors
17 "Identification and Characterization of Seismic Sources and
18 Determination of Safe Shutdown Earthquake Ground Motion";
19 Regulatory Guide 1.132, "Site Investigations for Foundations of
20 Nuclear Power Plants;" and Regulatory Guide 4.7, "General Site
21 Suitability Criteria for Nuclear Power Plants."

22 V. IMPLEMENTATION

23 The following is intended to provide guidance to applicants and licensees
24 regarding the NRC staff's plans for using this SRP section.

25 Except in those cases in which the applicant/licensee proposes an acceptable
26 alternative method for complying with specific portions of the Commission's
27 regulations, the method described herein will be used by the staff in its
28 evaluation of conformance with Commission regulations.

1 Implementation schedules for conformance to parts of the method discussed
2 herein are contained in the referenced regulatory guides (Refs. 4, 5, 6, 7,
3 and 8).

4 The provisions of this SRP section apply to reviews of construction permits
5 (CP), operating licenses (OL), early site permits, and combined license
6 (CP/OL) applications docketed pursuant to the ~~proposed~~ Section 100.23 to
7 10 CFR Part 100.

8 VI. REFERENCES

- 9 1. 10 CFR Part 50, Appendix A, General Design Criterion 2, "Design Bases
10 for Protection Against Natural Phenomena."
- 11 2. CFR Part 100, ~~Proposed~~ Section 100.23, "Geologic and Seismic Siting
12 Factors," Federal Register, Volume 59, page 52255, October 17, 1994
13 (59 FR 52255).
- 14 3. US NRC, "Identification and Characterization of Seismic Sources and
15 Determination of Safe Shutdown Earthquake Ground Motions," ~~Draft~~
16 Regulatory Guide DG-10321.165.
- 17 4. US NRC, "Site Investigations for Foundations of Nuclear Power Plants."
18 Regulatory Guide 1.132.
- 19 5. US NRC, "General Site Suitability Criteria for Nuclear Power Stations."
20 Regulatory Guide 4.7 (~~Proposed Revision 2, DG-4064~~).
- 21 6. US NRC, "Report of Siting Policy Task Force," NUREG-0625, August 1979.
- 22 7. US NRC, "Standard Format and Content of Safety Analysis Reports for
23 Nuclear Power Plants," Regulatory Guide 1.71.
- 24 8. American Petroleum Institute data base, accessible through RECON system,
- 25 9. GeoRef data base, American Geological Institute, Falls Church, Virginia.

- 1 10. R.L. Bates and J.A. Jacksons, editors, "Glossary of Geology," American
2 Geological Institute, Falls Church, Virginia, 1980.
- 3 11. G.V. Cohee (Chairman) et al., "Tectonic Map of the United States," U.S.
4 Geological Survey and American Association of Petroleum Geologists,
5 1962.
- 6 12. RECON/Energy data base, Department of Energy.
- 7 13. State geological maps and accompanying texts.
- 8 14. U.S. Geological Survey 7.5 and 15 minute topographic and geologic
9 quadrangle maps.
- 10 15. Aerial photographs from Federal agencies such as the National
11 Aeronautics and Space Administration, the U.S. Department of
12 Agriculture, the U.S. Geological Survey, and the U.S. Forest Service.
- 13 16. Satellite imagery such as Landsat and Skylab.
- 14 17. P.J. Murphy, J. Briedis, and J. H. Pfeck, "Dating Techniques in Fault
15 Investigations," pp. 153-168, in Geology in the Siting of Nuclear Power
16 Plants, A.W. Hatheway and C.R. McClure, Jr., editors, "Reviews in
17 Engineering Geology," Volume 4, Geological Society of America, 1979.
- 18 18. US NRC, "Safety Evaluation Report Related to the Operation of Diablo
19 Canyon Nuclear Power Plant, Units 1 and 2," NUREG-0675, Supplement No.
20 34, June, 1991.

ATTACHMENT 14

**REGULATORY GUIDE 1.12, REVISION 2
DRAFT WAS DG-1033**

(SEISMIC INSTRUMENTATION)

REGULATORY GUIDE 1.12
(Draft was DG-1033)

NUCLEAR POWER PLANT INSTRUMENTATION FOR EARTHQUAKES

A. INTRODUCTION

In 10 CFR Part 20, "Standards for Protection Against Radiation," licensees are required to make every reasonable effort to maintain radiation exposures as low as is reasonably achievable. Paragraph IV(a)(4) of ~~Proposed~~ Appendix S, "Earthquake Engineering Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," ~~would require~~ that suitable instrumentation ~~must~~ be provided so that the seismic response of nuclear power plant features important to safety can be evaluated promptly ~~after an earthquake~~. Paragraph IV(a)(3) of ~~Proposed~~ Appendix S to 10 CFR Part 50 ~~would require~~ shutdown of the nuclear power plant if vibratory ground motion exceeding that of the operating basis earthquake ground motion (OBE) occurs.¹

This guide ~~is being developed to describe~~ seismic instrumentation ~~that is acceptable to the NRC staff for satisfying the requirements of Part 20 and 50 and the Proposed Appendix S to Part 50.~~

~~Regulatory guides are issued to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the Commission's regulations, techniques used by staff in evaluating specific problems or postulated accidents, and guidance to applicants. Regulatory guides are not substitutes for regulations, and compliance with regulatory guides is not required. Regulatory guides are issued in draft form for public comment to involve the public in the early stages of developing the regulatory positions. Draft regulatory guides have not received complete staff review and do not represent official NRC staff positions.~~

¹Guidance is being developed in Draft Regulatory Guide DG-1034-1.1, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions," ~~on provides~~ criteria for plant shutdown.

1 Any information collection activities mentioned in this ~~draft~~ regulatory
2 guide are contained as requirements in the ~~proposed amendments to~~ 10 CFR
3 Part 50, which provides that ~~would provide~~ the regulatory basis for this
4 guide. The ~~proposed amendments have been submitted to~~ information collection
5 requirements in 10 CFR Part 50 have been approved by the Office of Management
6 and Budget for clearance that may be appropriate under the Paperwork Reduction
7 Act. Such clearance, if obtained, would also apply to any information
8 collection activities mentioned in this guide, Approval No. 3150-0011

9 B. DISCUSSION

10 When an earthquake occurs, it is important to take prompt action to
11 assess the effects of the earthquake at the nuclear power plant. This
12 assessment includes both an evaluation of the seismic instrumentation data and
13 a plant walkdown. Solid-state digital time-history accelerographs installed
14 at appropriate locations will provide time-history data on the seismic
15 response of the free-field, containment structure, and other Seismic Category
16 I structures. The instrumentation should be located so that ~~a comparison and~~
17 ~~evaluation of such the~~ response may be ~~made compared and evaluated~~ with the
18 design basis and so that occupational radiation exposures associated with
19 their location, installation, and maintenance are maintained as low as
20 reasonably achievable (ALARA).

21 Instrumentation is provided in the free-field and at foundation level
22 and at elevation in Seismic Category I structures. Free-field instrumentation
23 data ~~would will~~ be used to compare measured response to the engineering
24 evaluations used to determine the design input motion to the structures and to
25 determine whether the OBE has been exceeded (see ~~Draft Regulatory Guide DG-~~
26 ~~1034-1.166~~). ~~Foundation level instrumentation would provide data on the~~
27 ~~actual seismic input to the containment and other buildings and would quantify~~
28 ~~differences between the vibratory ground motion at the free field and at the~~
29 ~~foundation level.~~ The instruments located at the foundation level and at
30 elevation in the structures measure responses that are the input to the
31 equipment or piping and ~~would will~~ be used in long-term evaluations (see ~~Draft~~
32 ~~Regulatory Guide DG-1035-1.167~~, "Restart of a Nuclear Power Plant Shut Down by
33 a Seismic Event"). ~~Foundation-level instrumentation will provide data on the~~
34 ~~actual seismic input to the containment and other Seismic Category I~~
35 ~~structures and will be used to quantify differences between the vibratory~~

1 ground motion at the free-field and at the foundation level. Instrumentation
2 is not located on equipment, piping, or supports since experience has shown
3 that data obtained at these locations are obscured by vibratory motion
4 associated with normal plant operation.

5 The guidance ~~being developed in Draft Regulatory Guide DG-1034-1.166~~ is
6 based on the assumption that the nuclear power plant has operable seismic
7 instrumentation, including the equipment and software needed to process the
8 data within 4 hours after an earthquake. This is necessary to determine
9 whether plant shut down is required. This determination will be made by
10 comparing the recorded data against OBE exceedance criteria and the results of
11 the plant walkdown inspections that take place within 8 hours of the event.

12 It may not be necessary for identical nuclear power units on a given
13 site to each be provided with seismic instrumentation if essentially the same
14 seismic response at each of the units is expected from a given earthquake.

15 An evaluation of seismic instrumentation noted that instruments have
16 been out of service during plant shutdown and sometimes during plant
17 operation. The instrumentation system should be operable and operated at all
18 times. If the seismic instrumentation or data processing hardware and
19 software necessary to determine whether the OBE has been exceeded is
20 inoperable, the guidelines in Appendix A to ~~Draft Regulatory Guide DG-1034~~
21 ~~1.166~~ would ~~should~~ be used.

22 The characteristics, installation, activation, remote indication, and
23 maintenance of the seismic instrumentation are described in this guide to help
24 ensure (1) that the data provided are comparable with the data used in the
25 design of the nuclear power plant, (2) that exceedance of the OBE can be
26 determined, and (3) that the equipment will perform as required.

27 It is important that all of the significant ground motion associated
28 with an earthquake is recorded. This is accomplished by specifying how long
29 before and after the actuation of the seismic trigger the data should be
30 recorded. Settings for the instrumentations pre-event memory should be
31 correlated with the maximum distance to any potential epicenter that could
32 affect a specific site. The "P" wave may not be recorded at a 3-second
33 setting. Also, when an event occurs at some distance and the trigger
34 threshold limit is not exceeded until 15 or 20 seconds into the event, a part
35 of the record, albeit for a low event, is lost. A 30-second value may be more
36 appropriate and is within the capabilities of current digital time-history
37 accelerographs at no additional cost.

1 The appendix to this guide provides definitions to be used with this
2 guidance.

3 ~~Holders of an operating license or construction permit issued prior to~~
4 ~~the implementation date to be specified in the active guide may voluntarily~~
5 ~~implement the methods to be described in the active guide and the methods~~
6 ~~being developed in Draft Regulatory Guides DG 1034, "Pre Earthquake Planning~~
7 ~~and Immediate Nuclear Power Plant Operator Postearthquake Actions," and DG~~
8 ~~1035, "Restart of a Nuclear Power Plant Shut Down by a Seismic Event."~~

9 C. REGULATORY POSITION

10 The type, locations, operability, characteristics, installation,
11 actuation, remote indication, and maintenance of seismic instrumentation
12 described below are acceptable to the NRC staff for satisfying the require-
13 ments in 10 CFR Part 20, ~~10 CFR 50.65(b)(2)~~, and Paragraph IV(a)(4) of
14 ~~Proposed~~ Appendix S to 10 CFR Part 50 for ensuring the safety of nuclear power
15 plants.

16 1. SEISMIC INSTRUMENTATION TYPE AND LOCATION

17 1.1 Solid-state digital instrumentation that will enable the
18 processing of data at the plant site within 4 hours of the seismic event
19 should be used.

20 1.2 A triaxial time-history accelerograph should be provided at each
21 ~~of the~~ following locations:

- 22 1. Free-field.
- 23 2. Containment foundation.
- 24 3. Two elevations (excluding the foundation) on a structure
25 internal to the containment.
- 26 4. An independent Seismic Category I structure foundation where
27 the response is different from that of the containment
28 structure.

1 5. An elevation (excluding the foundation) on the independent
2 Seismic Category I structures selected in 4 above.

3 6. If seismic isolators are used, instrumentation should be
4 placed on both the rigid and isolated portions of the same
5 or an adjacent structure, as appropriate, at approximately
6 the same elevations.

7 1.3 The specific locations for instrumentation should be determined by
8 the nuclear plant designer to obtain the most pertinent information consistent
9 with maintaining occupational radiation exposures ALARA for the location,
10 installation, and maintenance of seismic instrumentation. In general:

11 1.3.1 The free-field sensors should be located and installed so
12 that they record the motion of the ground surface and that the effects that
13 are associated with certain surface features, buildings, and components will
14 be absent from on the recorded ground motion will be insignificant.

15 1.3.2 The in-structure instrumentation should be placed at
16 locations that have been modeled as mass points in the building dynamic
17 analysis so that the measured motion can be directly compared with the design
18 spectra. The instrumentation should not be located on a secondary structural
19 frame member that is not modeled as a mass point in the building dynamic
20 model.

21 1.3.3 A design review of the location, installation, and
22 maintenance of proposed instrumentation for maintaining exposures ALARA should
23 be performed by the facility in the planning stage in accordance with
24 Regulatory Guide 8.8, "Information Relevant to Ensuring that Occupational
25 Radiation Exposures at Nuclear Power Stations Will Be As Low As Is Reasonably
26 Achievable."

27 1.3.4 Instrumentation should be placed in a location with as low a
28 dose rate as is practical, consistent with other requirements.

1 1.3.5 Instruments should be selected to require minimal
2 maintenance and in-service inspection, as well as minimal time and numbers of
3 personnel to conduct installation and maintenance.

4 2. INSTRUMENTATION AT MULTI-UNIT SITES

5 Instrumentation in addition to that installed for a single unit will not
6 be required if essentially the same seismic response is expected at the other
7 units based on the seismic analysis used in the seismic design of the plant.
8 However, if there are separate control rooms, annunciation should be provided
9 to both control rooms as specified in Regulatory Position 7.1

10 3. SEISMIC INSTRUMENTATION OPERABILITY

11 The seismic instrumentation should operate during all modes of plant
12 operation, including periods of plant shutdown. The maintenance and repair
13 procedures should provide for keeping the maximum number of instruments in
14 service during plant operation and shutdown.

15 4. INSTRUMENTATION CHARACTERISTICS

16 4.1 The design should include provisions for in-service testing. The
17 instruments should be capable of periodic channel checks during normal plant
18 operation.

19 4.2 The instruments should have the capability for in-place functional
20 testing.

21 4.3 Instrumentation that has sensors located in inaccessible areas
22 should contain provisions for data recording in an accessible location, and
23 the instrumentation should provide an external remote alarm to indicate
24 actuation.

25 4.4 ~~After actuation, the~~ The instrumentation should record, at a
26 ~~minimum, the~~ 3 seconds of low-amplitude motion prior to seismic trigger
27 actuation, continue to record the motion during the period in which the
28 earthquake motion exceeds the seismic trigger threshold, and continue to

1 record low-amplitude motion for a minimum of 5 seconds beyond the last
2 exceedance of the seismic trigger threshold.

3 4.5 The instrumentation should be capable of recording 25 minutes of
4 sensed motion.

5 4.6 The battery should be of sufficient capacity to power the
6 instrumentation ~~and to~~ sense and record (see Regulatory Position 4.5) 25
7 minutes of motion, ~~with no battery charger,~~ over a period of not less than the
8 channel check test interval (Regulatory Position 8.2). This can be
9 accomplished by providing enough battery capacity for a minimum of 25 minutes
10 of system operation at any time over a 24-hour period, without recharging, in
11 combination with a battery charger whose line power is connected to an
12 uninterruptable power supply or a line source with an alarm that is checked at
13 least every 24 hours. Other combinations of larger battery capacity and alarm
14 intervals may be used.

15 4.7 Acceleration Sensors

16 4.7.1 The dynamic range should be 1000:1 zero to peak, or greater;
17 for example, 0.001g to 1.0g.

18 4.7.2 The frequency range should be 0.20 Hz to 50 Hz or an
19 equivalent demonstrated to be adequate by computational techniques applied to
20 the resultant accelerogram.

21 4.8 Recorder

22 4.8.1 The sample rate should be at least 200 samples per second in
23 each of the three directions.

24 4.8.2 The bandwidth should be at least from 0.20 Hz to 50 Hz.

25 4.8.3 The dynamic range should be 1000:1 or greater, and the
26 instrumentation should be able to record at least 1.0g ~~0-zero~~ to peak.

1 4.9 Seismic Trigger. The actuating level should be adjustable and
2 within the range of 0.001g to 0.02g.

3 5. INSTRUMENTATION INSTALLATION

4 5.1 The instrumentation should be designed and installed so that the
5 mounting is rigid.

6 5.2 The instrumentation should be oriented so that the horizontal axes
7 are parallel to the orthogonal horizontal axes assumed in the seismic
8 analysis.

9 5.3 Protection against accidental impacts should be provided.

10 6. INSTRUMENTATION ACTUATION

11 6.1 Both vertical and horizontal input vibratory ground motion should
12 actuate the same time-history accelerograph. One or more seismic triggers may
13 be used to accomplish this.

14 6.2 Spurious triggering should be avoided.

15 6.3 The seismic trigger mechanisms of the time-history accelerograph
16 should be set for a threshold ground acceleration of not more than 0.02g.

17 7. REMOTE INDICATION

18 ~~Activation-Triggering~~ of the free-field or any foundation-level time-
19 history accelerograph should be annunciated in the control room. If there is
20 more than one control room at the site, annunciation should be provided to
21 each control room.

22 8. MAINTENANCE

23 8.1 The purpose of the maintenance program is to ensure that the
24 equipment will perform as required. As stated in Regulatory Position 3, the

1 maintenance and repair procedures should provide for keeping the maximum
2 number of instruments in service during plant operation and shutdown.

3 8.2 Systems are to be given channel checks every 2 weeks for the first
4 3 months of service after startup. Failures of devices normally occur during
5 initial operation. After the initial 3-month period and 3 consecutive
6 successful checks, monthly channel checks are sufficient. The monthly channel
7 check is to include checking the batteries. The channel functional test
8 should be performed every 6 months. Channel calibration should be performed
9 during each refueling outage at a minimum.

10 D. IMPLEMENTATION

11 The purpose of this section is to provide guidance to applicants and
12 licensees regarding the NRC staff's plans for using this regulatory guide.

13 ~~This proposed revision has been released to encourage public~~
14 ~~participation in its development.~~ Except in those cases in which the
15 applicant proposes an acceptable alternative method for complying with the
16 specified portions of the Commission's regulations, ~~the method to be described~~
17 ~~in the active this guide reflecting public comments will be used in the~~
18 evaluation of applications for construction permits, operating licenses,
19 combined licenses, or design certification submitted after ~~the implementation~~
20 ~~date to be specified in the active guide~~ EFFECTIVE DATE OF THE FINAL RULE.
21 This guide ~~would~~ will not be used in the evaluation of an application for an
22 operating license submitted after ~~the implementation date to be specified in~~
23 ~~the active guide~~ EFFECTIVE DATE OF THE FINAL RULE if the construction permit
24 was issued prior to that date.

25 Holders of an operating license or construction permit issued prior to
26 EFFECTIVE DATE OF THE FINAL RULE may voluntarily implement the methods
27 described in this guide in combination with the methods in Regulatory Guides
28 1.166, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator
29 Postearthquake Actions," and 1.167, "Restart of a Nuclear Power Plant Shut
30 Down by a Seismic Event." Other implementation strategies, such as a
31 voluntary implementation of portions of the cited regulatory guides, will be
32 evaluated by the NRC staff on a case-by-case basis.

APPENDIX

DEFINITIONS

Acceleration Sensor. An instrument capable of sensing absolute acceleration and transmitting the data to a recorder.

Accessible Instruments. Instruments or sensors whose locations permit ready access during plant operation without violation of applicable safety regulations, such as those of the Occupational Safety and Health Administration (OSHA), or regulations dealing with plant security or radiation protection safety.

Channel Calibration (Primary Calibration). The determination and, if required, adjustment of an instrument, sensor, or system such that it responds within a specific range and accuracy to an acceleration, velocity, or displacement input, as applicable, or responds to an acceptable physical constant.

Channel Check. The qualitative verification of the functional status of the instrument sensor. This check is an "in-situ" test and may be the same as a channel functional test.

Channel Functional Test (Secondary Calibration). The determination without adjustment that an instrument, sensor, or system responds to a known input of such character that it will verify the instrument, sensor, or system is functioning in a manner that can be calibrated.

Containment - See Primary Containment and Secondary Containment.

Nonaccessible Instruments. Instruments or sensors in ~~a location~~ locations that ~~does~~ do not permit ready access during plant operation because of a risk of violating applicable plant operating safety regulations, such as OSHA, or regulations dealing with plant security or radiation protection safety.

Operating Basis Earthquake Ground Motion (OBE). The vibratory ground motion for which those features of the nuclear power plant necessary for continued

1 operation without undue risk to the health and safety of the public will
2 remain functional. The value of the OBE is set by the applicant.

3 Primary Containment. The principal structure of a unit that acts as the
4 barrier, after the fuel cladding and reactor pressure boundary, to control the
5 release of radioactive material. The primary containment includes (1) the
6 containment structure and its access openings, penetrations, and appurte-
7 nances, (2) the valves, pipes, closed systems, and other components used to
8 isolate the containment atmosphere from the environment, and (3) those systems
9 or portions of systems that, by their system functions, extend the containment
10 structure boundary (e.g., the connecting steam and feedwater piping) and
11 provide effective isolation.

12 Recorder. An instrument capable of simultaneously recording the data versus
13 time from an acceleration sensor or sensors.

14 Secondary Containment. The structure surrounding the primary containment that
15 acts as a further barrier to control the release of radioactive material.

16 Seismic Isolator. A device (for instance, laminated elastomer and steel)
17 installed between the structure and its foundation to reduce the acceleration
18 of the isolated structure, as well as the attached equipment and components.

19 Seismic Trigger. A device that starts the time-history accelerograph.

20 Time-History Accelerograph. An instrument capable of sensing and permanently
21 recording the absolute acceleration versus time. The components of the time-
22 history accelerograph (acceleration sensor, recorder, seismic trigger) may be
23 assembled in a self-contained unit or may be separately located.

24 Triaxial. Describes the function of an instrument or group of instruments in
25 three mutually orthogonal directions, one of which is vertical.

1 REGULATORY ANALYSIS

2 A separate regulatory analysis was not prepared for this regulatory
3 guide. The ~~draft~~-regulatory analysis, "~~Proposed~~-Revision of 10 CFR Part 100
4 and 10 CFR Part 50," was prepared for the ~~proposed~~-amendments, and it provides
5 the regulatory basis for this guide and examines the costs and benefits of the
6 rule as implemented by the guide. A copy of the ~~draft~~-regulatory analysis is
7 available for inspection and copying for a fee at the NRC Public Document
8 Room, 2120 L Street NW. (Lower Level), Washington, DC, as ~~Enclosure 2 to~~
9 ~~Secy 94-194~~ LATER.

ATTACHMENT 15

**REGULATORY GUIDE 1.166
DRAFT WAS DG-1034**

(PLANT SHUTDOWN)

1 REGULATORY GUIDE 1.166
2 (Draft was DG-1034)

3 PRE-EARTHQUAKE PLANNING AND IMMEDIATE NUCLEAR POWER
4 PLANT OPERATOR POSTEARTHQUAKE ACTIONS

5 A. INTRODUCTION

6 Paragraph IV(a)(4) of ~~Proposed~~ Appendix S, "Earthquake Engineering
7 Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of
8 Production and Utilization Facilities," ~~would require~~ that suitable instru-
9 mentation¹ be provided so that the seismic response of nuclear power plant
10 features important to safety can be evaluated promptly. Paragraph IV(a)(3) of
11 ~~Proposed~~ Appendix S to 10 CFR Part 50 ~~would require~~ shutdown of the nuclear
12 power plant if vibratory ground motion exceeding that of the operating basis
13 earthquake ground motion (OBE) or significant plant damage occurs. If
14 systems, structures, or components necessary for the safe shutdown of the
15 nuclear power plant ~~would be~~ not be available after occurrence of the OBE,
16 the licensee ~~would be required to~~ must consult with the NRC and must propose a
17 plan for the timely, safe shutdown of the nuclear power plant. ~~Proposed~~
18 ~~Paragraph 50.54(ff) to 10 CFR Part 50 would require licensees~~ Licensees of
19 nuclear power plants that have adopted the earthquake engineering criteria in
20 ~~Proposed~~ Appendix S to 10 CFR Part 50 are required by 10 CFR 50.54(ff) to shut
21 down the plant if the criteria in Paragraph IV(a)(3) of ~~Proposed~~ Appendix S
22 are exceeded.

23 This guide ~~is being developed to~~ provides guidance acceptable to the
24 NRC staff for a timely evaluation after an earthquake of the recorded
25 instrumentation data and for determining whether plant shutdown ~~would be~~ is
26 required by the ~~proposed amendments to~~ 10 CFR Part 50.

27 Regulatory guides ~~are issued to describe and make available to the~~
28 public such information as methods acceptable to the NRC staff for implement-
29 ing specific parts of the Commission's regulations, techniques used by the
30 staff in evaluating specific problems or postulated accidents, and guidance to
31 applicants. Regulatory guides are not substitutes for regulations, and
32 compliance with regulatory guides is not required. Regulatory guides are

33 ¹Guidance is being developed in Draft Regulatory Guide DG-1033, the Third
34 Proposed Revision 2 to Regulatory Guide 1.12, Revision 2, "Nuclear Power Plant
35 Instrumentation for Earthquakes," to describe seismic instrumentation that is
36 acceptable to the NRC staff.

1 ~~issued in draft form for public comment to involve the public in the early~~
2 ~~stages of developing the regulatory positions. Draft regulatory guides have~~
3 ~~not received complete staff review and do not represent official NRC staff~~
4 ~~positions.~~

5 Any information collection activities mentioned in this ~~draft regulatory~~
6 ~~guide are contained as requirements in the proposed amendments to 10 CFR Part~~
7 ~~50 that would provide, which provides the regulatory basis for this guide.~~
8 ~~The proposed amendments have been submitted to information collection~~
9 ~~requirements in 10 CFR Part 50 have been approved by the Office of Management~~
10 ~~and Budget for clearance that may be appropriate under the Paperwork Reduction~~
11 ~~Act. Such clearance, if obtained, would also apply to any information~~
12 ~~collection activities mentioned in this guide, Approval No. 3150-0011.~~

13 B. DISCUSSION

14 When an earthquake occurs, ground motion data are recorded by the
15 seismic instrumentation.² These data are used to make a rapid determination
16 of the degree of severity of the seismic event. The data from the ~~nuclear~~
17 ~~power plant's free-field seismic instrumentation, coupled with information~~
18 ~~obtained from a plant walkdown, are used to make the initial determination of~~
19 ~~whether the plant must be shut down, if it has not already been shut down by~~
20 ~~operational perturbations resulting from the seismic event. If on the basis~~
21 ~~of these initial evaluations (instrumentation data and walkdown) it is~~
22 ~~concluded that the plant shutdown criteria have not been exceeded, it is~~
23 ~~presumed that the plant will not be shut down (or could restart following a~~
24 ~~post-trip review, if it tripped off-line because of the earthquake).~~
25 ~~Guidance is being developed on postshutdown inspections and plant restart; is~~
26 ~~contained in the Draft Regulatory Guide DG-1035, 1.167, "Restart of a Nuclear~~
27 ~~Power Plant Shut Down by a Seismic Event." The Electric Power Research~~
28 ~~Institute has developed guidelines that will enable licensees to quickly~~
29 ~~identify and assess earthquake effects on nuclear power plants. These~~
30 ~~guidelines are in EPRI NP-5930, "A Criterion for Determining Exceedance of the~~
31 ~~Operating Basis Earthquake," July 1988²; EPRI NP-6695, "Guidelines for~~

32 ²EPRI reports may be obtained from the Electric Power Research Institute,
33 ~~Research Reports EPRI Distribution Center, 207 Coggins Dr., P.O. Box 50490~~
34 ~~20205, Palo Alto, CA 94303 Pleasant Hill, CA 94523.~~

1 Nuclear Plant Response to an Earthquake," December 1989²; and EPRI TR-100082,
2 "Standardization of the Cumulative Absolute Velocity," December 1991.²

3 This regulatory guide is based on the assumption that the nuclear power
4 plant has operable seismic instrumentation, including the computer equipment
5 and software required to process the data within 4 hours after an earthquake.
6 This is necessary because the decision to shut down the plant will be made, in
7 part, by comparing the recorded data against OBE exceedance criteria. The
8 decision to shut down the plant is also based on the results of the plant
9 walkdown inspections that take place within 8 hours of the event. If the
10 seismic instrumentation or data processing equipment is inoperable, the
11 guidelines in Appendix A to this guide would be used to determine whether the
12 OBE has been exceeded.

13 Because free-field seismic instrumentation data are used in the plant
14 shutdown determination, it is important to ascertain that the time-history
15 analysis hardware and software were functioning properly. Therefore, the
16 response spectrum and cumulative absolute velocity (CAV) should be calculated
17 using a suitable earthquake time-history or manufacturer's calibration standard
18 after the initial installation and each servicing of the free-field
19 instrumentation. After an earthquake at the plant site, the response spectrum
20 and CAV should be calculated using the time-history or calibration standard
21 that was used during the last servicing (or initial instrumentation
22 installation if no servicing has been performed) and the results compared with
23 the latest data on file at the plant.

24 Because earthquake-induced vibration of the reactor vessel could lead to
25 changes in neutron fluxes, a prompt check of the neutron flux monitoring
26 sensors would provide an indication that the reactor is stable.

27 Shutdown of the nuclear power plant ~~would be~~ is required if the
28 vibratory ground motion experienced exceeds that of the OBE. ~~Two criteria. A~~
29 ~~criterion~~ for determining exceedance of the OBE (based on data recorded in the
30 free-field) ~~are~~ is provided in EPRI NP-5930: a threshold response spectrum
31 ordinate ~~criterion check~~ and a ~~cumulative absolute velocity (CAV) CAV~~
32 ~~criterion check~~. Seismic Category I structures at the a nuclear power plant
33 site may be designed using different ground motion response spectra; for
34 example, one used for the certified standard design and another for site-
35 specific applications. The spectrum ordinate criterion is based on the lowest
36 spectrum used in the design of the Seismic Category I structures. A procedure
37 to standardize the calculation of the CAV is provided in EPRI TR-100082. A

1 spectral velocity threshold has also been recommended by EPRI since some
2 structures have fundamental frequencies below the range specified in EPRI NP-
3 5930. The NRC staff now recommends 1.0 to 2.0 Hz for the range of the
4 spectral velocity limit since some structures have fundamental frequencies
5 below 1.5 Hz. ~~The former range was~~ This is instead of the 1.5 to 2.0 Hz range
6 proposed by EPRI.

7 Since the containment isolation valves may have malfunctioned during an
8 earthquake, inspection of the containment isolation system is necessary to
9 ensure continued containment integrity.

10 The NRC staff does not endorse the philosophy discussed in EPRI NP-6695,
11 Section 4.3.4 (first paragraph, last sentence), pertaining to plant shutdown
12 considerations following an earthquake based on the need for continued power
13 generation in the region. If ~~the~~ licensee determines that plant shutdown is
14 required by the NRC's regulations, but the licensee does not consider it
15 prudent to do so, the licensee would be required to consult with the NRC and
16 propose a plan for the timely, safe shutdown of the nuclear power plant.

17 Appendix B to this guide provides definitions to be used with this
18 guidance.

19 ~~Holders of an operating license or construction permit issued prior to~~
20 ~~the implementation date to be specified in the active guide may voluntarily~~
21 ~~implement the methods to be described in the active guide and the methods~~
22 ~~being developed in Draft Regulatory Guides DG-1033, "Nuclear Power Plant~~
23 ~~Instrumentation for Earthquakes," and DG-1035, "Restart of a Nuclear Power~~
24 ~~Plant Shut Down by a Seismic Event."~~

25 C. REGULATORY POSITION

26 1. BASE-LINE DATA

27 1.1 Information Related to Seismic Instrumentation

28 A file containing information on all the seismic instrumentation should
29 be kept at the plant. The file should include:

30 1. Information on each instrument type such as make, model, and
31 serial number; manufacturers' data sheet; list of special features or options;
32 performance characteristics; examples of typical instrumentation readings and

1 interpretations; operations and maintenance manuals; repair procedures (manu-
2 facturers' recommendations for repairing common problems); and a list of any
3 special requirements, e.g., for maintenance, operational, operation, or
4 installation.

5 2. Plan views and vertical sections showing the location of each
6 seismic instrument and the orientation of the instrument axis with respect to
7 a plant reference axis.

8 3. A complete service history of each seismic instrument. The
9 service history should include information such as dates of servicing,
10 description of completed work, and calibration records and data (where
11 applicable). The documentation and retention of these data should be
12 commensurate with the recordkeeping for other plant equipment.

13 4. A suitable earthquake time-history (e.g., the October 1987
14 Whittier, California, earthquake) or manufacture's calibration standard and
15 the corresponding response spectrum and cumulative absolute velocity (CAV)
16 (see Regulatory Positions 4.1 and 4.2). ~~The response spectrum and CAV should~~
17 ~~be calculated after~~ After the initial installation and each servicing of the
18 free-field instrumentation, the response spectrum and CAV should be calculated
19 and filed (see Regulatory Position 4.3).

20 1.2 Planning for Postearthquake Inspections

21 Section 5.3.1 of EPRI NP-6695, "Guidelines for Nuclear Plant Response to
22 an Earthquake," describes actions that are to be taken before an earthquake,
23 such as, ~~The selection of selecting~~ equipment and structures for inspections
24 and the content of the baseline inspections ~~as described in Sections 5.3.1 and~~
25 ~~5.3.2.1 of EPRI NP-6695, "Guidelines for Nuclear Plant Response to an~~
26 ~~Earthquake,"~~ that are acceptable to the NRC staff for satisfying the
27 ~~proposed~~ requirements in Paragraph IV(a)(3) of ~~Proposed~~ Appendix S to 10 CFR
28 Part 50 for ensuring the safety of nuclear power plants.

29 2. IMMEDIATE POSTEARTHQUAKE ACTIONS ACTIONS IMMEDIATELY AFTER AN EARTHQUAKE

1 The guidelines for ~~actions immediately~~ ~~postearthquake actions immediately~~
2 ~~after an earthquake that are~~ specified in Sections 4.3.1 (with the exception
3 specified below) and 4.3.2 ~~(including Section 5.3.2.1 and items 7 and 8 of~~
4 ~~Table 5-1)~~ of EPRI NP-6695 are acceptable to the NRC staff for satisfying the
5 requirements ~~proposed in~~ Paragraph IV(a)(3) of ~~Proposed~~ Appendix S to 10 CFR
6 Part 50.

7 In Section 4.3.1, a check of the neutron flux monitoring sensors for
8 changes should be added to the specific control room board checks.

9 3. EVALUATION OF GROUND MOTION RECORDS

10 3.1 Data Identification

11 A record collection log should be maintained at the plant, and all data
12 should be identifiable and traceable with respect to:

- 13 1. The date and time of collection,
- 14 2. The make, model, serial number, location, and orientation of the
15 instrument (sensor) from which the record was collected.

16 3.2 Data Collection

17 3.2.1 Only personnel trained in the operation of the instrument should
18 collect the data.

19 3.2.2 The steps for removing and storing records from each seismic
20 instrument should be planned and performed in accordance with established
21 procedures.

22 3.2.3 Extreme caution should be exercised to prevent accidental damage
23 to the recording media and instruments during data collection and subsequent
24 handling.

25 3.2.4 As data are collected and the instrumentation is inspected, notes
26 should be made regarding the condition of the instrument and its installation,

1 for example, instrument flooded, mounting surface tilted, ~~fallen or~~ objects
2 that ~~fell and~~ struck the instrument or the instrument mounting surface.

3 3.2.5 For validation of the collected data, the information described
4 in Regulatory Position 1.1(4) should be ~~added to the record without affecting~~
5 ~~the previously recorded data provided.~~

6 3.2.6 If the instrument's operation appears to have been normal, the
7 instrument should remain in service without readjustment or change that would
8 defeat attempts to obtain postevent calibration.

9 3.3 Record Evaluation

10 Records should be analyzed according to the manufacturer's specifica-
11 tions and the results of the analysis should be evaluated. Any record
12 anomalies, invalid data, and nonpertinent signals should be noted, along with
13 any known causes.

14 4. DETERMINING OBE EXCEEDANCE

15 The evaluation to determine whether the OBE was exceeded should be
16 performed using data obtained from the three components of ~~the~~ free-field
17 ground motion (i.e., two horizontal and one vertical). The evaluation may be
18 performed on uncorrected earthquake records. It was found in a study of
19 uncorrected versus corrected earthquake records (see EPRI NP-5930) that the
20 use of uncorrected records is conservative. The evaluation should consist of
21 a check of the response spectrum, ~~and~~ CAV-limit, and the operability of the
22 instrumentation. This evaluation should take place within 4 hours of the
23 earthquake.

24 4.1 Response Spectrum Check

25 4.1.1

26 The OBE response spectrum check is performed using the lower of:

- 27 1. The spectrum used in the certified standard design, or

- 1 2. A spectrum other than (1) used in the design of any Seismic
2 Category I structure.

3 4.1.2

4 The OBE response spectrum is exceeded if any one of the three components
5 (two horizontal and one vertical) of the 5 percent damped free-field ground
6 motion response spectra is larger than:

- 7 1. The corresponding design response spectral acceleration (OBE
8 spectrum if used, otherwise 1/3 of the safe shutdown earthquake
9 (SSE) spectrum) or 0.2g, whichever is greater, for frequencies
10 between 2 to 10 Hz, or

11 2. The corresponding design response spectral velocity (OBE spectrum
12 if used, otherwise 1/3 of the SSE spectrum) or a spectral velocity
13 of 6 inches per second (15.24 centimeters per second), whichever
14 is greater, for frequencies between 1 and 2 Hz.

15 4.2 Cumulative Absolute Velocity (CAV) Limit Check

16 For each component of the free-field ground motion, the CAV should be
17 calculated as follows: (1) the absolute acceleration (g units) time-history is
18 divided into 1-second intervals, (2) each 1-second interval that has at least
19 1 exceedance of 0.025g is integrated over time, (3) all the integrated values
20 are summed together to arrive at the CAV. The CAV ~~limit check~~ is exceeded if
21 any CAV calculation is greater than 0.16 g-second. Additional information on
22 how to determine the CAV is provided in EPRI TR-100082.

23 4.3 Instrument Operability Check

24 After an earthquake at the plant site, the response spectrum and CAV
25 should be calculated using the same input as that used in the calibration
26 standard (see Regulatory Position 1.1(4)) and the results should be compared
27 with the latest filed data to demonstrate that the time-history analysis
28 hardware and software were functioning properly. The results of this
29 comparison should be reported to the NRC.

4.4 Inoperable Instrumentation or Data Processing Hardware or Software

If the response spectrum and the CAV (Regulatory Positions 4.1 and 4.2) can not be obtained because the seismic instrumentation is inoperable, data from the instrumentation are destroyed, or the data processing hardware or software is inoperable, the criteria in Appendix A to this guide should be used to determine whether the OBE has been exceeded.

5. CRITERIA FOR PLANT SHUTDOWN

If the OBE is exceeded or significant plant damage occurs, the plant must be shut down unless a plan for the timely, safe shutdown of the nuclear power plant has been proposed by the licensee and accepted by the NRC staff.

5.1 OBE Exceedance

If the response spectrum check and the CAV ~~limit-check~~ (performed or calculated in accordance with Regulatory Positions 4.1 and 4.2) were exceeded, the OBE was exceeded and plant shutdown is required. If either ~~limit-check~~ does not exceed the criterion, the earthquake motion did not exceed the OBE. If only one ~~limit-check~~ can be ~~checked-performed~~, the other ~~limit-check~~ is assumed to be exceeded; if ~~neither check can be performed~~, see Regulatory Position 4.4. The determination of whether or not the OBE has been exceeded should be performed even if the plant automatically trips off-line as a result of the earthquake.

5.2 Damage

The plant should be shut down if the walkdown inspections performed in accordance with Regulatory Position 2 discover damage. This evaluation should take place within 8 hours of the earthquake occurrence.

5.3 Continued Operation

If the OBE was not exceeded and the walkdown inspection indicates no damage to the nuclear power plant, shutdown of the plant is not required. The

1 plant may continue to operate (or ~~may~~ restart following a post-trip review, if
2 it tripped off-line because of the earthquake).

3 6. PRE-SHUTDOWN INSPECTIONS

4 The pre-shutdown inspections described in Section 4.3.4 (~~including all~~
5 ~~subsections~~) of EPRI NP-6695, "Guidelines for Nuclear Plant Response to an
6 Earthquake," with the exceptions specified below, are acceptable to the NRC
7 staff for satisfying the requirements ~~proposed~~ in Paragraph IV(a)(3) of
8 ~~Proposed~~ Appendix S to 10 CFR Part 50 for ensuring the safety of nuclear power
9 plants.

10 6.1 Shutdown Timing

11 Delete the last sentence in the first paragraph of Section 4.3.4.

12 6.2 Safe Shutdown Equipment

13 In Section 4.3.4.1, a check of the containment isolation system should
14 be added to the minimum list of equipment to be inspected.

15 6.3 Orderly Plant Shutdown

16 The following paragraph in Section 4.3.4 of EPRI NP-6695 is printed here
17 to emphasize that the plant should shut down in an orderly manner.

18 "Prior to initiating plant shutdown following an earthquake,
19 visual inspections and control board checks of safe shutdown
20 systems should be performed by plant operations personnel, and the
21 availability of off-site and emergency power sources should be
22 determined. The purpose of these inspections is to determine the
23 effect of the earthquake on essential safe shutdown equipment
24 which is not normally in use during power operation so that any
25 resets or repairs required as a result of the earthquake can be
26 performed, or alternate equipment can be readied, prior to
27 initiating shutdown activities. In order to ascertain possible

1 fuel and reactor internal damage, the following checks should be
2 made, if possible, before plant shutdown is initiated "

3 D. IMPLEMENTATION

4 The purpose of this section is to provide guidance to applicants and
5 licensees regarding the NRC staff's plans for using this regulatory guide.

6 ~~This proposed revision has been released to encourage public~~
7 ~~participation in its development. Except in those cases in which the~~
8 ~~applicant proposes an acceptable alternative method for complying with the~~
9 ~~specified portions of the Commission's regulations, the method to be described~~
10 ~~in the active this guide reflecting public comments will be used in the~~
11 ~~evaluation of applications for construction permits, operating licenses,~~
12 ~~combined licenses, or design certification submitted after the implementation~~
13 ~~date to be specified in the active guide~~ EFFECTIVE DATE OF THE FINAL RULE.

14 This guide ~~would~~ will not be used in the evaluation of an application for an
15 operating license submitted after ~~the implementation date to be specified in~~
16 ~~the active guide~~ EFFECTIVE DATE OF THE FINAL RULE if the construction permit
17 was issued prior to that date.

18 Holders of an operating license or construction permit issued prior to
19 EFFECTIVE DATE OF THE FINAL RULE may voluntarily implement the methods
20 described in this guide in combination with the methods in Regulatory Guides
21 1.12, "Nuclear Power Plant Instrumentation for Earthquakes," Revision 2, and
22 1.57, "Restart of a Nuclear Power Plant Shut Down by a Seismic Event." Other
23 implementation strategies, such as a voluntary implementation of portions of
24 the cited regulatory guides, will be evaluated by the NRC staff on a case-by-
25 case basis.

APPENDIX A

INTERIM OPERATING BASIS EARTHQUAKE EXCEEDANCE GUIDELINES

This regulatory guide is based on the assumption that the nuclear power plant has operable seismic instrumentation and equipment (hardware and software) to process the data. If the seismic instrumentation or data processing equipment is inoperable, the following should be used to determine whether the operating basis earthquake ground motion (OBE) has been exceeded:

1. For plants at which instrumentally determined data are available only from an instrument installed on a foundation, the cumulative absolute velocity (CAV) ~~limit-check~~ (see Regulatory Position 4.2 of this guide) is not applicable. In this case, the determination of OBE exceedance is based on a response spectrum check similar to that described in Regulatory Position 4.1 of this regulatory guide. A comparison is made between the foundation-level design response spectra and data obtained from the foundation-level instruments. If the response spectrum check at any foundation is exceeded, the OBE is exceeded and the plant must be shut down. At this instrument location it is inappropriate to use the 0.2g spectral acceleration limit or the 6 inches per second (15.24 centimeters per second) spectral velocity limit stated in Regulatory Position 4.1.2.

2. For plants at which no free-field or foundation-level instrumental data are available, or the data processing equipment is inoperable and the response spectrum check and the CAV ~~limit-check~~ can not be determined (Regulatory Positions 4.1 and 4.2), the OBE will be considered to have been exceeded and the plant must be shut down if one of the following applies:

1. The earthquake resulted in Modified Mercalli Intensity (MMI) VI or greater within 5 km of the plant,
2. The earthquake was felt within the plant and was of magnitude 6.0 or greater, or

1 3. The earthquake was of magnitude 5.0 or greater and occurred within
2 200 km of the plant.

3 A postearthquake plant walkdown should be conducted after the earthquake
4 (see Regulatory Position 2 of this guide).

5 If plant shutdown is warranted under the above guidelines, the plant
6 should be shut down in an orderly manner (see Regulatory Position 6 of this
7 guide).

8 Note: The determinations of epicentral location, magnitude, and
9 intensity by the U.S. Geological Survey, National Earthquake Information
10 Center, will usually take precedence over other estimates; however,
11 regional and local determinations will be used if they are considered to
12 be more accurate. Also, higher quality damage reports or a lack of
13 damage reports from the nuclear power plant site or its immediate
14 vicinity will take precedence over more distant reports.

1 APPENDIX B
2 DEFINITIONS

3 Certified Standard Design. A Commission approval, issued pursuant to Subpart
4 B of 10 CFR Part 52, of a standard design for a nuclear power facility.

5 Design Response Spectra. Response spectra used to design Seismic Category I
6 structures, systems, and components.

7 Operating Basis Earthquake Ground Motion (OBE). The vibratory ground motion
8 for which those features of the nuclear power plant necessary for continued
9 operation without undue risk to the health and safety of the public will
10 remain functional. The value of the OBE is set by the applicant.

11 Spectral Acceleration. The acceleration response of a linear oscillator with
12 prescribed frequency and damping.

13 Spectral Velocity. The velocity response of a linear oscillator with pre-
14 scribed frequency and damping.

1 REGULATORY ANALYSIS

2 A separate regulatory analysis was not prepared for this regulatory
3 guide. The ~~draft~~ regulatory analysis, "~~Proposed~~ Revisions of 10 CFR Part 100
4 and 10 CFR Part 50," was prepared for the ~~propose~~ -amendments, and it provides
5 the regulatory basis for this guide and examines the costs and benefits of the
6 rule as implemented by the guide. A copy of the ~~draft~~ regulatory analysis is
7 available for inspection and copying for a fee at the NRC Public Document
8 Room, 2120 L Street NW. (Lower Level), Washington, DC, as ~~Enclosure 2 to~~
9 ~~Secy 94-194~~ **LATER**.

ATTACHMENT 16

**REGULATORY GUIDE 1.167
DRAFT WAS DG-1035**

(PLANT RESTART)

1 REGULATORY GUIDE 1.167
2 (Draft was DG-1035)

3 RESTART OF A NUCLEAR POWER PLANT
4 SHUT DOWN BY A SEISMIC EVENT

5 A. INTRODUCTION

6 Paragraph IV(a)(3) of ~~Proposed~~ Appendix S, "Earthquake Engineering
7 Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of
8 Production and Utilization Facilities," ~~would require~~ shutdown of the nuclear
9 power plant if vibratory ground motion exceeding that of the operating basis
10 earthquake ground motion (OBE) occurs or if significant plant damage occurs.¹
11 Prior to resuming operations, the licensee must demonstrate to the NRC that no
12 functional damage has occurred to those features necessary for continued
13 operation without undue risk to the health and safety of the public.

14 This guide ~~is being developed to provide~~ guidance acceptable to the NRC
15 staff for performing inspections and tests of nuclear power plant equipment
16 and structures prior to restart of a plant that has been shut down by a
17 seismic event.

18 ~~Regulatory guides are issued to describe and make available to the~~
19 ~~public such information as methods acceptable to the NRC staff for~~
20 ~~implementing specific parts of the Commission's regulations, techniques used~~
21 ~~by the staff in evaluating specific problems or postulated accidents, and~~
22 ~~guidance to applicants. Regulatory guides are not substitutes for~~
23 ~~regulations, and compliance with regulatory guides is not required.~~
24 ~~Regulatory guides are issued in draft form for public comment to involve the~~
25 ~~public in the early stages of developing the regulatory positions. Draft~~
26 ~~regulatory guides have not received complete staff review and do not represent~~
27 ~~official NRC staff positions.~~

28 Any information collection activities mentioned in this ~~draft~~ regulatory
29 guide are contained as requirements in the ~~proposed amendments to~~ 10 CFR Part
30 50 ~~that would provide~~, which provides the regulatory basis for this guide.
31 The ~~proposed amendments have been submitted to~~ information collection
32 requirements in 10 CFR Part 50 have been approved by the Office of Management

33 ¹~~Guidance is being developed in Draft Regulatory Guide DG-1034-1.166,~~
34 "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator
35 Postearthquake Actions," ~~to provide~~ criteria for plant shutdown.

1 and Budget for clearance that may be appropriate under the Paperwork Reduction
2 Act. Such clearance, if obtained, would also apply to any information
3 collection activities mentioned in this guide, Approval No. 3150-0011.

4 B. DISCUSSION

5 Data from seismic instrumentation² and a walkdown of the nuclear power
6 plant are used to make the initial determination of whether the plant must be
7 shut down after an earthquake, if the plant has not already shut down from
8 operational perturbations resulting from the seismic event.¹

9 The Electric Power Research Institute has developed guidelines that will
10 enable licensees to quickly identify and assess earthquake effects on nuclear
11 power plants in EPRI NP-6695, "Guidelines for Nuclear Plant Response to an
12 Earthquake,"³ December 1989. This regulatory guide addresses sections of
13 EPRI NP-6695 that relate to postshutdown inspection and tests, inspection
14 criteria, inspection personnel, documentation, and long-term evaluations.

15 EPRI NP-6695 has been supplemented to add inspections and tests as a
16 basis for acceptance of stresses in excess of Service Level C and to recommend
17 that engineering evaluations of components with calculated stresses in excess
18 of service Level D focus on areas of high stress and include fatigue analyses.

19 ~~Holders of an operating license or construction permit issued prior to~~
20 ~~the implementation date to be specified in the active guide may voluntarily~~
21 ~~implement the methods to be described in the active guide and the methods~~
22 ~~being developed in Draft Regulatory Guides DG 1033, "Nuclear Power Plant~~
23 ~~Instrumentation for Earthquakes," and DG 1034, "Pre Earthquake Planning and~~
24 ~~Immediate Nuclear Power Plant Operator Postearthquake Action."~~

25 C. REGULATORY POSITION

26 ²~~Guidance is being developed in Draft Regulatory Guide DG 1033-1.12, the~~
27 ~~third Proposed Revision 2 to Regulatory Guide 1.12, Revision 2, "Nuclear Power~~
28 ~~Plant Instrumentation for Earthquakes," that will describes seismic~~
29 ~~instrumentation acceptable to the NRC staff.~~

30 ³EPRI reports may be obtained from the Electric Power Research Institute,
31 ~~Research Reports EPRI Distribution Center, 207 Coggins Dr., P.O. Box 50490~~
32 ~~23205, Palo Alto, CA 94303 Pleasant Hill, CA 94523.~~

1 After a plant has been shut down by an earthquake, the guidelines for
2 inspections and tests of nuclear power plant equipment and structures that are
3 depicted in EPRI NP-6695 in Figure 3-2 and specified in Sections 5.3.2
4 ~~(including Tables 2-1, 2-2, and 5-1), 5.3.3 (includes Table 5-1), and 5.3.4;~~
5 the documentation to be submitted to the NRC specified in Section in 5.3.5;
6 and the long-term evaluations that are specified in Section 6.3 ~~(all sections~~
7 ~~and subsections)~~, with the exceptions specified below, ~~would be~~ **are** acceptable
8 to the NRC staff for satisfying the requirements ~~proposed in Paragraph~~
9 IV(a)(3) of ~~the Proposed Appendix S to 10 CFR Part 50.~~

10 1. EXCEPTIONS TO SECTION 6.3.4.1 OF EPRI NP-6695

11 1.1 Item (1) should read:

12 If the calculated stresses from the actual seismic loading conditions
13 are less than the allowables for emergency conditions (e.g., ASME Code
14 Level C Service Limits or equivalent) or original design bases, the item
15 is considered acceptable, provided the results of inspections and tests
16 (Section 5.3.2) show no damage.

17 1.2 The second dashed statement of Item (3) should read:

18 -- An engineering evaluation of the effects of the calculated stresses
19 on the functionality of the item. This evaluation should address all
20 locations where stresses exceed faulted allowables and should include
21 fatigue analysis **for ASME Code Class 1 components and systems.**

22 ~~1.3~~ ~~The last paragraph should read:~~

23 ~~Reanalysis of safety-related piping systems is not considered necessary~~
24 ~~unless there is observed damage to the piping systems. Experience has~~
25 ~~shown that piping systems designed to the ASME Code are not damaged by~~
26 ~~inertia loads resulting from an earthquake. If damage occurs, it will~~
27 ~~most likely occur in the piping supports or as damage to the pipe at~~
28 ~~fixed supports caused by relative support displacements. These types of~~
29 ~~damage would be detected by the plant walkdown inspections and post-~~
30 ~~shutdown inspections described in Sections 4 and 5 of this report. In~~
31 ~~general, piping reanalysis should be performed on a sampling basis to~~
32 ~~verify the adequacy of piping and to assess the need for supplemental~~
33 ~~nondestructive examination of potential high strain areas.~~

1 2. LONG-TERM EVALUATIONS

2 Coincident with the long-term evaluations, the plant should be restored
3 to its current licensing basis. Exceptions to this must be approved by the
4 Director, Office of Nuclear Reactor Regulation.

5 D. IMPLEMENTATION







6 The purpose of this section is to provide guidance to applicants and
7 licensees regarding the NRC staff's plans for using this regulatory guide.

8 ~~This draft guide has been released to encourage public participation in~~
9 ~~its development.~~ Except in those cases in which the applicant proposes an
10 acceptable alternative method for complying with the specified portions of the
11 Commission's regulations, the method ~~to be described in the active~~ this guide
12 ~~reflecting public comments~~ will be used in the evaluation of applications for
13 construction permits, operating licenses, combined licenses, or design
14 certification submitted after ~~the implementation date to be specified in the~~
15 ~~active guide~~ EFFECTIVE DATE OF THE FINAL RULE. This guide ~~would~~ will not be
16 used in the evaluation of an application for an operating license submitted
17 after ~~the implementation date to be specified in the active guide~~ EFFECTIVE
18 DATE OF THE FINAL RULE if the construction permit was issued prior to that
19 date.

20 Holders of an operating license or construction permit issued prior to
21 EFFECTIVE DATE OF THE FINAL RULE may voluntarily implement the methods
22 described in this guide in combination with the methods in Regulatory Guides
23 1.12, Revision 2, "Nuclear Power Plant Instrumentation for Earthquakes," and
24 1.166, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator
25 Postearthquake Actions." Other implementation strategies, such as voluntary
26 implementation of portions of the cited regulatory guides, will be evaluated
27 by the NRC staff on a case-by-case basis.

2







IMAGE EVALUATION TEST TARGET (MT-3)



PHOTOGRAPHIC SCIENCES CORPORATION
770 BASKET ROAD
P.O. BOX 338
WEBSTER, NEW YORK 14580
(716) 265-1600

2







IMAGE EVALUATION TEST TARGET (MT-3)



PHOTOGRAPHIC SCIENCES CORPORATION
770 BASKET ROAD
P.O. BOX 338
WEBSTER, NEW YORK 14580
(716) 265-1600

2







IMAGE EVALUATION TEST TARGET (MT-3)



PHOTOGRAPHIC SCIENCES CORPORATION
770 BASKET ROAD
P.O. BOX 338
WEBSTER, NEW YORK 14580
(716) 265-1600

2

IMAGE EVALUATION TEST TARGET (MT-3)



PHOTOGRAPHIC SCIENCES CORPORATION
770 BASKET ROAD
P.O. BOX 338
WEBSTER, NEW YORK 14580
(716) 265-1600

REGULATORY ANALYSIS

A separate regulatory analysis was not prepared for this regulatory guide. The ~~draft~~-regulatory analysis, "~~Proposed~~ Revision of 10 CFR Part 100 and 10 CFR Part 50," was prepared for the ~~proposed~~-amendments, and it provides the regulatory basis for this guide and examines the costs and benefits of the rule as implemented by the guide. A copy of the ~~draft~~-regulatory analysis is available for inspection and copying for a fee at the NRC Public Document Room, 2120 L Street NW. (Lower Level), Washington, DC. as See ~~94-194~~ LATER.

ATTACHMENT 17

**RESOLUTION OF PUBLIC COMMENTS ON DRAFT
REGULATORY GUIDES AND STANDARD REVIEW PLAN
SECTIONS PERTAINING TO THE PROPOSED
SEISMIC AND EARTHQUAKE ENGINEERING CRITERIA
FOR NUCLEAR POWER PLANTS**

**RESOLUTION OF PUBLIC COMMENTS ON DRAFT
REGULATORY GUIDES AND STANDARD REVIEW PLAN
SECTIONS PERTAINING TO THE PROPOSED
SEISMIC AND EARTHQUAKE ENGINEERING CRITERIA
FOR NUCLEAR POWER PLANTS**

Section	Description
1.	Regulatory Guide 1.165, "Identification and Characterization of Seismic Sources and Determination of Shutdown Earthquake Ground Motions" (Draft was DG-1032)
	Standard Review Plan Section 2.5.1, Revision 3, "Basic Geologic and Seismic Information"
	Standard Review Plan Section 2.5.2, Revision 3 "Vioratory Ground Motion"
	Standard Review Plan Section 2.5.3, Revision 3, "Surface Faulting"
2.	Regulatory Guide 1.12, Revision 2, "Nuclear Power Plant Instrumentation for Earthquakes" (Draft was DG-1033)
3.	Regulatory Guide 1.166, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Post-Earthquake Actions" (Draft was DG-10 ³ 4)
4.	Regulatory Guide 1.167, "Restart of a Nuclear Power Plant Shut Down by a Seismic Event" (Draft was DG-1035)

SECTION 1

RESOLUTION OF PUBLIC COMMENTS REGULATORY GUIDE 1.165 (Draft was DG-1032) STANDARD REVIEW PLAN SECTIONS 2.5.1, 2.5.2 & 2.5.3

ORGANIZED BY COMMENTOR:

1. American Society of Civil Engineers
2. DOE/OCRWN
3. Morgan, Lewis and Bockius
4. NEI
5. Wais and Associates
6. Westinghouse
7. Yankee Atomic Electric Company

American Society of Civil Engineers (Washington Office)

Comment:

The seismic design and engineering criteria of ASCE Standard 4, "Seismic Analysis of Safety-Related Nuclear Structures and Commentary on Standard for Seismic Analysis of Safety-Related Nuclear Structures," should be incorporated by reference into the regulation.

Response:

We do not agree that ASCE Standard 4 should be referenced in the revised regulation. When a document is referenced in a federal regulation it becomes a part of that regulation. Codifying this standard would be reinstating a prescriptive format into the regulation, which has been cited over the past two decades as being one of the major contributors to difficulties in applying Appendix A to 10 CFR Part 100.

Thus, one of the primary reasons for revising Appendix A is to remove the prescriptive elements. These elements were put into the regulation more than two decades ago and soon became obsolete with respect to the state-of-the-science. Because of the cast-in-concrete nature of a federal regulation, it was extremely difficult to update. Also, the prescriptive list was incomplete, thus allowing the potential for gaps in the site specific investigations and analyses. It also required following procedures that were unnecessary at many sites.

Review Comments by DOE/OCRWM on NRC's Proposed Changes to 10 CFR Parts 50, 52, and 100

General Observations

1. Applicability of Appendix A Seismic Hazard Evaluations to the Mined Geologic Disposal System - MGDS (in "Supplementary Information" - Section III -page 52256)

In the top half of the center column, it is stated that "...The proposed regulatory action would apply to applicants who apply for a construction permit, operating license, preliminary design approval, final design approval, manufacturing license, early site permit, design certification, or combined license...."

COMMENT: This statement does not explicitly indicate whether or not the proposed revisions would apply to the MGDS.

2. Applicability of Appendix A or proposed Subpart B to a Monitored Retrievable Storage (MRS) facility (in "Supplementary Information" - Section III - page 52256)

In the top half of the center column, it is stated that "...The proposed regulatory action would apply to applicants who apply for a construction permit, operating license, preliminary design approval, final design approval, manufacturing license, early site permit design certification, of combined license...."

COMMENT: This statement does not explicitly indicate whether or not the proposed revisions would apply to a MRS.

Responses to Comments 1 and 2:

SECY-94-194, Enclosure 2, page RA-16, paragraph a., under IMPACTS, presents the staff's position on these issues: "The proposed regulation, Section 100.23 to Part 100, is still applicable only to nuclear power plants. The revision of Part 72 and Appendix A to Part 40, subject to the implementation of Section 100.23 to Part 100, should be a separate rulemaking initiative."

3. State of Knowledge about Earthquake Phenomena (in "Supplementary Information" - Section V.B.3. Uncertainties and Probabilistic Methods - page 52261)

In the middle of the third paragraph it is stated that "Because so little is known about earthquake phenomena..."

COMMENT: Use of the expression "so little is known" creates a false impression of the current state of knowledge about earthquake phenomena. Although our understanding of earthquake phenomena remains uncertain, quantum advances in knowledge have been made during the past 25 years. With these very significant advances, geoscientists now have much more confidence than previously in expressions of uncertainty regarding interpretations of inputs to a probabilistic seismic hazard analyses; and these can be fully accounted for in the uncertainty in the seismic hazard results. The language of the regulation should reflect these very positive developments.

Response:

The statement has been revised to put less emphasis on the negative as follows: "Because of uncertainties about earthquake phenomena (especially in the eastern United States), there have often been differences of opinion and differing....."

4. Nature of Geoscience Investigations (in "Supplementary Information" - Section V.B.3. Uncertainty and Probabilistic Methods - page 52262)

The key elements of the NRC's proposed balanced approach are listed in the top third of the left hand column on page 52262.

COMMENT: The wording of the fourth element should be revised to indicate that the geoscience investigations refer to site-specific data, or new regional data, or a combination of the two.

Response:

It refers to both regional and site investigations. The element has been revised to: "Determine if information from the regional and site geoscience investigations....."

DRAFT REGULATORY GUIDE DG - 1032 (now called Regulatory Guide 1.165)

1. Description of Probabilistic Seismic Hazard Analysis (PSHA) (in B. Discussion-Background, page 3, line 29)

COMMENT: Another important aspect of a PSHA, not mentioned, is its explicit estimation of SSE likelihood during the "design lifetime" of a facility.

Suggest adding a sentence after "...seismological parameters." such as: A PSHA also provides an evaluation of the likelihood of SSE recurrence during the design lifetime of a given facility - given the recurrence interval and recurrence pattern on pertinent seismic sources.

Response:

The aspect is implicit in the discussion but is not stated directly. We agree that the statement improves the discussion and have included it as you suggest.

2. Areal Extent for Regional Studies and Seismic Source Identification (in V. Regulatory Position, Section C.1.1., page 7, lines 15-17, and also Appendix D, D..2.1, page D-4, lines 27, 28)

COMMENT: The areal extent of regional seismic source investigations is defined as extending to 320 km (200 miles) from the site.

The requirement to perform investigations within 320 km around a site is excessive, and not generally needed to identify the seismic sources that could contribute to the seismic hazard at a site. Since the EPRI and LLNL seismic sources are accepted (with confirmation) as the basis for evaluating the seismic hazard at potential sites in the Eastern United States (EUS) the potential contributions of all sources in the EUS will be known. In the

western United States, the very high rate of attenuation of ground motion precludes seismic sources beyond about 150 km contributing to the seismic hazard at a site. The applicant should be required to develop and justify its rationale for the area considered and the size of seismic sources considered as function of distance from the site.

While Section C.1.1 states that the level of detail for the regional studies is data obtained from a literature survey and geologic reconnaissance, one would assume that all these sources are to be included in a probabilistic seismic hazard assessment (PSHA). This could result in many insignificant seismic sources being characterized and included in the PSHA DG-1032 should be modified to require identification only of sources that may contribute significantly to the seismic hazard at the site.

Response:

The reason for this distance is not only to identify those presently unknown seismic sources close enough to affect the site, but, because CEUS sources are at depth and largely undefined, the area should be as broad as reasonably possible to incorporate any sources identified that could be analogous to sources that may be near to or underlie the site. Within this area, assessment of regional seismological, geological, and geophysical data or other information that could be used to identify or interpret potential seismic sources should be made. It is not expected to be a detailed investigation and may consist of only literature studies (including earthquake catalogs, maps, and geophysical, airphoto, and other remote sensing data) and with limited ground truth reconnaissances.

In the past it has often been necessary to estimate the age of a potential seismic source in the site vicinity by relating its time of last activity to that of a similar, previously evaluated structure, or a known tectonic episode the evidence of which may be many tens or hundreds of miles away. Additionally, because of the relatively aseismic nature that characterizes the CEUS, the broader the area considered, the more earthquake epicenters will be included.

As described in Appendix E of DG-1032 (Regulatory Guide 1.165), a newly identified, potentially significant seismic source, the characteristics of which are supported by a strong technical basis, are identified within 320 km (200 mi) of the site will be assessed by a sensitivity analysis. If the results of that sensitivity test show that source has no impact on the SSE, then no further work will have to be done regarding that source. Most newly identified sources will be small, or ancient, and can be dismissed without sensitivity studies. Only if the sensitivity study indicates that the source could result in a significant change in the hazard will that source have to be included in the PSHA.

In the western U.S., to justify not extending the regional investigation out in all directions to 320 km (200 mi), may be less difficult in that there is usually a large source closer to the site that will be SSE-controlling and dominate more distant sources no matter how large they are. For example, The San Gregorio-Hosgri fault zone, which is approximately 4 km from the Diablo Canyon Nuclear Power Plant, with respect to the San Andreas, which is about 75 km (45 mi) from the site. It would, therefore, not be necessary to search for a seismic source on the other side of the San Andreas, or a source smaller

than the San Gregorio-Hosgri between the San Andreas and the site. On the other hand, it may be necessary, as was the case of the San Gregory-Hosgri fault zone, to extend the regional investigations well beyond 320 km (200 mi) along the fault zone in both directions to characterize the seismic hazard of that source.

3. Implied Definition of Seismic Potential (in C. Regulatory Position Section C.2.2, page 9, lines 30, 31)

COMMENT: The term "seismic potential" used in Section C.2.2, page 9. The following parenthetical phrase "magnitude and recurrence rate" implies that this is the definition of seismic potential.

This neglects the possibility that there is uncertainty in whether the source is active at all. The evaluation of the likelihood that a source is active (seismogenic) is necessary, because not all sources have a probability of 1.0 that they are active. Characterization of source's seismic potential should include magnitude, recurrence rate, and probability of activity.

More broadly, there is a general lack of emphasis in this document on the need to characterize the uncertainty in all inputs to the probabilistic seismic hazard analysis.

Response:

We agree and the text has been modified as follows:

"Typically, characterization of the seismic potential consists of four equally important elements:

- 1) Selection of a model for the spatial distribution of earthquakes in a source.
- 2) Selection of a model for the temporal distribution of earthquakes in a source.
- 3) Selection of a model for relative frequency of earthquakes of various magnitudes including an estimate for the largest earthquake that could occur in the source under the current tectonic regime.
- 4) A complete description of the uncertainty."

4. Use of the word "determined" (in C. Regulatory Position, Section C.2.2, page 9, line 32)

COMMENT: The use of the word "determined" in the phraseseismic potential should be determined... is too strong and unrealistic, given the lack of precision that can reasonably be expected for this task.

Suggest replacing "determined" with "evaluated".

Response:

The word "determined" has been replaced with "evaluated" as suggested.

5. Steps 1 through 5 in PSHA Procedure (in C. Regulatory Position, Section 3, pages 11 and 12)

COMMENT: The applicability of each Step to either "CEUS sites" or "CEUS and/or western USA sites" needs clarification.

Suggest adding the phrase "For any site (CEUS or western USA)," at the beginning of the text of appropriate steps - such as Steps 1, 4, and 5.

Response:

Step 1 concerns regional and site investigations and refers to Appendix D. Appendix D clearly states that these investigations are to be carried out regarding all sites, even for those plants that are to be sited at existing nuclear power plants. The description of Step 2 indicates that these are for CEUS sites. Step 4 refers to Appendix B for guidance, which discusses the procedure in terms of its application to CEUS. Step 5 gives Appendix C as a reference. Appendix C describes how to apply the procedure to CEUS and WUS.

6. Use and definition of the term; "controlling earthquake" (in Appendix A - Definitions, page A - 1, lines 3 - 7)

COMMENT: Use of this term is confusing. It is defined on page A - 1 (for the probabilistic seismic hazard analysis) as a mean magnitude and derived from a de-aggregation analysis of the PSHA.

Within this framework, there may be several controlling earthquakes. In Standard Review Plan 2.5.2 (page 2.5.2. - 9) "controlling earthquake" is used in a different (deterministic) sense (e.g., "...controlling earthquakes for each source..."). The definition of controlling earthquake should be expanded in Appendix A of DG-1032 to include its usage within both a probabilistic and deterministic framework.

Response:

At some sites in the CEUS there may be two PSHA controlling earthquakes; a nearby event that dominates the potentially damaging ground motion at higher frequencies, and a more distance large event that dominates the low frequency ground motions (e.g. the Vogtle site).

A deterministic controlling earthquake (or earthquakes) is no longer used in SRP 2.5.2. Therefore, any reference to controlling earthquakes refers to those determined by a PSHA.

7. Rock varnish cation ratio age-dating method (in Appendix D, Section D.2.4.5, page D-11, lines 8,9).

COMMENT: The text states that rock varnish cation ratio dating is controversial, and its use is not recommended pending further validation.

The rock varnish cation ratio method may prove to be no more controversial than many of the other methods discussed in the text. All methods have uncertainties.. The applicant should employ a variety of age-dating techniques to corroborate any given age data, and to address uncertainties.

Additional work on cosmogenic dating, pertinent to an independent potential corroboration of rock varnish ages, is now underway at Los Alamos National Laboratory.. It is recommended that the NRC reconsider the subject statement

on page D-11 in light of the above discussion, when results of the in-progress work on cosmogenic dating are available.

Response:

During the past few years, most articles in scientific journals, which have addressed the rock varnish cation ratio method of dating, indicated that the use of this method is becoming progressively less acceptable, based on theoretical, statistical, and practical considerations. Therefore, we feel that the statement is appropriate.

PROPOSED REVISION - STANDARD REVIEW PLAN SECTION 2.5.1

1. Areal Extent for Regional Studies and Seismic Source Identification (in II. Acceptance Criteria Section 2.5.1.1, page 2.5.1-7, lines 20-23)

COMMENT: This section describes the requirement for an applicant to discuss a site's regional geology within a distance of 320 km of the site.

See Comment for DG-1032.

Standard Review Plan Section 2.5.1 (II.. Acceptance Criteria) should be modified to require identification of only those seismic sources that may generate earthquakes which provide strong seismic ground motions at the site.

Response:

See response to Comment 2 on DG-1032 (now called Regulatory Guide 1.165).

PROPOSED REVISION - STANDARD REVIEW PLAN SECTION 2.5.2

1. Areal Extent for Regional Studies and Seismic Source Identification (in I. Areas of Review, page 2.5.2-2, lines 22, 23)

COMMENT: The statement is made that "all seismic sources that have any part within 320 km (200 miles) of the site must be identified."

See Comment 2 for DG-1032.

Standard Review Plan Section 2.5.2 should be modified to require identification only of sources that may contribute significantly to the seismic hazard at the site.

Response:

See responses to Comment 2 for DG - 1032 (Regulatory Guide 1.165).

2. NRC's "Balanced Approach" and It's Deterministic Component (in II. Acceptance Criteria, Section 2.5.2.4, page 2.5.2.9, lines 13, 14)

COMMENT: It would be useful if the NRC provided a flow diagram that clearly indicated how the PSHA procedure would encompass an independent evaluation.

This would be helpful because it would clearly show where independent evaluations will be used as input to the PSHA.

Response:

As stated in a previous comment response, the requirement for the staff to perform a deterministic seismic hazard analysis has been eliminated.

"Balanced approach" refers to: (1) deterministic regional and site geological, seismological, geophysical, and geotechnical investigations; and (2) probabilistic seismic hazard analyses.

3. Procedure for Developing Site-Specific Spectral Shapes (in II. Acceptance Criteria, Section 2.5.2.6, pages 2.5.2-11, line 24 through 2.5.2-14, line 10)

COMMENT: This procedure does not take proper advantage of the current state of knowledge in ground motion estimation, and (in general) could be unnecessarily contentious and difficult to implement.

Although the primary preferred procedure (No. 1) would be the most desirable approach, data are rarely (if ever) available to permit this procedure to be properly used. Accordingly, this procedure should be used only in those instances where data are available.

The second preferred (No. 2) procedure should not be used without specific additional procedures for scaling source spectra such as those contained in the random vibration modeling approaches used in Reference 12 of the cited references.

The third of the preferred procedures, the random vibration method, should be emphasized. The random vibration method has been extensively validated against data during the past 10 years and can now be said to be accepted state of practice. Moreover, it is simple to apply now for any region of the United States.

Response:

Procedure No. 1, page 2.5.2-12. It is true that data required for this procedure is rarely available for a specific site, however, the staff is of the opinion that there is usually data available regarding analogous sites (similar sized earthquakes, similar subsurface conditions, etc.) within the worldwide database. If not, greater reliance will have to be placed on one or more of the other procedures.

Regarding your comment on the second procedure, we agree. The staff's intent has always been to use a multi-procedural approach. The results should be confirmed by performing additional procedures for scaling source spectra such as one of those used in Reference 12.

The random vibration method, procedure 3, has been validated to a large extent by data over the past decade, and may be used along with another method or methods. However, the staff prefers the application of Procedure 1.

Comments on Draft Regulatory Guide DG-1032

Draft Regulatory Guide DG-1032 reiterates the provision in Section 100.23(d)(1) of the proposed rule, which states that uncertainties in the Safe Shutdown Earthquake (SSE) must be addressed through appropriate analysis, such as a probabilistic seismic hazard analysis or suitable sensitivity analysis.. However, the draft regulatory guide then goes on to state that a probabilistic seismic hazards analysis should be performed. Additionally, almost all of the draft regulatory guide is devoted to the methodology for performing a probabilistic seismic hazards analysis, and it contains no discussion at all of other methods for addressing uncertainties in the SSE, thereby implying that other methods are not acceptable. However, there is no clear statement that if a probabilistic analysis is performed no further analysis is necessary or if a suitable sensitivity analysis is performed a probabilistic analysis is not necessary.

Furthermore, the draft regulatory guide states that the probability of exceeding the SSE should not exceed the median probability of existing plants exceeding their SSE's. The draft regulatory guide provides no explanation or justification for this provision, and none is apparent.

Response:

The staff prefers that an acceptable probabilistic seismic hazard analysis such as the LLNL or EPRI be performed, but leaves open the option to perform sensitivity studies. In Regulatory Guide 1.165 (formerly DG-1032), Section B. Discussion, Background, the first paragraph reads "A probabilistic seismic hazard analysis (PSHA) has been identified in Section 100.23 as a means to determine the SSE and account for uncertainties in the seismological and geological evaluations. The rule further recognizes that the nature of uncertainty and the appropriate approach to account for it depend on the tectonic regime and parameters such as the knowledge of seismic sources, the existence of historical and recorded data, and the level of understanding of the tectonics. Therefore, methods other than probabilistic methods such as sensitivity analyses may be adequate for some sites to account for uncertainties."

The type of analysis is left up to the applicant. However, in some cases, if an applicant elects to perform a sensitivity study to validate a site, it may also be necessary to conduct a probabilistic analysis, based on the results of the sensitivity analysis. For example, assume that the geological investigations identify paleoseismic evidence for a single large earthquake that occurred near the site several thousand years ago, but there is no evidence of a similar event within the past hundred thousand years. It might be desirable to address that event within the context a probability analysis to determine what percent of the total hazard that earthquake represents before calculating the SSE.

Operating plants have gone through the licensing process and have been subjected to the requirements of Appendix A to 10 CFR Part 100. Furthermore, in the Commission policy statement on severe accidents in nuclear power plants issued on August 2, 1985 (50FR 32138), the Commission concluded, based on

available information, that existing plants pose no undue risk to the public health and safety. Based on that decision the staff decided to require that new plants base their SSE on the median probability of exceeding the SSE of the more recently licensed operating plants (those designed to Regulatory Guide 1.60 response spectra or to a similarly conservative response spectra).

This recommendation is discussed in the Statement of Considerations (RIN 3150-AD93), V.B.3, last paragraph, and the procedure itself is described in Appendix B to Regulatory Guide 1.165. In the referenced Statement of Considerations paragraph, the statement is made concerning the staff's review of applicants' SSE databases: "This review takes into account the information base developed in licensing more than 100 plants. Although the basic premise in establishing the target exceedance probability is that the current design levels are adequate, a staff review further assures that there is consistency with previous licensing decisions and that the scientific basis for decisions are clearly understood."

Responses to Comments of NEI Regarding the NRC Siting Documents

Comment No. 3:

Proposed Rule, line 3, 100.23. Section d(1) of this subpart states, "Determination of the Safe Shutdown Earthquake Ground Motion. The Safe Shutdown Earthquake Ground Motion for the site is characterized by both horizontal and vertical free-field ground motion response spectra at the free ground surface. The Safe Shutdown Earthquake Ground Motion for the site is determined considering the results of the investigations required by paragraph (c) of this section. Uncertainties are inherent in such estimates. These uncertainties must be addressed through an appropriate analysis, such as a probabilistic seismic hazard analysis or suitable sensitivity analyses. Paragraph IV (a)(1) of Appendix S to Part 50 of this chapter defines the minimum Safe Shutdown Earthquake Ground Motion for design."

Determination of the SSE is based upon an evaluation that includes investigation of geological and seismological information and the results of a probabilistic seismic hazard analysis. Addressing uncertainties is an inherent part of the process.

Based upon prior licensing decisions and scientific evaluations (Systematic Evaluation Program, Appendix A evaluations, LLNL, and EPRI) it seems reasonable to only perform detailed confirmatory site investigations (Regulatory Guide 1.132) at existing sites. Standardized 0.3g advanced plant designs are sufficiently robust to bound the seismic design attributes of all nuclear power plants at current sites. Inclusion of these simplified requirements for existing sites represents a significant step toward predictable and cost-effective licensing. Revise to read (substitution in italics):

Desired Change:

"Determination of the Safe Shutdown Earthquake Ground Motion. The Safe Shutdown Earthquake Ground Motion for the site is characterized by both horizontal spectra and vertical free-field ground motion response spectra at the free ground surface. *The Safe Shutdown Earthquake Ground Motion for the site is based upon the investigations required by paragraph (c) of this section and the results of a probabilistic seismic hazard analysis. Seismological and geological uncertainties are inherent in these determinations and are captured by the probabilistic analysis. Suitable sensitivity analyses may also be used to evaluate uncertainties.* Paragraph IV (a)(1) of Appendix S to Part 50 of this Chapter defines the minimum Safe Shutdown Earthquake Ground Motion for design. *Based upon prior scientific findings and licensing decisions at existing nuclear power plant sites east of the Rocky Mountain Front (east of approximately 105 west longitude), a 0.3g Standardized design level is acceptable at these sites given confirmatory foundation evaluations.*"(1)DG-1032

Response No. 3:

(1) Determination of the Safe Shutdown Earthquake ground Motion. Your recommended rewording is another way of saying the same thing, but places less

emphasis on site-specific investigations relative to the PSHA than the current wording. We regard the current wording as better reflecting the proper priorities. Site specific investigations (regional and site geological, seismological, geophysical, and geotechnical) are of prime importance in deriving the bases for the SSE. It must not be forgotten that if all of the data that is needed about a site to determine the SSE could be obtained through site-specific investigations, a PSHA would not be necessary. However, because of uncertainties, at the present time, more reliance must be placed on PSHA's than may be necessary in the future when more information is available.

Paragraph IV(a)(1) of Appendix S to Part 50. Investigations at most of the existing sites will more than likely be confirmatory if the initial investigations were thorough, and there has not been too much time past since the initial investigations were accomplished and the results reviewed by the NRC, during which a substantial amount of new information has been developed. However, in many cases it may be necessary to carry out more extensive investigations than are usually considered as "confirmatory" investigations because: (1) the state-of-the-science is rapidly changing as new information is derived from every earthquake that occurs, and from ongoing research; (2) applicants may elect not to use the standard design plant and justify an SSE different than 0.03g; and (3) it will often be necessary, even for standard design sites, to determine a site-specific SSE as the design basis for other, non-standard design, safety-related structures, systems or components such as dams, reservoirs, intake and discharge facilities, etc.

The current wording in the proposed regulation most accurately represents the NRC staff's position on this issue.

Comment No. 4:

DG-1032, page 8, line 8. Item 4 states, "Very detailed geological, geophysical, and geotechnical engineering investigations should be conducted within the site (radius of approximately 1 Km)....."

The guidance language should include English units consistent with NRC staff policy.

Desired Change:

Revise to read:

"Very detailed geological, geophysical, and geotechnical engineering investigations should be performed within the site [1 km (0.5 miles)]..."

Response No. 4:

We agree with this comment and the English units have been added.

Comment No. 5:

DG-1032, pages 7-8, Line 15 on P7 to 10 on P8, Paragraph 3. This Section states:

"1. Regional geological and seismological investigations such as geological reconnaissances and literature reviews should be conducted within a radius of 320 km (200 miles) of the site to identify seismic sources (seismogenic and capable tectonic sources)."

2. Geological, seismological and geophysical investigations should be carried out within a radius of 40 km (25 miles) in greater detail than the regional investigations to identify and characterize the seismic and surface deformation potential of any capable tectonic sources and the seismic potential of seismogenic sources...

3. Detailed geological, seismological geophysical and geotechnical investigations should be conducted within 8 km (5 miles) of the sites as appropriate...

4. Very detailed geological, geophysical, and geotechnical engineering investigations should be conducted within the site (radius of approximately 1 km) to assess specific soil and rock characteristics..."

The requirements to perform investigations within 320 Km (200 miles) around a site is excessive and not generally needed to determine the seismic sources that could contribute to the seismic hazard at a site. The seismic hazard at a site in the Central and Eastern U.S. (EUS) is dominated by earthquakes that occur at distances less than 100 km in most cases. Nonetheless, seismic sources beyond 100 km are considered in the PSHA if appropriate (e.g., incorporation of the New Madrid seismic zone).

Since the EPRI and LLNL seismic sources are accepted (with confirmation) as the basis for determining the seismic hazard at potential sites in the EUS, the potential contributions of all sources will be known. In the WUS, the very high rate of attenuation of ground motion precludes seismic sources beyond 150 Km contributing to the seismic hazard at a site.

The IAEA Safety Guide No. 50-SG-S1 (Rev. 1), "Earthquakes and Associated Topics in Relation to Nuclear Power Plant Siting, 1991" provides the justification for the proposed revisions regarding the distances, i. e., 320 Km to 200 Km and 40 Km to 25 Km.

Desired Change:

Revise Paragraph 1 to read:

"...reviews should be conducted within a radius of 200 Km (125 miles) of the site to identify seismic sources..."

Revise Paragraph 2 to read:

"...carried out within a radius of 25 km (15 miles)..."

Note: This comment also applies to DG-1032, Appendix D, page D-4, line 28; SRP 2.5.2, Page 2.5.2.-5, line 17 and Page 2.5.2.-6, line 17.A.

Response No. 5:

Paragraph 1. The 320 km (200 mi) radius was established by the authors of Appendix A to 10 CFR Part 100 and we see no compelling reason to change that

distance at this time. The reason for this distance in the CEUS is not only to provide a broad enough area to allow for the identification of seismic sources close enough to affect the site, but also to allow for the incorporation of more earthquake data, which is diagnostic of seismic sources, into the analysis. It also allows the incorporation of a greater amount of technical information concerning previously identified, more distant potential seismic sources that could be analogous to sources near to, or underlying the site.

In past licensing activities in the CEUS it has often been necessary to estimate the age of a potential capable fault by relating its time of last activity to that of a previously evaluated structure, or a known tectonic episode, the evidence of which may be many tens or hundreds of miles from a site. The converse has also occurred when it became necessary to relate the age of last activity of a distant significant regional source to one investigated in detail near a site.

Because the CEUS is relatively aseismic and earthquake sources are undefined, we believe the area should be as broad as reasonable to expand the database. This database includes regional data such as historic and instrumentally recorded seismicity, paleoseismic evidence, geological evidence, and geophysical anomalies that could be used to identify or interpret potential seismic sources.

In most cases the types of investigations necessary within the 200 mile radius will not be extensive, but consist of a literature search, and the study of existing maps, subsurface data, remote sensing data, and geophysical data, with some ground truth reconnaissances.

In the western U.S. (WUS) it is also often necessary to extend the investigations to great distances (up to hundreds of kilometers) to characterize a major tectonic structure, such as the San Gregorio-Hosgri Fault Zone, the Juan de Fuca Subduction Zone, etc. On the other hand, in the WUS, it is not usually necessary to extend the regional investigations that far in all directions. For example, for a site such as Diablo Canyon, which is near the San Gregorio-Hosgri Fault Zone, it would not be necessary to extend the regional investigations to the east beyond the dominant San Andreas Fault, which is about 75 km (45 mi) from the site; nor to the west beyond the Santa Lucia Banks Fault, which is about 45 km (27 mi) from the site. In other words, in the WUS it is often possible to specifically define and justify closer in (less than 200 mi) limits of regional investigations and focus investigations at greater distances (greater than 200 mi) because the major sources are more often known than in the CEUS.

Paragraph 2. The purpose of the 25 mile (40 km) radius is to ensure that an investigation of sufficient detail will be carried out to demonstrate that there is no potential significant seismic source within the near field of the site, or to provide sufficient information to characterize the hazard of such a source if it exists. The near field is considered to be within about 17 km, however, it is prudent to extend the area of investigations at this level of detail beyond that limit due to the difficulty of defining seismic sources in the CEUS. Detailed investigations within this area will most likely be asymmetric and focussed on limited locations that were identified during the regional investigations.

Comment No. 6:

DG-1032, Page 13, line 23, Item 4. Last paragraph of item 4 states, "To obtain an adequate design SSE based on the site specific response spectrum or spectra, develop a smooth spectrum or spectra...."

As currently stated, this item confuses the design SSE (established by the certified design of the given ALWR) with the site-specific SSE response spectra associated with ensuring a certified design can be placed on that site.

The design SSE is established by the DG-1032 process. Part 100 addresses the determination of the site-specific SSE response spectrum that should be emphasized by the design.

Desired Change:

Revise to read:

"To obtain an adequate comparison of the site-specific SSE response spectrum or spectra with the ground motion spectra used for design, develop...."

Response No. 6:

The paragraph has been revised to address the concern.

Comment No. 7:

DG-1032, Page 10, lines 1 and 21, Sections 2.2.1 & 2.2.2.1. Section 2.2.1 states, "For sites located in the EUS, the seismic sources and data that have been accepted by the NRC staff in past licensing decisions may be used to estimate seismic potential."

Section 2.2.2.1 states, "For sites located in the CEUS, the seismic sources and data that have been accepted by the NRC staff in past licensing decisions may be used to estimate seismic potential."

The actual meaning or value of these statements are not clear in the context of a PSHA and in particular regarding the use of the EPRI and LLNL seismic hazard methodologies. The text should also refer to seismic sources and data used in the LLNL and EPRI seismic hazard studies. Given that past licensing decisions have been made on the basis of deterministic assessments, there is clear method for considering that information.

It would be useful to an applicant if the NRC staff could provide in Appendix D a section that presents a complete description of the "NRC accepted" source zones and their associated controlling earthquakes from past licensing decisions.

Desired Change:

Revise Section 2.2.1 and/or 2.2.2.1 to read:

"For sites located in the EUS and CEUS, the seismic sources and data that have been accepted by the NRC staff in both past licensing decisions and in the

LLNL and EPRI methodologies may be used to estimate seismic potential. Appendix D contains a section that presents a complete description of accepted source zones and their associated controlling earthquakes."

Response No. 7:

Because we are recommending that the LLNL and EPRI PSHA's be used, it is understood that the seismic sources that form the bases of these analyses will be considered. However, the wording has been changed to make the intent of the statement more clear as follows: "For sites located in the CEUS, when the EPRI and LLNL PSHA methodologies are used to determine the SSE, it still may be necessary to investigate and characterize potential seismic sources that were previously unknown or uncharacterized, and perform sensitivity analyses to assess their significance to the seismic hazard estimate. The results of investigations discussed in Regulatory Position 1 are to be used, in accordance with Appendix E, to determine whether updating of the LLNL or EPRI seismic sources and their characterization is needed. The guidance in 2.2 and 2.3 below and Appendix D of this guide may be used if additional seismic sources are to be developed as a result of investigations."

Since the dual deterministic and probabilistic method described in former DG 1015 was abandoned, the intent of Regulatory Guide 1.165 (formerly DG 1032 and before that DG 1015) has been to describe acceptable deterministic investigation procedures and probabilistic seismic hazard methodologies; but not deterministic seismic hazard methodologies. Because your comment is in regard to a deterministic seismic hazard analysis, its resolution more appropriately belongs in SRP 2.5.2. Therefore, a table, Table 1, which is a very general presentation based on technical information developed over the past two decades of licensing nuclear power plants, has been added to Subsection 2.5.2.4, for use by the NRC staff in reviewing the results of the applicants' PSHA.

Comment No. 8:

DG-1032, Page 10, lines 12-14, Sect 2.2.1. This Section states, "These seismic sources and their parameters should be used to judge the adequacy of seismic sources and parameters used in the LLNL or EPRI PSHA."

It is technically inappropriate to establish the seismic sources developed as part of past licensing decisions as a criterion for acceptance of the LLNL and EPRI seismic source characterizations. The determination of seismic sources used in past licensing decisions was made in the context of a deterministic analysis. Consequently, there is no practical way to use these seismic sources and their parameters developed in past licensing decisions as a measure of the adequacy of a probabilistic assessment that considers the uncertainty in the seismic source characterization.

Section 2.2.1 is an apparent attempt to apply a deterministic acceptance criterion (i.e., measure of adequacy) to the PSHA seismic source characterization.

Desired Change:

Delete this entire section.

Response No. 8:

Section 2.21 has been modified as described in the responses to Comments 6 and 7, but the section has been left in. The significance of these modifications is that the staff is no longer required to perform a deterministic check of the applicants' PSHA, which appears to be the objection to the section.

Among the criteria with which the staff will judge the adequacy of the PSHA-determined SSE are: (1) the results of the applicants' deterministic regional and site investigations and other available technical information, (2) the results of its own independent PSHA, and (3) comparison with Table 1 in SRP 2.5.2, which is based to a large extent on consideration of historic seismicity.

Comment No. 9:

DG-1032, Page 2, lines 1-5, Sect A. The text states, "In the proposed section 100.23, paragraph (d)(1)...would require that uncertainty inherent in estimates of the SSE be addressed through an appropriate analysis such as a probabilistic seismic hazard analysis or suitable sensitivity analysis."

The proposed revision makes the draft regulatory guide (DG-1032) consistent with the proposed rule Section 100.23.

See also the rationale provided in Comment Number 3 above.

Desired Change:

Revise to read:

"In the proposed section 100.23, paragraph (d)(1), determination of the safe shutdown earthquake ground motion for the site is based upon the investigations required by paragraph (C) of this section and the results of the probabilistic seismic hazard analysis. Seismological and geological uncertainties are inherent in these evaluations and are captured by the probabilistic analysis."

Response No. 9:

See Response No. 3. Section 100.23, paragraph (d)(1) was not modified in the regulation, so there is no need to alter the present wording for consistency.

Comment No. 10:

DG-1032, page 3, line 5, Sect B. The text states, "A probabilistic seismic hazard analysis (PSHA) has been identified in the proposed Section 100.23 as one of the means to address uncertainties in estimates of the SSE."

The proposed revision makes the draft regulatory guide (DG-1032) consistent with the proposed rule § 100.23. Also see the rationale provided in Comment Number 3 above. Revise to read:

"A probabilistic seismic hazard analysis (PSHA) has been identified in the proposed § 100.23 as a means to determine the SSE and account for inherent uncertainties in the seismological and geological evaluations."

Response No. 10:

The text has been changed to include the recommended wording as follows: "A probabilistic seismic hazard analysis (PSHA) has been identified in Section 100.23 as a means to determine the SSE and account for uncertainties in the seismological and geological evaluations."

Comment No. 11:

DG-1032, page 3, line 16, Sect B. The text states, "...incorporate uncertainty in the..."

The proposed revision is more accurate and consistent.

Desired Change:

Revise to read:

"...incorporate uncertainty (i.e., alternative scientific interpretations) in the"

Response No. 11:

We agree that the suggested revision says it better, and has been adopted in the following manner: "(including alternative scientific interpretations)."

Comment No. 12:

DG-1032, page 4, line 16, Sect B. The text states, "The process to determine the SSE at a site should include:"

The proposed revision makes the draft regulatory guide (DG-1032) consistent with the proposed rule § 100.23. It is understood that regional investigations are not needed at existing sites.

Desired Change:

Revise to read:

"The process to determine the SSE at a site in general include:

Response No. 12:

The phrase "in general" has been inserted to replace "should" in this statement as recommended, however, it will in most cases, be necessary to conduct regional investigations at existing sites. The scope of these regional studies will vary from site to site, however.

Comment No. 13:

DG-1032, page 5, lines 5-9, Sect B. The text states, "Thus, there is greater uncertainty in making judgments about the CEUS than there is for active plate margin regions, and it is important to account for this uncertainty by the use of multiple alternative models."

This sentence should be deleted because it is likely to be incorrect both probabilistically and deterministically. Probabilistic analyses have shown that the uncertainty at a given probability (say 10^{-6} median) for WUS sites is comparable or larger than that found for EUS sites. If a LLNL analysis were performed for an existing WUS site it is likely that the uncertainty would far exceed that shown for a typical EUS site. Furthermore, it would be prudent to exercise the LLNL methodology at a WUS site to confirm the adequacy/suitability of the probabilistic approach for WUS sites. Deterministically, there is great uncertainty concerning blind faults and subduction zone sources. In addition, not only is the process highly uncertain for the WUS, but it has yet to be demonstrated at a hypothetical EUS site.

Desired Change:

Delete this statement.

Response No. 13:

We agree with the comment and have deleted the statement. The last phrase has been made into a sentence that reads "Therefore, it is important to account for this uncertainty by the use of multiple alternative models."

Comment No. 14:

DG-1032, page 10, line 12, Sect B. The text states, "These seismic sources and their parameters should be used to judge the adequacy of the seismic sources and parameters used in the LLNL or EPRI PSHA."

Considering the recommended changes in Comment 8, this statement becomes meaningless. Hence, it is proposed to delete it.

Desired Change:

Delete this statement.

Response No. 14:

This part of the Regulatory Guide has been rewritten and the statement referenced in the comment has been deleted from the document.

Comment No. 15:

DG-1032, page 11, line 31, Sect 3. The text states, "The PSHA should only be updated if it will lead to higher hazard estimates."

More balance and discipline is needed in the process that determines if, and when, the PSHA should be updated to reflect new data than is indicated by this statement. The PSHA should not be updated solely based on new hazard data, rather based on sound technical basis.

Desired Change:

Revise to read: "The PSHA should only be updated if there is a strong technical basis supporting the validity of the new data."

Response No. 15:

The statement has been revised to: "The PSHA should only be updated if the new information indicates that the current version significantly underestimates the hazard and there is a strong technical basis that supports such a revision. It may be possible to justify a lower hazard estimate with an exceptionally strong technical basis. However, it is expected that large uncertainties in estimating seismic hazard in the CEUS will continue to exist in the future, and substantial delays in the licensing process will result in trying to address them with respect to a specific site. For these reasons the staff discourages efforts to justify a lower hazard estimate. In most cases, limited-scope sensitivity studies should be sufficient to demonstrate that the existing data base in the PSHA envelopes the findings from site-specific investigations. In general, significant revisions to the LLNL and EPRI data base are to be undertaken only periodically (every ten years), or when there is an important new finding or occurrence. An overall revision of the data base also requires a reexamination of the reference probability discussed in Appendix B and used in Step 4 below. Any significant update should follow the guidance of Reference 9.

Comment No. 16:

DG-1032, App A, page A-1, line 3, para 1. The text states, "In the probabilistic seismic..."

The procedure to determine probabilistic controlling earthquakes is described in detail and is clearly reproducible. On the other hand, deterministic controlling earthquakes are implied (see regulatory Position 4, par (1) of DG-1032), yet there is no parallel definition for the deterministic controlling earthquake. There is a need to clearly define how the staff will determine deterministic earthquakes; also the proposed process should be reproducible.

Desired Change:

Revise to read:

"As a result of the probabilistic seismic..."

Response No. 16:

The suggested wording has been incorporated into the definition. There is no longer a need to define a deterministic controlling earthquake or describe the process for determining its magnitude and distance. The staff is not required

to perform an independent deterministic seismic hazard analysis (see the response to Comment 8).

Comment No. 17:

DG-1032, App A, page A-1, line 19, para 5. Safe Shutdown Earthquake Ground Motion is defined as "the vibratory ground motion for which certain structures, systems and components would be designed ...to remain functional."

The ground motion should be noted to be in the free-field.

Desired Change:

Revise to read:

"The safe shutdown earthquake ground motion is the *free-field* vibratory..."

Response No. 17:

We agree. The term "free-field" has been inserted into the sentence.

Comment No. 18:

DG-1032, App A, page A-2, lines 26-29, para 6. Seismogenic Source is defined as "a portion of the earth that has uniform earthquake potential (same expected maximum earthquake and frequency of recurrence) distinct from other regions..."

"Earthquake potential" can have a misleading connotation. The proposed change suggests a more precise definition.

Desired Change:

Revise to read:

"A "seismogenic source" is a portion of the earth that has assumed uniform seismicity (same recurrence frequency) distinct from the seismicity of the surrounding regions..."

Response No. 18:

The sentence has been partially revised to read: "A "seismogenic source" is a portion of the earth that we assume has uniform earthquake potential (same expected maximum earthquake and recurrence frequency) distinct from the seismicity of the surrounding regions."

Comment No. 19:

DG-1032, App B, page B-2, line 18, Sect B.3.2. The text states, "Using an accepted methodology, calculate..."

The proposed revision should offer applicants the flexibility to use different methodologies, as long as they can be demonstrated to meet the intent of the regulatory guidance.

Desired Change:

Revise to read:

"Using LLNL, EPRI, or a comparable methodology, calculate.....".

Response No. 19:

The phrase has been revised to read "Using LLNL, EPRI, or a comparable methodology that is acceptable to the NRC staff, calculate____"

Comment No. 20:

DG-1032, App B, page 2, line 24, Sect B.3.2. The text states, "Calculate the median composite annual probability...".

The word "median" is deleted to be consistent with line 26 of DG-1032, Appendix B, page 2. Also it is prudent to de-emphasize the use of the word median. There is sufficient explanation to show that the composite probability is based upon medians.

Desired Change:

Delete the word "median"

Response No. 20:

The term "median" has been deleted.

Comment No. 21:

DG-1032, App C, page 1, line 16, Sect C.1. The text states, "A site specific response spectrum shape is determined..."

Rationale for not determining a site-specific spectrum:
If an ALWR is to be placed at an existing site, then the standardized ALWR spectrum is good enough and no further work should be required.

Desired Change:

Revise to read:

"A site specific response spectrum may be determined..."

Response No. 21:

A site specific response spectrum should be determined, even when a standard design plant is to be placed on a site, for the purposes of: (1) comparing it with the standardized ALWR spectrum, and (2) developing the seismic design

basis for other, nonstandardized safety related structures, systems and components.

Comment No. 22:

DG-1032, App C, page 1, line 20, Sect C.2. The text states, "Procedure to determine controlling earthquakes.."

The procedure provided in this section is inconsistent with the example given. In particular, the de-aggregation described in step 1 (page C-2) cannot take place before the de-aggregation ground motion level is determined, which is step 2.

Desired Change:

The example needs further clarification.

Response No. 22:

Steps 1 and 2 have been rewritten to clarify the procedure.

Comment No. 23:

DG-1032, App C, page 2, line 23, Sect C.2. The text states, "Steps 3 to 5 describe the procedure to develop the seismic hazard information base for each ground motion level determined in Step 2. This information base will consist of:

- Fractional contribution of each magnitude-distance pair to the total median seismic hazard.
- Magnitudes and distances of the controlling earthquakes.
- The ground motion levels for the spectral accelerations at 1, 2.5, 5, and 10 Hz defined in Step 2.
- The average of the ground motion levels listed above at the 1 and 2.5 Hz, $S_{a,1-2.5}$, and 5 and 10 Hz, $S_{a,5-10}$, spectral accelerations corresponding to the reference probability."

This explanation can be simplified, as indicated in the proposed change.

Desired Change:

Delete this whole paragraph. Replace it with Step 3 as follows:

"Step 3

Perform a complete PSHA, deaggregating in terms of magnitude and distance for each of the bins described in Table C.3."

Response No. 23:

As recommended, the referenced paragraph has been removed. The following statement has been labeled as Step 3 "Perform a complete probabilistic seismic hazard analysis for each of the magnitude-distance bins described in Table C.3."

Comment No. 24:

DG-1032, App C, page 3, lines 13-14, Sect C.2. The text states, "Step 3 Using the de-aggregated median hazard results from Step 1, at the ground motion levels obtained from Step 2 calculate the fractional contribution to the total median hazard of earthquakes in a selected set of magnitude and distance bins... The median annual probability of exceeding the ground motion levels calculated in Step 1 for each magnitude and distance bin and ground motion measure is denoted by H_{med} ."

The proposed revision, in conjunction with the changed recommended in Comment 23, makes the process sequentially correct.

Desired Change:

Revise to read:

"Step 4 Using the de-aggregated median hazard results from Step 3, at the ground motion levels obtained from Step 2 calculate the fractional contribution to the total median hazard of earthquakes in a selected set of magnitude and distance bins... The median annual probability of exceeding the ground motion levels calculated in Step 2 for each magnitude and distance bin and ground motion measure is denoted by H_{med} ."

Response No. 24:

The sequence is correct by changing Step 1 to Step 3 in the first line of step 4. The suggested modification has been made.

Comment No. 25:

DG-1032, App C, pages 4-5, lines 3 & 17 on Pages 4, 5, and 6, Sect C. The text provides steps 4, 5, and 6 on pages 4 and 5.

Steps 4, 5, and 6 are unnecessary for the rock sites. The basis for the proposed revision is recent knowledge gained concerning attenuation of ground motion in the EOS. Distant sources are only an issue at soil sites where amplification at low frequencies can be significant.

Desired Change:

Delete steps 4, 5, and 6 for the rock sites.

Response No. 25:

We do not agree with the recommended deletion.

Comment No. 26:

DG-1032, App C, pages 7-8, All, Tables C.3 & C.4. It would be helpful to an applicant to show a table of actual hazard values for each bin and the total hazard. This would help in understanding the overall process and the development of Table C.4.

Desired Change:

Develop table suggested.

Response No. 26:

Tables C.4-C.7, which show the hazard values corresponding to the ground motion levels defined in step 2 for the spectral acceleration at 1, 2.5, 5, and 10 Hz, have been added.

Comment No. 27:

DG-1032, App D, page 8, line 26, Sect. D.2.3.2.1. This item states, ".....and provide assurance that there are no significant sources of earthquakes within the site vicinity."

Although it is certainly an objective to demonstrate that there are no significant seismic sources within the site vicinity, the use of seismographic records during a period from site selection to finalization of staff review for combined license is not sufficient time to base conclusions on the results of such records.

Desired Change:

Delete this statement.

Response No. 27:

Your comment is correct. The statement gives more weight to seismic monitoring in accomplishing this objective than is warranted. Instead of deleting the statement we have reworded it to place seismic monitoring in its proper perspective as follows: "The data obtained by monitoring current seismicity will be used, along with the much larger data base acquired from site investigations, to evaluate site response and to provide information about whether there are significant sources of earthquakes within the site vicinity, or to provide data by which an existing source can be characterized."

Comment No. 28:

DG-1032, App D, page 1, line 1, Sect. D. Industry recommended changes to the distance associated with various regional and site studies are defined in earlier comments on the main body of DG-1032. See Comment Number 5.

Desired Change:

As stated in Comment Number 5

Response No. 28:

Based on the reasons described in our response to Comment Number 5, we haven't modified the distances specified for regional and site investigations.

Comment No. 29:

DG-1032, App D, page 8, lines 20-33, Sect D.3.2.2. For sites in the CEUS, a single large dynamic range, broad-band seismograph may be adequate. For sites in the Western United States, a network of at least five such seismographs would be deployed within 25 km (15 mi.) surrounding the site.

The primary purposes of seismic monitoring are to obtain data from distant earthquakes, to determine site response, and provide assurance that there are no significant sources of earthquakes within the site vicinity. For sites in the Western United States seismic monitoring could help locate any ongoing seismicity that may indicate capable faulting within the site vicinity.

Monitoring should be initiated up to five years prior to construction of a nuclear unit at a site and should continue for at least five years following initiation of plant operation.

Comment: - to expect data from distant earthquakes or to determine site response for a EUS site based on putting in a seismic network is unlikely.

Desired Change:

Revise to read:

"For sites in the Western United States, a network of at least five such seismographs would be deployed within 25 km (15 mi.) surrounding the site. For sites located in regions containing active seismographic networks, additional monitoring is not required. The primary purpose of seismic monitoring is to provide assurance that there are no significant sources of earthquakes within the site vicinity. For sites in the Western United States seismic monitoring could help locate any ongoing seismicity that may indicate capable faulting within the site vicinity. Monitoring should be initiated as soon as practicable at a site."

Response No. 29:

Relying on existing seismographs is not enough, unless one of these happens to be located at the site. Instrumentation is particularly important if water is to be impounded in a reservoir at the site. An effort should be made by an applicant to monitor seismicity at least five years before construction.

Subsection D.2.3.2.2 has been revised in the following manner: "Seismic monitoring in the site area should be established as soon as possible after site selection. For sites in both the CEUS and WUS, a single large dynamic range, broad-band seismograph, and a network of short period instruments to locate events should be deployed around the site area.

The data obtained by monitoring current seismicity will be used, along with the much larger data base acquired from site investigations, to evaluate site response and to provide information about whether there are significant sources of earthquakes within the site vicinity, or to provide data by which an existing source can be characterized.

Monitoring should be initiated as soon as practicable at the site, preferably at least five years prior to construction of a nuclear unit at a site and

should continue at least until the free field seismic monitoring strong ground motion instrumentation described in Regulatory Guide 1.12 is operational."

Comment No. 30:

DG-1032, App E, page 1, lines 1-22, Sect E.1. Updating of the input parameters to the seismic hazard analysis is inherently destabilizing to the licensing process. The reference probability is based upon results obtained from a consistent application of the LLNL methodology at all EUS sites. Application of the reference probability to an analysis that is inconsistent with the basis for the reference probability is inconsistent with the use of relative probabilities. Therefore, all source zones, attenuation models, and upper bound magnitudes should be frozen until they are again determined in a consistent manner. Seismicity parameters should be updated based upon use of a current earthquake catalog. Only if there is consensus within the scientific community supporting the validity of the new data should the data be updated. If the new data only has an impact on the site being evaluated (source zones) then a new reference probability need not be calculated. If the new data has a potential impact on all sites (new attenuation model) then the seismic hazard at all Table B.1 sites needs to be recalculated using the new attenuation model, and a new reference probability calculated.

Desired Change:

This discussion should be modified to include the admonition that input parameters are only subject to change after thorough review and consensus within the scientific community.

Response No. 30:

We agree that it should be revised if there is a strong technical basis supporting it. The new data will certainly be made available to the scientific community for its opinions. However, obtaining consensus of opinion from the scientific community is usually a very lengthy and tedious process and a decision will more than likely be needed before a consensus is reached (a consensus is not likely anyway). We will rely on discussions with knowledgeable scientists, the applicant and its consultants, the expertise of the staff and its consultants in evaluating the new technical information, and advice from the US Geological Survey in deciding whether the technical bases are strong enough to warrant a modification of the PSHA.

Beginning on line 19 of page E-1, the text has been modified to read: "if new information identified by the site specific investigations would result in a significant increase in the hazard estimate for a site, and this new information is validated by a strong technical basis, the PSHA may have to be modified to incorporate the new technical information."

In general, major recomputations of the LLNL and EPRI data base are planned to be undertaken periodically (approximately every ten years), or when there is an important new finding or occurrence that has, based on sensitivity studies, resulted in a significant change in the hazard estimate."

Comment No. 31:

DG-1032, App F, page 1, line 28, Sect F.2. The text states, "...the following three possible situations...."

The proposed revision provides consistency throughout DG-1032.

Desired Change:

Revise to read:

"...the following acceptable situations...."

Response No. 31:

We see no reason to revise this statement.

Comment No. 32:

DG-1032, App F, page 2, line 4, Sect F.2. The text states, "....site specific spectra."

The proposed addition provides consistency and coherency.

Desired Change:

Revise to add the following sentence at the end of the statement.
"In this case a site specific SSE is determined."

Response No. 32:

We see no reason to revise this statement.

Comment No. 33:

DG-1032, page 4, line 16, Sect B. The text states, "...that site should include:"

This proposed revision provides consistency.

Desired Change:

Revise to read:...at a site in general include:"

Response No. 33:

As suggested, "in general" has been inserted to replace "should" in this statement.

Comment No. 34:

DG-1032, App D, page 8, line 32, Item D.2.3.2.2. This item states, "....and should continue for at least five years following initiation of the plant operation."

The staff assessment of information on which to base a final conclusion of site suitability would have been completed before major plant construction is

advanced and certainly before the start of plant operation. Furthermore, the free field seismic monitoring instrumentation required by DG-1034 would be operational by the time of plant operation.

Desired Change:

Delete the last phrase in this statement.

Response No. 34:

The last phrase has been deleted and replaced with "until the free field seismic monitoring strong ground motion instrumentation described in Regulatory Guide 1.12 is operational."

Comment No. 53:

SRP 2.5.1, page 12, lines 8-9, Item IV. This item states, 'The evaluation determinations are made by the staff after the early site, construction permit, or operating license reviews. A similar conclusion....'

In the first sentence, it is unclear whether the phrase *evaluation determinations* refers to . If separate staff reviews are performed at construction permit and operating license stages, the staff evaluation based upon inspection of excavations would be performed during construction and prior to the operating license review, not after it. The phrase *similar conclusion* at line 9 is unclear in as much as a clear description of a conclusion does not precede this sentence.

Desired Changes:

These statements need clarify that a final staff determination is essential to establish a regulatory position on site suitability and relieve the applicant's exposure to regulatory uncertainty. The timely documentation of the staff's final conclusions after their inspection of site excavation for a combined license should be stressed.

Response No. 53:

Evaluation determinations refer to decisions by the staff regarding the geological and seismological suitability of the site. The subject paragraph has been revised to read: "The evaluation determinations with respect to the geological and seismological suitability of the site are made by the staff after the early site and construction permit reviews, and during the operating license reviews. A conclusion regarding an Operating License will include an evaluation of the excavations for Category 1 structures. A conclusion regarding the geological and seismological suitability of a site following a combined license review will be made when the applicant has committed to mapping excavations for Category 1 facilities and notifying the staff of their availability for examination. The staff will conduct this examination at the appropriate time after licensing to confirm that there are no previously unknown features, such as potentially active faults, evidence for strong ground motions such as late Quaternary seismically induced paleoliquefaction features, unsuitable soil zones, or cavities in the excavations."

Comment No 54:

SRP 2.5.2, All pages, lines 7-23 of Pages 8-9, Sect 2.5.2.4. General Comment: This SRP is the staff basis for a deterministic evaluation of controlling earthquakes. It is unclear how the source zone model based upon seismology and geology is to be used, e.g., controlling earthquakes based upon the probabilistic analysis or controlling earthquakes based upon a staff deterministic evaluation. Historically, determination of controlling earthquakes using deterministic methods has been extremely controversial. Also, the basis for determining the controlling earthquake is interpretive and non-quantitative.

More specifically, Section 2.5.2.4 states, "The staff will review the applicant's probabilistic seismic hazard analysis, including the underlying assumptions and how the results of the site investigations and findings of Sections 2.5.2.2 and 2.5.2.3 are used to update the existing sources in the probabilistic seismic hazard analysis. The staff will perform an independent evaluation of the earthquake potential associated with each seismic source that could affect the site. The staff will evaluate the applicant's controlling earthquakes based on historical and paleo-seismicity. In this evaluation, the controlling earthquakes for each source are at least as large as the maximum historic earthquake. The staff will review the controlling earthquakes and associated ground motions at the site derived from the applicant's probabilistic hazard analysis to be sure that they are either consistent with the controlling earthquakes/ground motions used in licensing of (a) other licensed facilities at the site, (b) nearby plants or (c) plants licensed in similar seismogenic regions, or the reasons they are not consistent are understood."

This paragraph describes the independent review the staff will conduct with respect to the seismic sources that are used in the PSHA and SSE determination. The review will look at the controlling earthquake for each seismic source, yet once the controlling earthquake for each seismic source is reviewed, it is not clear how this section will be used. The DG-1032 process does not require, nor should it require, an applicant to determine a controlling earthquake for individual seismic sources.

The controlling earthquake for each seismic source will be compared to the maximum historical event to see if it is at least as large. This acceptance criterion for the source specific controlling earthquake is inappropriate, because it is a criterion that has no relationship to the probabilistic assessment and the manner in which the controlling earthquake is determined. Furthermore, it is an unnecessary conservatism that as a matter of routine NRC staff practice should not be added to the seismic siting process.

This paragraph concludes by saying that the controlling earthquake and the SSE determined from the PSHA will be compared to the SSE and controlling earthquakes for units that have already been licensed at or near the site being considered. The reasons for any inconsistencies will be considered. It is important to recognize, if the SSE were to be evaluated using the procedure described in DG-1032 at each existing plant site, a comparison would conclude that at approximately one-third of the sites the existing SSEs are higher than the value determined using the proposed procedure. This is inherent to the process.

The above being the case, the reason for comparison and the action that might be taken by the staff (e.g., reject the DG-1032 result) is not clear. The net result of this paragraph is open ended flexibility in the NRC staff review with a process that is foreign to the PSHA approach recommend in DG-1032.

Conversely, the SRP provides no guidance relative to reviewing the PSHA performed by the applicant in order to assess its adequacy.

Desired Change:

Suggest clarification of this Section such that the review process can be efficient and reproducible. For example, (1) when NRC staff performs an independent evaluation of the earthquake potential associated with each seismic source, it is not clear if these are the probabilistic sources or the sources based upon the model, (2) can the staff provide examples or description of how this evaluation is performed, and (3) can the staff define what a deterministic controlling earthquake is and how it is determined.

Response No. 54:

The following text now comprises Subsection 2.5.2.4:

For the CEUS sites relying on LLNL or EPRI methods, the staff will review the applicant's probabilistic seismic hazard analysis, including the underlying assumptions and how the results of the site investigations are used to update the existing sources in the probabilistic seismic hazard analysis, how they are used to develop additional sources, or how they are used to develop a new data base.

The staff will review the controlling earthquakes and associated ground motions at the site derived from the applicant's probabilistic hazard analysis to be sure that they are either consistent with the controlling earthquakes/ground motions used in licensing of (a) other licensed facilities at the site, (b) nearby plants, or (c) plants licensed in similar seismogenic regions, or the reasons they are not consistent are understood. For the CEUS, a comparison of the PSHA results can be made with the information included as Table 1, which is a very general presentation based on technical information developed over the past two decades of licensing nuclear power plants.

The applicant's probabilistic analysis, including the derivation of controlling earthquake, is considered acceptable if it follows the procedures in Regulatory Guide 1.166 and its Appendix C (Ref. 9). The incorporation of results of site investigations into the probabilistic analysis is considered acceptable if it follows the procedure outlined in Appendix E of Regulatory Guide 1.165 and is consistent with the review findings of Sections 2.5.2.2 and 2.5.2.3.

For the sites not using LLNL or EPRI methods, the staff will review the applicant's PSHA or other methods used to derive controlling earthquakes. The staff will particularly review the approaches used to address uncertainties. The staff will perform an independent evaluation of the earthquake potential associated with each seismic source that could affect the site. The staff will evaluate the applicant's controlling earthquakes based on historical and

paleo-seismicity. In this evaluation, the controlling earthquakes for each source are at least as large as the maximum historic earthquake.

Comment No. 55:

SRP 2.5.2, Page 7, line 14, Sect 2.5.2.3. The text states, "The applicant's presentation is accepted when the earthquakes discussed in Subsection 2.5.2.1 of the SAR are shown to be associated with either ~~geologic structure or tectonic province~~ seismic sources."

It is not clear how an applicant knows that an earthquake is associated with a seismic source other than the fact that the earthquake occurred within the source.

Desired Change:

Delete the statement.

Response No. 55:

The statement has not been deleted because this activity is still considered an important aspect of the site evaluation procedure.

Comment No. 56:

SRP 2.5.2, page 6, lines 6 & 9, Sect 2.5.2.2. The text states, "...This subsection is accepted when all seismic sources that are significant..."

Also the text on line 9 states "...reasonable assurance that all significant..."

It is impossible to know all seismic sources.

Desired Change:

Replace the word "all" with "known". It would be helpful to clarify the difference between a "seismic source" and a "seismotectonic province", if any.

Response No. 56:

The entire paragraph has been replaced, therefore "all" and "reasonable assurance" are no longer in the text. The definition of seismogenic source, which is a seismic source that is not expected to cause surface faulting, is given in Regulatory Guide 1.165, Appendix A, on page A-2. Seismotectonic province is defined as a seismogenic source that is a large region of diffuse seismicity thought to be characterized by the same earthquake recurrence model.

Comment No. 57:

SRP 2.5.2, page 10, line 1, Sect 2.5.2.5. The text states, "In the PSHA procedure described in DG-1032 (Ref. 5), the controlling earthquakes are determined for actual or hypothetical rock conditions. The site amplification studies are performed in a distinct separate step as a part of the determination of the SSE."

Desired Change:

Delete the phrase, "in a distinct separate step".

Response No. 57:

In DG 1032 (Regulatory Guide 1.165) and Appendix C the application studies are presented as a distinct step, so the phrase should be left in.

Comment No. 58:

SRP 2.5.2, page 11, lines 27-33, Sect 2.5.2.6. This Section states, "As part of the review to judge the adequacy of the SSE proposed by the applicant, the staff performs an independent evaluation of ground motion estimates, as required. In these independent estimates, the staff may consider effects on ground motion from the controlling earthquakes discussed in Subsection 2.5.2.4 by assuming the controlling earthquakes for each seismic source (geological structures or seismotectonic provinces) to be at its closest approach to the site."

This paragraph continues to overemphasize a deterministic process for assessing the adequacy of the SSE derived from the PSHA procedure described in DG-1032. In our opinion it is inappropriate to make an assessment of the SSE in this manner or to use this procedure as a means to assess the adequacy of the SSE determined using the DG-1032 process.

The text does not describe how the procedure will be implemented. For example, for the host seismic source, where is the controlling earthquake (which is at least as big as the maximum historic event) located?

Desired Change:

This Section needs clarification for consistency and reproducibility of the process. As a minimum, the text should be expanded to clarify how the procedure will be implemented.

Response No. 58:

All of the text that referred to an independent deterministic seismic hazard analysis has been revised. Also see the response to Comment 54.

Comment No. 59:

SRP 2.5.2, page 16, line 8, Sect III. This item states, "...borings, geophysical data, trenches, and those geologic conditions exposed during construction if the review is for an operating license."

The change as suggested would indicate that staff site visits can be performed to inspect trenches excavated prior to a combined license, or to inspect the geologic conditions exposed during construction (after the COL, at the option of the applicant). With the new combined license process, either approach should be permitted in order for the staff to reach a final conclusion. But, as indicated in the comment on SRP, page 2.5.3-9 lines 29-32, a final staff conclusion should not be deferred until the time of construction excavation if an inspection of trenches is performed during the review preceding a combined license.

Desired Change:

Revise to read:

"...borings, geophysical data, trenches, or those geologic conditions exposed..."

Also delete the phrase, "if the review is for an operating license."

Response No.59:

Examination of exploratory trenches by the staff during site investigations does not preclude the necessity for the staff to examine the final excavations for the plant. See Response to Comment 53. The phrase, "if the review is for an operating license." has been deleted.

Comment No. 60:

SRP 2.5.2, page 2, line 4, para 1. The text states, "SSE represents the potential for earthquake ground motion at the site and is the vibratory ground motion for which certain structures, systems, and components are designed to remain functional."

The word *potential* typically is associated with maximum, maximum credible, etc. This can be linked to the probabilistic upper bound. In this context, the word *design* is a better choice.

Desired Change:

Revise to read:

"The SSE represents the ~~potential for design~~ earthquake ground motion at the site and is the vibratory ground motion for which certain structures, systems, and components are designed to remain functional."

Response No. 60:

The words "potential for" have been deleted from the statement and "design" added as suggested.

Comment No. 61:

SRP 2.5.2, page 2, lines 16-26, para 3. The text states, "Guidance on seismological and geological investigations is being developed in Draft Regulatory Guide DG-1032, "Identification and Characterization of Seismic Sources and Determination of Safe Shutdown Earthquake Ground Motion." These investigations describe the seismicity of the site region and the correlation of earthquake activity with seismic sources. Seismic sources are identified and characterized, including the rates of occurrence associated with each seismic source. All seismic sources that have any part within 320 km (200 miles) of the site must be identified. More distant sources that have a potential for earthquakes large enough to affect the site must also be identified. Seismic sources can be capable tectonic sources or seismogenic sources; a seismotectonic province is a type of seismogenic source.

The wording implies a rate of occurrence of seismic sources. It is more correct to state the rate of occurrence of earthquakes. It is impossible to know when one has identified all source zones and included all seismic sources have been included.

Desired Change:

Revise to read the following "... including the rates of occurrence of earthquakes associated with each seismic sources that have any part within 200 km (125 miles) ..."

Response No. 61:

The distance of 320 km (200 mi) will not be changed. See response to Comment 5.

The subject paragraph has been modified and appears in the SRP as follows:

"Guidance on seismological and geological investigations is provided in Regulatory Guide 1.165, "Identification and Characterization of Seismic Sources and Determination of Safe Shutdown Earthquake Ground Motion." These investigations describe the seismicity of the site region and the correlation of earthquake activity with seismic sources. Seismic sources are identified and characterized, including the rates of occurrence of earthquakes associated with each seismic source. Seismic sources that have any part within 320 km (200 miles) of the site must be identified. More distant sources that have a potential for earthquakes large enough to affect the site must also be identified. Seismic sources can be capable tectonic sources or seismogenic sources; a seismotectonic province is a type of seismogenic source."

Comment No. 62:

SRP 2.5.3, page 9, line 3, Sect III. This item states, " This procedure could create a problem for the staff in that the applicant could already have a license"

As written, the statement illustrates the potential difficulty that may arise with a Combined Operating License approach. That is, site excavation occurring preceding the staff's final suitability determination.

Desired Change:

The statement should be reworded to more explicitly state how to disposition the issue, e.g., by inspection of the foundation excavation(s) followed by final determination of site suitability by the staff.

Response No. 62:

In response to this comment and Comment 64, the referenced paragraph now beginning on line 9, page 2.5.3-9 and ending on line 23 has been rewritten as follows:

"The current two-step procedure of requiring applicants to obtain a Construction Permit, followed several years later after the plant design bases have been approved by the staff, by application for an Operating License. This procedure, called combined licensing, could create a problem for the staff in that the Safety Evaluation Report will already have been written and the applicant will have a license before excavations are started. Therefore, faults discovered for the first time in the excavations will not have been evaluated by the staff. To alleviate this potential problem there must be a commitment in the site specific portion of the SAR for a facility to: (1) notify the staff immediately if previously unknown geologic features that could represent a hazard to the plant are encountered in the excavation; (2) geologically map all excavations for Category 1 structures, as a minimum; and (3) notify the staff when the excavations are open for examination.

Comment No. 63:

SRP 2.5.3, page 9, lines 29-32, Sect III. This item states, "applicants usually excavate trenches....when the construction excavations are made."

Unless it is intended that such trenching would precede a COL permit and supplant the need for any later staff inspection of construction excavation to reach a final determination, it is inappropriate to speculate on whether the applicants will or will not excavate trenches in the areas where major facilities are to be located.

Desired Change:

Delete this whole sentence, lines 29 through 32.

Response No. 63:

The main purpose of the SRP is to provide guidance to the regulatory staff in assessing information submitted in support of applications for licenses to construct or operate nuclear power plants. It is appropriate to make the staff aware of the kinds of investigations that will be undertaken to obtain the information that appears in that application, particularly when it may be important for the staff to go to the site for first hand observations. As stated in Response No. 59, examination by the staff of exploratory trenches does not supplant the need for the staff to examination the excavations for the plant.

However, we agree that it is not appropriate to speculate about the techniques that might be used. The sentence has been reworded: "In past investigations applicants have often excavated trenches in the areas where major facilities are to be located for in situ testing to reduce the chance for surprises when the construction excavations are made."

Comment No. 64:

SRP 2.5.3, page 9, line 7, Sect III. This item states, "It is imperative that Section 2.5.3. of the SER..."

It is understood that the SRPs provide guidance to the staff and is generally followed. Therefore, the word 'imperative' adds unnecessary emphasis.

Desired Change:

Delete the word "imperative"

Response No. 64:

We agree. The sentence will be revised (without "imperative") as it appears in the revised paragraph in Response No. 62.

Wais and Associates - Comments on Draft Regulatory Guides, DG-1032, SRP 2.5.1, 2.5.2, and 2.5.3.

1. Page 7, lines 15 to 19. Appendix A of Draft Regulatory Guide DG-1034 (now called Regulatory Guide 1.166) proposes an OBE criteria of a Richter 5 earthquake within 200 km of the site. Rightly so, earthquakes farther than 200 km from the site are not given a high importance. To ensure consistency between DG1034 and DG1032, it is recommended that the outer bound of regional geological and seismic investigations also be limited to 200 km, or 125 miles. This can significantly reduce the cost of the investigation without reducing the level of safety that is achieved.

Response:

It is not appropriate for the OBE distance criteria specified in DG 1034 (Regulatory Guide 1.166) and the radius of the area to be investigated for determining the SSE described in DG 1032 (now called Regulatory Guide 1.165) to be the same. They are for different magnitude earthquakes and levels of ground motions.

The reason for specifying a radius of 320 km (200 mi) for the regional investigations is not only to ensure that the area of study be broad enough to encompass those seismic sources close enough to affect the site, but also, because the CEUS is relatively aseismic and sources are at depth and largely undefined, it is our opinion that the area should be as large as reasonably possible to include a greater number of earthquakes for analysis, and to incorporate any sources identified that could be related to, or analogous to sources that may be near to or underlie the site.

In the past it has often been necessary to estimate the age of a potential seismic source, or potential capable fault in the site vicinity by relating its time of last activity to that of a similar, previously evaluated structure, or a known tectonic episode the evidence of which may be many tens or hundreds of miles away.

Within this area (320 km), assessment should be made of existing regional seismological, geological, geophysical, remote sensing, physiographic, and other information that could be used to identify or interpret potential seismic sources. It is not expected to be a detailed investigation, and may consist of only literature study with limited, focussed ground truth reconnaissances.

2. Page 11, lines 28 to 29. It is not clear why the PSHA should only be updated if it lead to higher hazard estimate. If there is a sound basis for reducing the PSHA, this should not be precluded by regulation.

Response:

It may be possible to justify a lower hazard estimate with an exceptionally strong technical basis. However, it is expected that large uncertainties in estimating seismic hazard in the CEUS will continue in the future, and substantial delays in the licensing process will result in trying to justify a

lower value than with respect to a specific site. On the other hand, lower seismic hazard estimates that are supported by strong technical bases can be incorporated into the PSHA during the periodic updating which will occur about every ten years.

The referenced statement in DG 1032 (Regulatory Guide 1.165) has been modified as follows: "The PSHA should only be updated if the new information indicates that the current version significantly under estimates the hazard and there is a strong technical basis that supports such a revision. For most cases, limited scope sensitivity studies should be sufficient to demonstrate that the existing data base in the PSHA envelops the findings from site-specific investigations. In general, the significant revisions to the LLNL and EPRI data base is to be only undertaken periodically (every ten years), or when there is an important new finding or occurrence. The overall revision of the data base will also require a reexamination of the reference probability discussed in Appendix B and used in Step 4 below."

3. Page 13, line 28. A fifth step should be added to this procedure to define an SSE level for which it is not necessary to conduct a seismic design. The process as now written results in an SSE, no matter how small. It is conceivable for sites in the eastern United States that the SSE that results from this process will be very small. There should be some small SSE level for which it is not necessary to design for. Note that in DG 1034, a criteria is provided in the appendix that states that earthquakes of less than MMI VI do not require any shutdown for inspection if there is no apparent damage. If this is the case, does a site with an equivalent to a MMI of VI or less require seismic design?

Response:

Seismic hazard estimates are based to a large extent on historic seismicity, and because of this in certain regions such as Florida and southeastern Texas the calculated Safe Shutdown Earthquake ground motions (SSE) are lower than ground motions expected to be generated by a magnitude 4.5 to 5 (MMI VI) earthquake. This may be because the historical seismic record is not long enough to have experienced larger earthquakes, and it is difficult to identify geological evidence of prehistoric earthquakes in these regions. Additionally, the sources of the earthquakes are undefined. Because of such uncertainties the staff requires a minimum seismic design even in those regions that do not seem to require it based on the seismic hazard analysis.

Appendix A:

1. The definition of the Safe Shutdown Earthquake Ground Motion in this draft Regulatory Guide is almost indistinguishable from the definition of the Operating Basis Earthquake Ground Motion in DG-1033. Given the adoption of PSHA methods, a likelihood should be assigned to the SSE, such as 1 in ten-thousand in any given year; or it should be defined as the largest earthquake that has been felt at the site in the last 50,000 years (see the definition of a capable tectonic source).

Response:

The definitions of the SSE and OBE are essentially unchanged in the revised regulations and guides from those in Appendix A to 10 CFR Part 100. The SSE (Safe Shutdown Earthquake ground motion) target probability, which is acceptable to the staff to be used in conjunction with the LLNL and EPRI PSHA, is $1E-5$ /yr as described in Step 3 of Appendix B to Regulatory Guide 1.165 (formerly DG 1032). It is not appropriate to put that value in the definition of SSE because some applicants may elect to use other acceptable hazard techniques to which that criterion would not apply, including a deterministic seismic hazard analysis. Appendix A to 10 CFR Part 100, Section 100.23 of Part 100, and Appendix S to 10 CFR Part 50 all establish a minimum seismic design level. It has long been a part of the licensing process.

Appendix B

1. The logic for arriving at the reference probability is flawed. Although it is descriptive of how the NRC arrived at a reference probability of $1E-5$ for the SSE, it does not add significantly to the Regulatory Guide. It is clear that the NRC has licensed plants in the CEUS with SSE ranging in likelihood from $1E-6$ to $1E-4$ and that a value of $1E-5$ is consistent with past practices. The question that is not answered is whether the use of $1E-5$ imposes an unreasonable and imprudent burden on the construction of nuclear plants. Note that many of the plants in the $1E-6$ range were forced to assume an SSE of 0.1g by 10 CFR Part 100 Appendix A even though the geology of the region dictated that the value was very conservative. If these plants had selected a lower SSE, their probability would have been higher and the median value would have been greater than $1E-5$. Are plants in the Western United States also licensed for an SSE likelihood of $1E-5$? Should there be a different standard for eastern US versus the western US?

Average past practice does not appear to be a reasonable basis for selecting a design earthquake. What is reasonable is to select a level of risk that is acceptable to the public and is consistent with other risks the public accepts. If that level of risk is $1E-5$ then so be it. However, if we consider that ice ages occur every ten thousand years, then $1E-4$ appears to be a more prudent level of risk than $1E-5$.

Suggest deleting this appendix once a level of risk is established. The acceptable level of risk should not be revised based on changes individual plants implement, as is stated on page B-1, lines 19 to 20.

Response:

See the response to a similar comment by Morgan, Lewis, and Bockius. The $1E-5$ is based on the likelihood of exceedance of the SSE's of operating plants built later on (those designed to RG 1.60 or to a similar spectrum) than those previously designed. We do not regard $1E-5$ as being unreasonable or imprudent based on the uncertainties in seismicity, seismic sources and ground motion parameters; nor do we regard that it is placing an unreasonable burden on future builders of nuclear power plants. It is true that several plants had to be designed for an SSE exceedance probability of $1E-6$ even though there was

no seismic or geologic evidence supporting it. As explained in the response to an earlier comment, the minimum value of 0.1g is a conservatism based on the seismic and geologic uncertainties. Western and eastern U.S. plants are not presently designed to the same likelihood of SSE exceedance because deterministic hazard analyses were done in both regions, and the empirical database is much more extensive in the west than in the east. For this reason an additional layer of conservatism was applied to eastern sites.

Publicly accepted levels of risk vary with the type of hazard. For example, it will accept a much higher risk of an automobile accident or an airplane crash than for a nuclear accident. It isn't reasonable to compare the return of an ice age to earthquake occurrence. To prepare for the resumption of glaciation, one will have hundreds or thousands of years, but for an earthquake there is no lead time.

The NRC staff and the nuclear industry at large are of the opinion that the current PSHA database for LLNL and EPRI will be adequate for the next ten years. When it is time for the first routine update of the PSHA database in about ten years, the acceptable level of risk will be revised based on new geological, seismological, and geophysical information and on changes individual plants implement. This update is considered to be necessary because of the rapid advances that are occurring in these scientific fields.

Appendix D

1. Page D-8, lines 31 to 33. It is unreasonable to assume that seismic monitoring should be initiated five years prior to construction and should continue for five years following initiation of plant operation. Note that DG1033, DG1034, and DG1035 talk about seismic monitoring over the life of the plant. It is unlikely that a licensee will be interested in updating the seismic design bases following issuance of the construction permit.

Response:

Section D,2.3.2.2 has been modified to: "Seismic monitoring in the site area should be established as soon as possible after site selection. For sites in both the CEUS and WUS, a single large dynamic range, broad-band seismograph, and a network of short period instruments to locate events should be deployed around the site area.

The data obtained by monitoring current seismicity will be used, along with the much larger data base acquired from site investigations, to evaluate site response and to provide information about whether there are significant sources of earthquakes within the vicinity, or to provide data by which an existing source can be characterized.

Monitoring should be initiated as soon as practical at the site, preferably at least five years prior to construction of a nuclear unit at the a site and should continue at least until the free field seismic monitoring strong ground motion instrumentation described in Regulatory Guide 1.12 is operational."

Monitoring seismicity for five years before construction is not considered to be unreasonable by the staff if the site is instrumented shortly after a site is selected. We regard seismic monitoring to be an important part of the site investigations. It is expected to provide information on background seismicity, seismic sources, the characteristics of ground motions from nearby small to moderate earthquakes, more distant large events, and those generated by other mechanisms such as nearby quarry blasts, and provide important data on the ground motion transmission characteristics of site area soils and rocks. Preconstruction monitoring is especially important in the western U.S., where, because of the relatively high seismicity, there is a good chance of recording ground motions from a significant earthquake. It is also important in the central and eastern U.S. where there are numerous uncertainties about ground motion characteristics and little is known about the nature of seismic sources. The analysis of locally recorded earthquakes may help to reduce these uncertainties and provide clues to the nature of seismic sources.

Pre-construction seismic information would have been valuable in past licensing activities (for example: Diablo Canyon, San Onofre, Indian Point, Brunswick, Summer, Oconee, WNP-2, etc.), and is expected to be important in the licensing of future nuclear sites.

These responses also apply to the appropriate SRP Sections.

Westinghouse - Comments on Proposed Rule - 10CFR Parts 50,52, and 100,
"Reactor Site Criteria Including Seismic and Earthquake Engineering Criteria
for Nuclear Plants"

Seismic

COMMENT No. 1: Westinghouse supports NRC's decision to move guidance material from the proposed rule to the proposed regulatory guides. We also support NRC's decision to eliminate the "dual deterministic and probabilistic analyses from the proposed rule. We, however, are concerned that retaining deterministic evaluations in SRP 2.5.2 will lead to confusion as to whether future licenses will also need to perform a deterministic analysis even though such an analysis is only recommended for NRC to perform as a "sanity" check. This additional deterministic analysis will add to instability in the licensing process and increase a future license applicant's seismic analysis costs (in defending its probabilistic analyses) without any additional benefit to public health and safety. We recommend that references to deterministic analyses be removed from all documentation associated with the proposed rule revision.

Response No. 1:

SRP 2.5.2 has been revised and this concern has been addressed.

COMMENT No. 2: Westinghouse shares NEI's concern with respect to the type of analyses needed to construct a new plant on an existing approved site, using the proposed rule and associated proposed regulatory guides. We also believe that site characterization analysis for existing sites should be confirmatory in nature and of "limited scope," rather than "full scope" as required for new sites.

Response No. 2:

It is possible that site characterization investigations and analyses at some previously validated sites will be confirmatory. Reliance on the previous characterization depends on its thoroughness, the kinds of investigative techniques used as compared to the current state-of-the-art, the geological and seismological complexity of the site and region, and the quantity and quality of new information and hypotheses that have been advanced since the site was last studied. The previous information should be used as part of the database, along with other available technical information, to plan the extent and level of detail of the new investigations for the new plant site. Based on consideration of all available information the new investigations could range from confirmatory to a very extensive investigation.

An example is the Indian Point 1, 2, and 3 site. Indian Point 1 was investigated in the 1960's when investigative methods were far less advanced than in the mid 1970's when units 2 and 3 came in for operating licenses. Because of the complexity of the site and region, the occurrences of several earthquakes, new theories about the tectonics of the region, and new

investigative techniques, site characterization with respect to estimating the seismic hazard was similar to that of a new site.

On the other hand, if, within the next year or so a Unit 4 is planned at this site, the regional investigations would likely be minimal because thorough investigations, including monitoring seismicity for a number of years, was accomplished for Units 2 and 3.

COMMENT No. 3: There are several phrases that are used in the proposed rule that should be modified to make the rule more stable from a licensing point of view. Since these phrases are used in several places, only the phrase, and not the location, are identified below. We suggest that these phrases and others that are similar in nature be modified as well.

- (1) "certain structures, systems, and components" should read: "certain structures, systems, and components as identified in Regulatory Guides xxx." By referencing the regulatory guides, the vagueness of the statement is eliminated from the rule and the description of the structures, systems, and components can be changed, if necessary, via changes to the regulatory guides.

Response No. 3(1):

Reference to a specific guide in the regulation would raise the guide to the status of a regulation, and its recommendations would be required by law. Therefore, such references cannot be included in the rule.

- (2) "without loss of capability to perform their safety functions" should read: "without loss of capability to perform their intended functions." The components perform a function and not a "safety" function -- components may be a part of a safety system or a non-safety system. There are other sentences which have similar phraseology -- for example, item 3 below. These sentences should be similarly modified.

Response No. 3(2):

The structures, systems, and components referred to in these texts are those that have to do with safe shutdown in the event of an accident or potential accident caused by an earthquake or surface deformation. It is therefore correct to have the word "safety" in the statement.

- (3) "The required safety functions of structures, systems, and components must be assured" should read: "The required functions of structures, systems, and components must be assured per the guidance provided in Regulatory Guide xxx". The underlined phrase shows that the regulatory guide contains guidance as to how a future license applicant can provide "assurance."

Response No. 3(3):

See response to 3(1). References cannot be included in the proposed rule because the guide referenced would become a requirement.

As stated in the response to 3(2), the word "safety" should remain in the text as is.

Responses to Comments of Yankee Atomic Electric Company Regarding the NRC
Proposed Seismic Siting Documents (59FR52255, October 17, 1994)

Attachment 1

YAEC proposes that at existing eastern U.S. sites (rock or soil), or at eastern U.S. rock sites not located in areas of high seismicity (for example, Charleston, South Carolina, New Madrid, Missouri, Attica, New York) a 0.3g standardized ALWR design is acceptable and only evaluations of foundation conditions at the site are required (Regulatory Guide 1.132), but not geologic/geophysical seismological investigations. For other sites a DG-1032 review is required. It proposes that 10CFR Part 100 Section 100.23 be modified to reflect this consideration as follows:

& 100.23 (d) Geologic and seismic siting factors.

Determination of the Safe Shutdown Earthquake Ground Motion. The Safe Shutdown Earthquake Ground Motion for the site is characterized by both horizontal and vertical free-field ground motion response spectra at the free ground surface. ~~The Safe Shutdown Earthquake Ground Motion for the site is determined considering the results of the investigations required by paragraph (c) of this section. Uncertainties are inherent in such estimates. These uncertainties must be addressed through an appropriate analysis, such as a probabilistic seismic hazard analysis or suitable sensitivity analyses. Paragraph IV(a) (1) of Appendix S to Part 50 of this chapter defines the minimum Safe Shutdown Earthquake Ground Motion for design.~~

The Safe shutdown Earthquake Ground Motion for the site is based upon the investigations required by paragraph (c) of this section and the results of a probabilistic seismic hazard analysis. Seismological and geologic uncertainties are inherent in these determinations and are captured by the probabilistic analysis. Suitable sensitivity analyses may also be used to evaluate uncertainties. Paragraph IV(a) (1) of Appendix S to Part 50 of this Chapter defines the minimum Safe Shutdown Earthquake Ground Motion for design. Based upon prior scientific findings and licensing decisions at existing nuclear power plant sites east of the Rocky Mountain Front (east of approximately 105 west longitude) a 0.3g Standardized design level is acceptable at these sites given confirmatory foundation evaluations. For rock sites not in areas of known seismic activity including but not limited to the regions around New Madrid, MO, Charleston, SC, and Attica, New York, a 0.3g Standardized design level is acceptable given confirmatory foundation evaluations at the site.

Response to attachment 1:

Although some of the suggested wording may improve the readability of the text, the staff does not agree with the basic philosophy of the recommended modification for the following reasons:

1. The suggested modification brings back a prescriptive element which we have tried to eliminate in revising the siting document. It is more

appropriate to include such a modification in Regulatory Guide 1.165 (formerly DG 1032). The staff's position regarding the application of the 0.3g ALWR design is addressed in the main body of Regulatory Guide 1.165, and in Appendix D.

2. A standard design of 0.3g does not preclude the need to conduct a thorough regional and site area investigation. The standard plant is designed for 0.3g, but other safety related components aren't part of the standard design plan. Such components include emergency cooling ponds and associated dams levees, spillways, etc., and they will have to be designed to the appropriate level based on regional and site geological, seismological, geophysical, and geotechnical investigations and site specific PSHA.

3. The level of investigations for a standard design plant or any additional unit sited on a previously validated site depends on when that site was previously validated, the complexity of the geology and seismology of the region and site, the advent of new information or hypotheses about regional tectonics, and the kinds of methods used and the thoroughness applied in using those methods in the original investigations and analyses. The investigations can range anywhere between a literature review to a very extensive investigation program.

4. The discovery of the Meers Fault and the paleoseismic evidence for a large prehistoric earthquake in the Wabash Valley are examples in the central and eastern U.S. of the occurrences of events of great significance to the seismic hazard to those regions that were unknown until regional investigations were performed. Thus, we expect that evidence for similar, currently unknown tectonic structures or events is present in the CEUS.

Based on the above factors, the level of investigations could vary considerably, therefore, it would be inappropriate to make the modifications recommended in Attachment 1.

Attachment 2. (DG 1032 and Appendices)

1. Page 1, lines 27-31. YAEC suggests that they be replaced by page 2, lines 1-6 to be consistent with Section 100.23. Since the staff doesn't agree with the recommended change in Section 100.23, there is no need to alter this text.

2. Page 2, lines 15 and 16. YAEC recommends adding the phrase, "level that is acceptable to the staff.", to the first sentence in the paragraph, and replacing the word "information" with "data" in the next sentence. We agree that the first suggested revision improves the text and have made the recommended changes. In regard to the second part of this comment we don't agree. Many times the broader term, information, is more appropriate, such as when it includes reference to interpretations or hypotheses, etc. The word "data" in this case is too restrictive.

3. Page 3, lines 6-9. Recommends changing the text to be consistent with its suggested changes to Section 100.23. The staff has made the suggested changes in the text.

4. Page 3, lines 19 and 20. We did not delete "uncertainty" but added the suggested phrase "(alternative scientific interpretations)" in parentheses.

5. Page 4, lines 14 and 15. The comment has to do with the basic difference in philosophies between the YAEC and the staff. We don't agree with the comment, however, we have modified the text by replacing "should" with "in general includes:".

6. Page 4, lines 37-40 and page 5, lines 1-10. We agree with the comment, and have deleted the sentence beginning with "Thus.....", and have added the statement "Therefore, it is important to account for this uncertainty by the use of multiple alternative models."

7. Page 5, line 24. We regard "information" as being more appropriate than "data." See the response to 2.

8. Page 6, lines 29-41, and page 7, lines 1 and 2. The comment involves the differences in philosophies between the YAEC and the NRC, and the recommended change was not adopted regarding Section 100.23 to 10 CFR Part 100. Therefore, there is no need to make this change.

9. Page 7, lines 16, 17, 20, 24, and 31. The NRC staff does not agree with the radius of investigations for the region and the site area prescribed by the IAEA, and therefore is not obligated to make those specified in Regulatory Guide 1.165 consistent with those of the international organization.

Although recent evidence indicates that a site at distances greater than 200 km from a major earthquake are not likely to experience damaging ground motions, and seismic sources beyond 40 km are not likely to generate near-field ground motions or cause surface deformation at the site, there are other reasons for specifying the greater distances (320 km and 40 km as opposed to 200 km and 25 km of IAEA).

The reasons that we do not plan to reduce the larger radii include:

1. In the CEUS where earthquakes are few, small, and relatively far between, the larger area of consideration allows that more earthquakes be included in the applicant's catalogue for consideration, and thus provides a broader data base with which to study the regional seismicity and to characterize regional and local seismic sources.

2. In past licensing activities, particularly in the CEUS, it has often been impossible to determine the absolute age of most recent displacements on faults identified at sites and thus difficult to show whether those faults met the criteria of being noncapable. To compensate for this lack of evidence, it has been necessary to assess the relationship between the structural geology and tectonics of the site and the regional structural geology and tectonics, often many tens to hundreds of kilometers distant. In these cases, associating the faults identified at the site with documented ancient faults or tectonic events in the region served as a basis for concluding that the site faults were not capable faults.

3. In the WUS it has sometimes been necessary to extend investigations hundreds of kilometers along major tectonic structures that pass near a site to properly characterize the seismic hazard of those structures (i.e. the San Gregorio-Hosgri fault zone relative to the Diablo Canyon Nuclear Power Plant; the Rattlesnake-Wallula Lineament with respect to Washington Nuclear 2; the Cascadia Subduction Zone relative to Washington Nuclear 3; etc.). Conversely, with respect to Diablo Canyon, a case can be made for not extending the regional investigations more than 75 km (45 mi) to the east and 45 km (27 mi) to the west because of the presence of the San Andreas and San Luis Banks faults, respectively.

Most of the regional investigations are expected to be literature searches and the study of existing regional geophysical data, maps, and remote sensing data. The difference in the level of effort in these studies for sites, particularly in the CEUS, between a radius of 200 km and 320 km is not expected to be significant. Most tectonic structures can likely be ruled out as potential seismic sources without going to the field. Ground truth reconnaissances can be made on a very selective basis.

10. Page 9, lines 20-26, and 35-38. The section within which these references are found has been revised. We assume that the main objection to the text was the reference to a deterministic seismic hazard analysis by the staff. The requirement for a deterministic analysis has been removed.

11. Page 10, lines 31-35. We have made the suggested changes in your line 31 as follows: after "PSHA", delete ". The PSHA"; add "and also" before "can be used"; and insert "hazard" between "the" and "sensitivity". The suggested deletion of lines 32 and 33 was not done because its inclusion in Regulatory Guide 1.165 does not make it a requirement for applicants. It is mentioned only as an acceptable methodology.

12. Page 11, lines 11-41. The referenced text has been rewritten as follows: "The PSHA should only be updated if the new information indicates that the current version significantly under estimates the hazard and there is a strong technical basis that supports such a revision. It may be possible to justify a lower hazard estimate with an exceptionally strong technical basis. However, it is expected that large uncertainties in estimating seismic hazard in the CEUS will continue to exist in the future, and substantial delays in the licensing process will result in trying to address them with respect to a specific site. For most cases, limited scope sensitivity studies should be sufficient to demonstrate that the existing data base in the PSHA envelops the findings from site-specific investigations. In general, the significant revisions to the LLNL and EPRI data base is to be only undertaken periodically (every ten years), or when there is an important new finding or occurrence. The overall revision of the data base will also require a reexamination of the reference probability discussed in Appendix B and used in Step 4 below."

"Strong technical basis" is used instead of "consensus of opinion by the scientific community." A decision regarding this issue will more than likely be needed long before consensus among the scientific community can be

obtained. The staff will make the decision based on the strength of the available data and advice from the scientific community, including the USGS.

13. Page 12, lines 7-11, and 24. The broader term "information" is preferred in both contexts, so the suggested change has not been made. We do not consider it useful to add the sentence, "For soil sites, the rock hazard results will be amplified based upon site-specific amplification factors" to this paragraph.

14. Page 12, lines, 35-39, and page 13, lines 1-9. The suggested addition to the text was not included because Appendix F discusses options to develop the SSE.

15. Page 13, lines 20-42, page 14, lines 1-7, lines 11-12, and lines 16-18. All of the changes recommended in these references are based on previously recommended changes that were not adopted, or on a basic philosophy that differs from that of the NRC staff, and therefore were not made.

Appendix A

1. Page A-1, line 4, and lines 9-11. As suggested, "In" has been struck and "As a result of" added on line 4. Reference to deterministic controlling earthquakes has been removed from SRP 2.5.2, so there is no need to address the concept here.

2. Page A-1, line 23. "free-field" has been inserted between "the" and "vibratory".

3. Page A-2, lines 22-28. The first sentence in the definition of Seismogenic Source has been revised to read, "A "seismogenic source" is a portion of the earth that we assume has uniform earthquake potential (same expected maximum earthquake and recurrence frequency) distinct from the seismicity of the surrounding regions."

Appendix B

1. Page B-1, lines 17-19. It is inappropriate to refer to the SSHAC program here as "median" as used in that program was for a different intent.

2. Page B-2, lines 17-18. The statement has been modified as suggested to read: "Using LLNL, EPRI, or a comparable methodology that is acceptable to the NRC staff, calculate ____"

Appendix C

1. Appendix C has been modified with close consideration of your comments.

2. Change all seismic hazard information base to seismic hazard data base. As stated early, we consider it to be more appropriate to use information because it includes alternate hypotheses as well as data.

3. Page 1, lines 22-24. the phrase "and the results from the PSHA." has been added to the paragraph as recommended.

4. Page 1, lines 26-28, and Page 2, lines 4-24. The procedure described in section C.2 (Steps 1-7) has been modified to put the steps in their proper sequence.

5. Page C-7, lines 29-30. We agree with this comment and Tables C.4-C.7 have been modified to include actual values for each bin and the total hazard.

Appendix D

1. Page D-1, Lines 4 and 5. The staff does not agree with the investigation distance radii recommended by YAEF for the reasons given in the response to DG-1032 (now Regulatory Guide 1.165) Comment No. 9 above.

2. Page D-1, lines 31-35. Regional and site specific investigations are performed and the acquired data are analyzed to evaluate the seismic and geologic conditions of the site and surrounding region, and to determine whether significant seismic sources are present in the region that may not be enveloped by the PSHA database, and to assure that the correct attenuation values have been used. We assume that your concern is related to the way in which this data will be utilized in a deterministic hazard analysis. As stated in an earlier response, the previous requirement in SRP 2.5.2 for the staff to perform a deterministic seismic hazard analysis to compare with the applicant's PSHA results has been removed.

3. Page D-7, lines 22 and 23. The existence of an active seismographic network in the site region may suffice in some cases, but generally not. It is important, particularly in the CEUS, to be able to record small events, including microearthquakes, to obtain data that might provide clues to the nature of the local source. Regional networks, unless they are nearby and are so designed, will not accomplish this. For this reason we did not add the recommended sentence.

4. Page D-7, lines 25-31. The subject paragraph has been revised to read: "The data obtained by monitoring current seismicity will be used, along with the much larger data base acquired from site investigations, to evaluate site response and to provide information about whether there are significant sources of earthquakes within the site vicinity, or to provide data by which an existing source can be characterized."

5. Page D-7, lines 34-38. The paragraph has been reworded as follows: "Monitoring should be initiated as soon as practicable at the site, preferably at least five years prior to construction of a nuclear unit at the site and should continue at least until the free field seismic monitoring strong ground motion instrumentation described in Regulatory Guide 1.12 is operational." Although not pertinent to siting decisions, the presence of a continuously operating free field seismograph could help resolve issues such as occurred at the Perry site following the 1986 Astabula (Ohio) Earthquake. One of the issues arose because there were no free field records to compare with the in-

plant seismograph records. Also, free-field records would have provided clues to the character of the seismic source, which was also a big issue at the time.

Appendix E

1. Page E 1, lines 5-27. Updating the input parameters to the PSHA's could be destabilizing to the licensing process, and it is intended that all source zones, attenuation models, and upper bound magnitudes be frozen until they are again determined in a consistent manner in ten years.

If, however, new data indicate that there is a potential for a significant change in the hazard estimate, such as the discovery of a previously unknown capable tectonic source at the site, then sensitivity studies will be carried out to estimate the impact of the new data on the seismic hazard. If the resulting value is approximately enveloped by the PSHA database, no further analysis is necessary.

Analyses along these lines were performed by NUMARC (now NEI) and EPRI in regard to the effect on the seismic hazard in the Wabash Valley as defined by the LLNL and EPRI PSHA's of the discovery of paleoseismic evidence for a prehistoric earthquake of an estimated magnitude of 7.5. They demonstrated that the occurrence of such an event centered at Vincennes, Indiana, was enveloped by the PSHA input, and a new PSHA was not necessary. It is expected that the results of this analysis of the new information about the Wabash Valley will be typical of most assessments of new data that initially imply that there might be a change in the seismic hazard.

A similar exercise was accomplished regarding new information and its impact on the seismic hazard of a site on the Savannah River Reservation. In this case the seismic design was impacted by the new information because of the significance of new data.

Although advice from the scientific community will be sought, obtaining its consensus regarding the significance of new data is a difficult, if not an impossible task. Licensing activities should not be delayed for a substantial amount of time waiting for this to come about. The staff will make a judgement on the significance of new data based on strong technical evidence, and communication with, but not on a consensus of, the scientific community.

In most cases, if it can be shown that the new data only has an impact on the site being evaluated (source zones only applicable to that site), then a new reference probability need not be calculated. When more than one site is affected, then it may be necessary to recalculate the seismic hazard at all sites and develop a new reference probability. An overall revision of the database would also require a re-examination of the acceptability of the reference probability.

The procedure described in lines 21-23 is similar to the staff's "sanity check" for the PSHA described in DG 1032. The staff is no longer required to perform a deterministic seismic hazard analysis.

2. Page E-2, lines 2-4. These referenced lines have been modified to read; "If new information identified by the site specific investigations would result in a significant increase in the hazard estimate for a site, and this new information is validated by a strong technical basis, the PSHA may have to be modified to incorporate the new technical information."

3. In general, major recomputations of the LLNL and EPRI data base are planned to be undertaken periodically (approximately every ten years), or when there is an important new finding or occurrence ~~that has, based on sensitivity studies, resulted in a significant increase in the hazard estimate.~~

4. Page E-2, line 13. The word "effect" has been replaced with "affect".

5. Page E-2, line 20. The phrase "will probably" has been replaced with "may".

Appendix F

1. Page F-1, lines 11-27, and page F-2, lines 5-9, 16-21, 24-28, and 33-38. The referenced text has been revised to: "The SSE response spectrum can be determined by scaling a site-specific shape determined for the controlling earthquakes or by scaling a standard broad-band spectral shape to envelop the average of the ground motion levels for 5 and 10 Hz ($S_{a,2-10}$), and 1 and 2.5 ($S_{a,1-2.5}$) as determined in Step C.2 of Appendix C to this guide."

The recommended sentence on lines 18-21 (also page F-2, lines 5-9) were not added.

2. Page F-2, lines 10 and 11. Changing the phrase "three possible" to "acceptable" does not improve the text, therefore this was not done.

3. Page F-3, lines 4-7, and 33-35. We do not agree with the suggested changes of Position 4, therefore, the recommended modifications were not made.

SRP 2.5.2

1. Page 2.5.2-1, lines 8-11. The requirement for a deterministic seismic hazard analysis by the staff has been revised.

2. Page 2.5.2-2, line 7. The word "design" has been inserted between "represents the" and "earthquake".

3. Page 2.5.2-2, line 28. The phrase has been revised to: "including rates of occurrence of earthquakes___."

4. Page 2.5.2-2, line 30, and page 2.5.2-3, lines 6 and 7. "All" has been deleted and the "s" in "seismic" has been capitalized.

5. Page 2.5.2-6, line 3 and 7. This part of the text has been rewritten and the word "all" is no longer included.

6. Page 2.5.2-6, lines 16-18. The word "assumed" has been inserted between "regions of" and "uniform" in this statement.

7. Page 2.5.2-6, lines 23 and 24. The relationship between seismic source and seismotectonic province is defined in Regulatory Guide 1.165, Appendix A, Page A-2, in the definition of seismogenic source, which is a seismic source that does not rupture ground surface. Seismotectonic province is defined as a seismogenic source that is a large region of diffused seismicity. The entire paragraph, lines 1-24, has been rewritten and reorganized based on these and other comments.

8. Page 2.5.2-6, lines 38-42, and page 2.5.2-7, lines 1 and 2. The referenced text has been revised. However, in reviewing the results of the applicant's regional and site investigations and assessing the seismic sources identified by those investigations, it still may be necessary to develop realistic models based on this information in order to determine whether those models have been enveloped by the PSHA used in the estimation of the SSE. The evaluation guidance described in the referenced paragraph has been rewritten with that purpose in mind. Some revision of Sections III, REVIEW PROCEDURES, and Section IV, EVALUATION FINDINGS has also been accomplished to more clearly define the staff's responsibilities.

9. Page 2.5.2-7, lines 15-21. The following statements have been added to the referenced sentence for clarification: "For the CEUS sites, when the SSE is determined using LLNL or EPRI PSHA methodology and Regulatory Guide 1.165, in meeting the requirements of Reference 1, this subsection is acceptable when adequate information is provided to demonstrate: (1) that a thorough investigation has been conducted to assess the seismicity and identify seismic sources that could be significant in estimating the seismic hazard of the region if they exist; (2) that existing sources in the PSHA are consistent with the results of site and regional investigations, or the sources have been updated in accordance with the Appendix E of regulatory Guide 1.165.

For sites where LLNL or EPRI methods have not been used, and it is necessary to identify and characterize seismic sources in meeting the requirements of Reference 1, this subsection is acceptable when adequate information is provided to demonstrate that all seismic sources that are significant in determining the earthquake potential of the region are identified, or that an adequate investigation has been carried out to provide reasonable assurance that there are no unidentified significant seismic sources."

10. Page 2.5.2-7, lines 36-39. The phrase "(those identified by the investigations)" has been inserted between "seismic sources" and "is based on" in parentheses for clarification.

Comments 11. through 16. Page 2.5.2-9, lines 4, 5, 10, 11, 13-15, 16, 17, 24-27, 30-32, 39, and 40. These comments pertain to the deterministic seismic hazard "sanity check" of the applicant's PSHA. This proposed procedure has been abolished. The description of that procedure has been deleted and replaced by the following text:

"For the CEUS sites relying on LLNL or EPRI methods, the staff will review the applicant's probabilistic seismic hazard analysis, including the underlying assumptions and how the results of the site investigations are used to update the existing sources in the probabilistic seismic hazard analysis, how they are used to develop additional sources, or how they are used to develop a new data base.

The staff will review the controlling earthquakes and associated ground motions at the site derived from the applicant's probabilistic hazard analysis to be sure that they are either consistent with the controlling earthquakes/ground motions used in licensing of (a) other licensed facilities at the site, (b) nearby plants, or (c) plants licensed in similar seismogenic regions, or the reasons they are not consistent are understood. For the CEUS, a comparison of the PSHA results can be made with the information included as Table 1, which is a very general presentation based on technical information developed over the past two decades of licensing nuclear power plants.

The applicant's probabilistic analysis, including the derivation of controlling earthquakes, is considered acceptable if it follows the procedure in Regulatory Guide 1.165 and its Appendix C (Ref. 9). The incorporation of results of site investigations into the probabilistic analysis is considered acceptable if it follows the procedure outlined in Appendix E of Regulatory Guide 1.165 and is consistent with the review findings of Sections 2.5.2.2 and 2.5.2.3.

For the sites not using LLNL or EPRI methods, the staff will review the applicant's PSHA or other methods used to derive controlling earthquakes. The staff will particularly review the approaches used to address uncertainties. The staff will perform an independent evaluation of the earthquake potential associated with each seismic source that could affect the site. The staff will evaluate the applicant's controlling earthquakes based on historical and paleoseismicity. In this evaluation, the controlling earthquakes for each source are at least as large as the maximum historic earthquake associated with the source."

17. Page 2.5.2-11, lines 16-18. The sentence is appropriate because, as explained in response to an earlier comment, even at ALWR sites, regional evaluations are still required.

18. Page 2.5.2-11, lines 25-27. The referenced sentence has been deleted from the SRP Subsection.

19. Page 2.5.2-12, lines 1 and 2. The referenced sentence has been modified to: "These procedures are also used to make ground motion estimates when the probabilistic methods are not used. In the following procedures, 84th percentile response spectra are used for both spectral shape as well as ground motion estimates.

SECTION 2

**RESOLUTION OF PUBLIC COMMENTS
REGULATORY GUIDE 1.12, REVISION 2**

COMMENT RESOLUTION

Regulatory Guide 1.12, Revision 2 Seismic Instrumentation for Nuclear Power Plants (Draft was DG-1033)

BACKGROUND

The first proposed revision of the Reactor Site Criteria Including Seismic and Earthquake Engineering Criteria for Nuclear Power Plants (10 CFR Parts 50, 52 and 100) was published for public comment on October 20, 1992, (57 FR 47802). The availability of the draft regulatory guides and standard review plan section that were developed to provide guidance on meeting the proposed regulations was published on November 25, 1992, (57 FR 55601). Because of the substantive nature of the changes to be made in response to public comments the proposed regulations and draft guidance documents were withdrawn and replaced with the second proposed revision of the regulations published for public comment on October 17, 1994, (FR 59 52255). The availability of the draft guidance documents was published on February 28, 1995, (FR 60 10810).

Nine letters (References 1 through 9) contained comments on Draft Regulatory Guide DG-1016, "Seismic Instrumentation for Nuclear Power Plants," November 1992. Draft Regulatory Guide DG-1033, "Seismic Instrumentation for Nuclear Power Plants," February 1995 reflects the only documentation pertaining to NRC staff evaluation and implementation of all comments provided in References 1 to 9.

Three letters (References 10-12) contained comments on Draft Regulatory Guide DG-1033, "Seismic Instrumentation for Nuclear Power Plants." A synopsis of the comments and the NRC staff response follows.

A. INTRODUCTION

- A1. It is not evident why it is necessary to require (1) that nuclear sites have seismic instrumentation, or (2) that nuclear power plants be shutdown if the Operating Basis Earthquake Ground Motion (OBE) is exceeded, if no damage is apparent. It appears that the USGS has adequate instrumentation for detecting and reporting earthquakes anywhere in the United States. Also, if a plant is designed to withstand an SSE it is more than reasonable that if it survives an OBE (1/2 SSE or an MMI V) without damage and without tripping, it should be permitted to continue to operate without interruption. (Reference 10)

Response to (1). The USGS may have adequate instrumentation for detecting and reporting earthquakes anywhere in the United States; however, their instrumentation will not satisfy the Commission's requirements that suitable instrumentation must be provided so that the seismic response of nuclear power plant features important to safety can be evaluated promptly. These requirements will be contained in Appendix S, "Earthquake Engineering Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities," for applications received after the effective date of the final rule. They are currently contained in Appendix A, "Seismic and Geologic Siting Criteria for Nuclear Power Plants," to 10 CFR Part 100, "Reactor Site Criteria," for existing plants.

Regulatory guides are issued to describe and make available to the public such information as methods acceptable to the NRC staff for implementing specific parts of the Commission's regulations. Regulatory guides are not substitutes for regulations, and compliance with regulatory guides is not required.

Should an earthquake occur, the instrumentation described in Draft Regulatory Guide DG-1033 satisfies the Commission's regulations by providing information on the vibratory ground motion and resultant vibratory responses of representative Seismic Category I structures. The instrumentation will provide data so that an evaluation can be made as to (1) whether or not the design response spectra have been exceeded, (2) whether or not the calculated vibratory responses used in the design of the representative seismic Category I structures have been exceeded at instrumented locations, and (3) the degree of applicability of the mathematical models used in the seismic analysis of the buildings.

Response to (2). The Commission's regulations cited above also require shut down of the nuclear power plant if vibratory ground motion exceeding that of the Operating Basis Earthquake Ground Motion (OBE) occurs. Appendix S to Part 50 will also require plant shutdown if significant plant damage occurs.

Small, nondamaging earthquakes may exceed the OBE spectrum in the high-frequency range without causing damage. The January 31, 1986 magnitude 5.0 earthquake near the Perry nuclear power plant is a good example. To avoid unnecessary plant shutdowns the Electric Power Research Institute (EPRI) developed guidelines that will enable licensees to quickly identify and assess earthquake effects on nuclear power plants. These guidelines are in EPRI NP-5930, "A Criterion for Determining Exceedance of the Operating Basis Earthquake," EPRI NP-6695, "Guidelines for Nuclear Plant Response to an Earthquake," and EPRI TR-100082, "Standardization of Cumulative Absolute Velocity." The regulatory position on OBE exceedance in Draft Regulatory Guide DG-1034, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions," is based on EPRI NP-5930 and EPRI TR-100082 reports. The following, extracted from EPRI NP-5930, is a statement about the conservatism deliberately placed in the OBE exceedance criterion:

"Note that the recommended criterion for determining OBE exceedance is purposely conservative. Based on direct correlation of the criterion parameters with damage data, ground motions which cause damage to buildings of good design and construction (which in general have lesser seismic resistant provisions than nuclear facilities) are a factor of at least 1.5 larger than the recommended threshold values. This means that when the criterion is used in the future, and if the OBE is moderately exceeded, it is very likely that no significant damage will have occurred."

Thus, the criterion stated in DG-1034 is high enough to avoid needless shutdowns yet low enough so that plant safety is not compromised.

The post-shutdown inspections and tests are described in EPRI NP-5695 and endorsed in Draft Regulatory Guide DG-1034. Section 5.3.2(1) addresses the situation where the plant was shut down because of OBE exceedance and the detailed visual inspections of the equipment and structures discover no physical or functional damage.

The guide was not changed.

- A2. Guide should be focused on describing the seismic instrumentation a licensee must have in place if it does not wish to follow guideline number 2 of Appendix A of DG-1034. Since the likelihood of an earthquake in the eastern United States is so low, it is more prudent for plants in this region not to install the seismic instrumentation and shutdown for an inspection if the USGS determines that an earthquake that exceeds the guidelines occurs. West Coast or Alaska facilities may find it more prudent to install the instrumentation in order to have an alternative to guideline number 2 of Appendix A to DG-1034. However, it is likely that they too will choose to shutdown and conduct an inspection if the criteria of guideline number 2 in the Appendix are exceeded. If that is the case, the seismic instrumentation is not of benefit to them either. (Reference 10)

Response The regulatory guide describes the type, locations, operability, characteristics, installation, actuation, remote indication, and maintenance of seismic instrumentation that are acceptable to the NRC staff for satisfying the requirements in the Commission's regulations for ensuring the safety of nuclear power plants. The instrumentation system should be operable and operated at all times; however, an evaluation of seismic instrumentation noted that instruments have been out of service during plant shutdown and sometimes during plant operation. Therefore, the staff developed the guidelines in Appendix A to Draft Regulatory Guide DG-1034 to be used if the seismic instrumentation or data processing hardware and software necessary to determine whether the OBE has been exceeded is inoperable. As an incentive to have operable instrumentation, the guidelines on OBE exceedance in Appendix A to DG-1034 are more conservative than those in the regulatory position.

The regulatory position was not changed.

B. DISCUSSION

- B1. Page 2, lines 27-30. The sentence "Foundation-level instrumentation would provide data on the actual seismic input to the containment and other buildings and would quantify differences between the vibratory ground motion at the free-field and at the foundation level." should be deleted or placed after the next sentence. The current location implies that the differences between the foundation motion and motions in the buildings are used in the determination of OBE exceedance, which is incorrect. (Reference 11)

Response. The sentence was moved.

- B2. Page 2, line 28. Foundation level seismic instrumentation should not be required at buildings other than seismic category I structures. Revise to read "... to the containment and other seismic category I buildings and would quantify ..." (Reference 11)

Response. Agreed.

- B3. Page 3, lines 3-6. Revise to state that Draft Regulatory Guide DG-1034 addresses cases when the installed seismic instrumentation is and is not operable. (Reference 11)

Response. Page 3, lines 3-6 discusses a critical assumption about seismic instrumentation operability and data processing capability pertaining to the development of the regulatory positions in DG-1034. Lines 16-19 discusses the NRC staff's position if the seismic instrumentation or data processing hardware and software is inoperable.

The discussion was not changed.

- B4. Page 3, lines 10-12. Supports the discussion about instrumentation at multi-unit sites in so far as the same or higher levels of quality are implemented during the construction phase of the follow-on plants. There should be an established means to verify, from a structural perspective, that the reactors are built to the same quality levels. In those cases where this cannot be demonstrated, separate seismic instrumentation should be installed in subsequent units. (Reference 12)

Response. The design and construction methods proposed by an applicant are described in a safety analysis report that is submitted to the NRC staff for review and approval. In its review the NRC staff ensures that the proposed design and construction methods are commensurate with current practices.

C. REGULATORY POSITION

- C1. Page 5, lines 1-3. The phrase "certain features" should be defined or more specific language used in its place. (Reference 11)

Response. A portion of the statement provided in References 1 and 2 was inadvertently omitted. The regulatory position was revised.

C2a. Page 5, lines 24-25. Supports the regulatory position about annunciation in separate control rooms, if applicable, for new licensees. Recommends an exemption for licensees of existing plants that may want to voluntarily upgrade their systems and implement the new standards. (Reference 12)

C2b. Page 5, lines 24-25. This implies that annunciation is required in the control room. EPRI TR-104239 allows a minimum system where the data is retrieved by hand and processed at a different site. As long as the determination of OBE exceedance can be performed within 4 hours this should be acceptable to the NRC. Running cables from the instrumentation to the control room is expensive and may not be cost beneficial to some utilities. Note that if the operators in the control have not felt an earthquake then for practical considerations an earthquake has not occurred.

Revise the section not to require control room annunciation. (Reference 11)

Response. Support for the NRC staff's regulatory position for control room annunciation is contained in several peer reviewed national standards, most notably, ANSI N18.5, "Earthquake Instrumentation Criteria for Nuclear Power Plants," (endorsed with exception in Regulatory Guide 1.12, Revision 1), and ANSI/ANS-2.2-1978 and 1988, "Earthquake Instrumentation Criteria for Nuclear Power Plants." The regulatory position because it pertains to new plants was not changed. However, the implementation section of the regulatory guide was revised to include a voluntary implementation by licensees of operating plants. The implementation section states that partial compliance with the regulatory positions will be reviewed on a case-by-case basis recognizing that it may not be cost beneficial for licensees to implement all aspects of the regulatory positions.

C3. Page 6, lines 13-14. State that the instrumentation should record, at minimum, 3 seconds of low amplitude motion prior to seismic trigger actuation. Setting for the pre-event memory should be correlated with the maximum distance to any potential epicenter that can effect a specific site. The "P" wave may not be recorded at a 3 second setting. Also, when an event occurs at some distance and the trigger threshold limit is not exceeded until 15 or 20 seconds into the event, a part of the record, albeit for a low event, is lost. A 30 second value may be more appropriate and is within the capabilities of current digital time-history accelerographs. (Reference 12)

Response. Agreed. The regulatory position was changed. In addition, a new paragraph was added to the Discussion section addressing the pre-event memory setting.

- C4. Page 6, lines 21-24. Can not comply with the stated regulatory position. It would require equipment to have the capability to record for 30 days without power. Current capability is for equipment to sense and record for no less than 24 hours in the absence of power. Loss of AC and DC power alarms are optionally available that would notify personnel if there is a problem with the power system. (Reference 12)

Response. The regulatory position was revised to recommend enough battery capacity for a minimum of 25 minutes of system operation at any time over a 24 hour period, without recharging, in combination with a battery charger whose line power is connected to an uninterruptable power supply or a line source with an alarm that is checked, at least every 24 hours. It is also stated that other combinations of larger battery capacity and alarm intervals may be used.

- C5. Page 7, lines 10-11. The lower range of the seismic trigger actuation level should be 0.005g (not 0.001g). Our instrumentation is capable of having a trigger actuation level of 0.001g, however, an actuation level of 0.005g would avoid spurious triggering of the system. (Reference 12)

Response. What is stated is a range of seismic trigger operability not a specific setting. If necessary, the actuation level of the seismic trigger could be set to 0.005g to avoid spurious triggering of the system. Therefore, in response to References 1 and 2, and because the stated range is available the regulatory position was not changed.

- C6. Page 8, lines 4-7. Supports control room annunciation of the free-field or any foundation level time history accelerograph for new plants. Recommends an exemption for licensees of existing plants that may want to voluntarily upgrade their systems and implement the new standards. (Reference 12)

Response. See response to C2.

- C7. Reinstate Regulatory Position 4.3 of DG-1016, "The instrumentation of the foundation and at elevations within the same building or structure should be interconnected for common starting and common timing, and the instrumentation should contain provisions for an external remote alarm to indicate actuation." In the absence of a common time base for

instruments in the same building or structure, comprehensive post-earthquake (off-line) dynamic analysis, is not possible. (Reference 12)

Response. The regulatory guide recommends the minimum instrumentation requirements necessary to meet the Commission's regulations. As noted in Reference 5, the proposed instrumentation is not sufficient to identify some of the major vibratory modes of the structure, such as rocking and torsion. However, the instrumentation described in the regulatory guide will provide data so that an evaluation can be made as to (1) whether or not the design response spectra have been exceeded, (2) whether or not the calculated vibratory responses used in the design of the representative seismic Category I structures have been exceeded at instrumented locations, and (3) the degree of applicability of the mathematical models used in the seismic analysis of the buildings.

The regulatory position was not changed.

APPENDIX

- AA1. Improve the definition of the Operating Basis Earthquake. First, it is not necessarily true that all features necessary for continued operation of the plant are seismically designed (circulating water system, sewage treatment, turbine, reactor coolant pumps, etc.). Systems necessary for safe shutdown are seismically designed. Second, why require shutdown at the OBE if the plant is designed for it? Third, as written, all earthquakes less than the OBE meet the definition of the OBE. Fourth, DG-1034 page 8 appears to define the OBE as either an OBE spectra, as $1/3$ the SSE, or as $.2g$. Fifth, Appendix A of DG-1034, guideline number 2 appears to define an OBE as an MMI earthquake within 5 km of the plant, a Richter 6 felt at the plant, or a Richter 5 within 200 km of the plant.

A better definition for the OBE is: "An earthquake occurring in the vicinity of a plant after which the plant is shutdown for detailed review and evaluations, even if no damage is apparent. The earthquake must result in an MMI VI or greater within 5 km of the plant. For plants with calibrated, operable and installed seismic instrumentation, the OBE must also exceed $1/2$ of the SSE spectrum." (Reference 10)

Response. With regard to the other OBE related statements, the proposed regulations and information pertaining to NRC staff positions on the value of the OBE ground motion, required OBE analysis, and required plant shutdown are contained in the Federal Register notice cited above and briefly summarized below.

The requirement associated with the OBE is that all structures, systems, and components of the nuclear power plant necessary for continued operation without undue risk to the health and safety of the public must remain functional and within applicable stress, strain, and deformation limits when subjected to the effects of the OBE in combination with normal operating loads (Paragraph IV(a)(2) of Appendix S to 10 CFR Part 50). The value of the OBE can be set at (i) one-third or less of the SSE, where OBE requirements are satisfied without an explicit response or design analyses being performed, or (ii) a value greater than one-third of the SSE, where analysis and design are required. In selecting the value of the OBE the applicant should consider two items: first, the regulations require plant shutdown if vibratory ground motion exceeding that of the OBE occurs (Paragraph IV(a)(3) of Appendix S to 10 CFR Part 50), and second, the amount of analyses associated with the OBE. (Refer to Paragraphs V(B)(5) and V(B)(6) of FR 59 52255 for more discussion.)

Since December 1973 (the effective date of Appendix A to 10 CFR Part 100) the Commission's regulations have required that a nuclear power plant shut down if vibratory ground motion exceeding that of the OBE occurred. Exceedance is not clearly defined in the regulation or in any other regulatory guidance. Interim guidelines as to what constitutes an OBE exceedance warranting shutdown were published in Reference 13. The cited pages in DG-1034 contain OBE exceedance guidelines for plants with and without operable seismic instrumentation and data processing equipment, not additional OBE definitions. Note that the OBE exceedance criteria has been developed to reflect damage potential of the earthquake ground motion at a site and, as such, relates to the MMI measures. EPRI NP-5930 and EPRI TR-100082 contain details of the development of the OBE exceedance criteria.

REFERENCES

1. Yankee Atomic Electric Company, D.W. Edwards, March 23, 1993
2. Nuclear Management and Resources Council (now Nuclear Energy Institute), William H. Rasin, March 24, 1993
3. Department of Energy, Dwight E. Shelor, March 24, 1993
4. South Carolina Electric and Gas Company, John L. Skolds, March 24, 1993
5. United States Department of the Interior, Geological Survey, Dallas L. Peck, June 2, 1993
6. Sargent and Lundy Engineers, B.A. Erler, March 23, 1993
7. State of Vermont, Lawrence R. Becker, March 23, 1993
8. TU Electric, William J. Cahill, March 30, 1993
9. Northern States Power Company, Roger O. Anderson, April 21, 1993
10. Wais and Associates, Inc., Royce M. Reinecke, April 4, 1995, (Comments on Draft Regulatory Guides DG-1033, DG-1034, and DG-1035)
11. Nuclear Energy Institute, William H. Rasin, May 12, 1995
12. Kinometrics, Inc., Brian S. Herzog, May 11, 1995
13. Proceedings of the Third Symposium on Current Issues Related to Nuclear Power Plant Structures, Equipment and Piping, December 1990, Paper XII/3

SECTION 3

RESOLUTION OF PUBLIC COMMENTS REGULATORY GUIDE 1.166

COMMENT RESOLUTION

Regulatory Guide 1.166 Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions (Draft was DG-1034)

BACKGROUND

The first proposed revision of the Reactor Site Criteria Including Seismic and Earthquake Engineering Criteria for Nuclear Power Plants (10 CFR Parts 50, 52 and 100) was published for public comment on October 20, 1992, (57 FR 47802). The availability of the draft regulatory guides and standard review plan section that were developed to provide guidance on meeting the proposed regulations was published on November 25, 1992, (57 FR 55601). Because of the substantive nature of the changes to be made in response to public comments the proposed regulations and draft guidance documents were withdrawn and replaced with the second proposed revision of the regulations published for public comment on October 17, 1994, (FR 59 52255). The availability of the draft guidance documents was published on February 28, 1995, (FR 60 10810).

Seven letters (References 1 through 7) contained comments on Draft Regulatory Guide DG-1017, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions," November 1992. Draft Regulatory Guide DG-1034, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions," February 1995 reflects the only documentation pertaining to NRC staff evaluation and implementation of all comments provided in References 1 to 7.

Two letters (References 8-9) contained comments on Draft Regulatory Guide DG-1034, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions." A synopsis of the comments and the NRC staff response follows.

B. DISCUSSION

- B1. Page 2, lines 23-27. Clarification is needed. First, only the free-field instrument (or possibly the containment foundation accelerograph, if the utility elects to only use the response spectrum check) are used to determine if the plant must be shut down. Second, shutdown by "operational perturbations" does not necessarily mean that OBE

exceedance has occurred and that the plant must go through analytical steps before the plant can be restarted. (Reference 9)

Response. The sentence starting on line 23 was changed to read: "The data from the free-field seismic instrumentation, coupled with ..."

The following was added after the words "shut down" on line 30: "(or could restart following a post-trip review, if it tripped off-line because of the earthquake)."

- B2. Page 3, lines 6-15. It is not clear why the seismic instrumentation must process the data within four hours when plant walkdowns need not be completed for eight hours. Suggest changing the data processing requirements to eight hours. It is also not clear why if the plant has operated without problems for eight hours following the earthquake, and no damage is apparent, why the plant is automatically forced to shutdown. (Reference 8)

Response. The recommended times for the processing of data from the seismic instrumentation and the completion of the operator walkdown inspections was extracted from guidelines published by the Electric Power Research Institute (EPRI). These guidelines are contained in EPRI NP-6695, "Guidelines for Nuclear Plant Response to an Earthquake," Sections 4.3.2, Operator Walkdown Inspections, and 4.3.3, Evaluation of Ground Motion Records. The following is extracted from the Report Summary (Approach Section):

"The guidelines were developed by a team with expertise in system performance, plant operations, and seismic structural engineering disciplines. Based on the knowledge that operating and emergency procedures to respond to plant systems are already in place at nuclear power plants, the team formulated comprehensive guidelines for utilities to develop plant-specific procedures for response to an earthquake. Throughout guideline development, a panel of utility and industry experts on plant operation and earthquake engineering provided a comprehensive peer review."

The Commission's regulation (Appendix S, "Earthquake Engineering Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities") require shut down of the nuclear power plant if vibratory ground motion exceeding that of the Operating Basis Earthquake Ground Motion (OBE) or significant plant damage occurs. If no damage is apparent shutdown would only be required if the OBE were exceeded.

The discussion was not changed.

- B3. Page 3, lines 12 to 15. Suggest rewording to "If the seismic instrumentation or data processing equipment is inoperable, or the licensee has chosen not to install seismic monitoring instrumentation, the guidelines in Appendix A to this guide will be used to determine whether the OBE has been exceeded." (Reference 8)

Response. The installation of seismic monitoring instrumentation is not optional it is required by the Commission's regulations (Appendix S, "Earthquake Engineering Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Domestic Licensing of Production and Utilization Facilities"). The discussion was not expanded to include the phrase "or the licensee has chosen not to install seismic monitoring instrumentation."

- B4. Page 3, lines 20-23. EPRI NP-5930 refers to a single "criterion" with two checks (i.e., response spectrum and CAV). The NRC should adhere to this convention to avoid misunderstandings. (Reference 9)

Response. Agreed.

- B5. Page 4, lines 1-3. Delete this statement. We are not aware of any plants where containment isolation valves have malfunctioned during an earthquake. It is not believed that it is necessary that these valves be checked by the plant operators during a post-earthquake walkdown. This would be an appropriate component to review during the restart phase, if a plant is shutdown due to OBE exceedance or discovery of significant damage. (Reference 9)

Response. The comment on page 4, lines 1-3 discusses why the NRC staff took exception to Section 4.3.4 of EPRI NP-6695 and added Regulatory Position 6.2. Section 4.3.4 of EPRI NP-6695 describes pre-shutdown inspections that are only performed if it has been determined that the plant must shut down because the OBE was exceeded or the operator

walkdown inspections discovered damage. For the selected equipment it is important to perform a visual inspection focusing on functional damage that may impair the capability of the damaged item to perform its safety function. Physical damage which does not affect equipment operability is not a major concern in these inspections. Because it is essential to maintain containment integrity a check of the containment isolation system was added to the minimum list of equipment to be checked.

- B6. Page 4, lines 4-10. The NRC position that nuclear power plants be automatically shutdown following an OBE, even if the plant is stable and no damage is observed, precludes prudent operators in earthquake prone zones such as the West Coast and Alaska from building nuclear power plants. This decision will limit nuclear power facilities to low seismic zones such as the eastern United States, where the likelihood of an earthquake is so low that shutdown of the power plant for a post OBE inspection is moot anyway. (Reference 8)

Response. The requirement associated with the OBE is that all structures, systems, and components of the nuclear power plant necessary for continued operation without undue risk to the health and safety of the public must remain functional and within applicable stress, strain, and deformation limits when subjected to the effects of the OBE in combination with normal operating loads (Paragraph IV(a)(2) of Appendix S to 10 CFR Part 50). The value of the OBE can be set at (i) one-third or less of the SSE, where OBE requirements are satisfied without an explicit response or design analyses being performed, or (ii) a value greater than one-third of the SSE, where analysis and design are required. In selecting the value of the OBE the applicant should consider two items: first, the regulations require plant shutdown if vibratory ground motion exceeding that of the OBE occurs (Paragraph IV(a)(3) of Appendix S to 10 CFR Part 50), and second, the amount of analyses associated with the OBE. (Refer to Paragraphs V(B)(5) and V(B)(6) of FR 59 52255 for more discussion.) The regulations do not preclude prudent operators in earthquake prone zones such as the West Coast and Alaska from building nuclear power plants.

Shutdown of the power plant for a post OBE inspection is not a moot point for eastern United States power plants. Small, nondamaging

earthquakes have exceeded the OBE spectrum in the high-frequency range without causing damage. In 1978 and 1979 a series of earthquakes occurred near the Virgil C. Summer plant in South Carolina, in 1986 an earthquake occurred near the Perry plant in Ohio, in 1987 an earthquake that occurred in southern Illinois was either felt or triggered instruments at six plants. To avoid unnecessary plant shutdowns the Electric Power Research Institute (EPRI) developed guidelines that will enable licensees to quickly identify and assess earthquake effects on nuclear power plants. These guidelines are in EPRI NP-5930, "A Criterion for Determining Exceedance of the Operating Basis Earthquake," EPRI NP-6695, "Guidelines for Nuclear Plant Response to an Earthquake," and EPRI TR-100082, "Standardization of Cumulative Absolute Velocity." The regulatory position on OBE exceedance in Draft Regulatory Guide DG-1034, "Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions," is based on EPRI NP-5930 and EPRI TR-100082 reports.

C. REGULATORY POSITION

- C1. Page 5, line 4. Add a statement that the requirements for service history of seismic instrumentation should not be more restrictive than requirements for other plant equipment. (Reference 9)

Response. Agreed.

- C2. Page 5, lines 8-11. It should be made clear that the same earthquake time-history used for the calibration check should be used for all accelerometers. This will avoid someone thinking that the response of the structure from a dynamic analysis should be used to check accelerometers high up in the building.

The request in lines 11, 12 and 13 (listed above) seems inconsistent. It would be more appropriate if each accelerometer were treated independently. A calibration check should be performed for an instrument after servicing, but there is no need to require a check (of all instruments) after only the free-field instrument is serviced. (Reference 9)

Response. The intent of this Position is to have sufficient information available at the plant so that the licensee can ascertain that the time-history analysis hardware and software were functioning properly.

Regulatory Positions 1.1(4) and 4.3 were modified to clarify this point. The following was added to the Discussion section of the guide:

"Because free-field seismic instrumentation data are used in the plant shutdown determination, it is important to ascertain that the time-history analysis hardware and software were functioning properly. Therefore, the response spectrum and cumulative absolute velocity (CAV) should be calculated using a suitable earthquake time-history or manufacturers calibration standard after the initial installation and each servicing of the free-field instrumentation. After an earthquake at the plant site, the response spectrum and CAV should be calculated using the time-history or calibration standard that was used during the last servicing (or initial instrumentation installation if no servicing has been performed) and the results compared with the latest data on file at the plant."

This Position is not addressing seismic instrumentation maintenance. The maintenance of the accelerometers is described in Regulatory Guide 1.12, "Nuclear Power Plant Instrumentation for Earthquakes," Revision 2 (Draft was DG-1033).

- C3. Page 5, lines 15-18. Sections 5.3.1 and 5.3.2.1 of EPRI NP-6695 are for "post-shutdown inspections and tests" assuming that the plant has been shut down due to OBE exceedance or discovery of significant damage during the operator walkdown. This section should be revised to refer to Section 4.3.2 of EPRI NP-6695. This latter section refers to Section 5.3.2.1, but it says: "In performing these inspections, consideration (underline added for emphasis) should be given to the specific list of equipment selected for focused inspections described in Section 5.3.2.1 of this report."

The key word here is "consideration." Section 5.3.2.1 guidance relies on a very major inspection procedure that is beyond the scope of post earthquake inspection guidance of Section 4 of EPRI NP-6695. The post earthquake walkdown is performed by plant operators, while the post-shutdown review in Section 5 is performed by engineers. The operator walkdown after a felt earthquake should be kept simple. (Reference 9)

Response. Regulatory Position 1.2 discusses pre-earthquake actions, that is, the upfront planning that is needed to perform the postearthquake inspections. Section 5 of EPRI NP-6695 is titled,

"Guidelines for Post-Shutdown Inspections and Tests," however, Section 5.3.1 is titled, "Pre-Event Actions," and describes the selection of equipment and structures for inspections and the base line inspections.

Section 5.3.2.1 of EPRI NP-6695 was cited because it is mentioned in Section 5.3.1 and the NRC staff wanted to make it clear that it was also accepted. In retrospect this is not necessary, exceptions to a section, if any, are noted (see Regulatory Position 2). The text was modified to state that the Position pertains to pre-earthquake actions, and the reference to Section 5.3.2.1 was removed.

- C4. Page 5, lines 22-24. See comment C3 above. There should not be a direct reference to Section 5 in EPRI NP-6695 since this refers to post-shutdown actions. Revise this Section so it does not refer to Section 5 in EPRI NP-6695, which refers to post-shutdown earthquake actions. (Reference 9)

Response. Agreed, the parenthetical statement was removed. See response to Comment C3 for the rationale as to why the parenthetical statement was made.

- C5. Page 7, lines 7-10. The option should be permitted to allow the containment basemat location to be used in the same manner as a free-field station for plants founded on rock sites. This is specifically allowed for this in the EPRI NP-5930 report, because flexibility was conservatively included in the OBE exceedance criterion to account for variability between free field and containment basemat responses at rock sites. (Reference 9)

Response. NRC staff approval of an applicant's standard design certification submittal pursuant to 10 CFR Part 52 means that the design is usable for a multiple number of units or at a multiple number of sites without reopening or repeating the review. In the design certification applications that have been reviewed and approved by the NRC staff (System 80+, NUREG-1462 and Advanced Boiling Water Reactor, NUREG-1503), the applicant has committed to the location and characteristics of the seismic instrumentation, OBE exceedance criterion (using data from free-field seismic instrumentation), and plant shutdown and restart procedures. Deviations from these commitments can not be made after site selection and still have the design characterized as a certified standard design. In addition, an application for a

construction permit or operating license pursuant to Appendix S of Part 50 has the SSE characterized by free-field ground motion response spectra at the free ground surface. Thus, the free-field seismic instrumentation data would be used to compare measured response to the engineering evaluations used to determine the design input motions to the structures.

In a 10 CFR Part 50 application the characteristics of the design and site are reviewed simultaneously. The applicant's commitments to the location and characteristics of the seismic instrumentation, OBE exceedance criterion, and plant shutdown and restart procedures are made with explicit siting conditions known. However, an application for a construction permit or operating license pursuant to Appendix S of Part 50 has the SSE characterized by free-field ground motion response spectra at the free ground surface. The free-field seismic instrumentation data would be used to compare measured response to the engineering evaluations used to determine the design input motions to the structures.

In addition, there is a publication on recent Lucerne Valley, California data (Reference 10) which questions the criteria for classifying a site as rock. Reference 10 concludes that the use of rock outcrop motion to develop base rock motion needs further evaluation. The NRC staff is aware of other unpublished studies with similar conclusions that were conducted after recent California earthquakes. This will be addressed in a new NRC sponsored research program to develop revised regulatory guidance to characterize the vibratory ground motion used for nuclear power plant design. Results will provide the technical basis to support a revision to Regulatory Guide 1.60, "Design Response Spectra for Seismic Design of Nuclear Power Plants," and associated standard review plan sections.

The final regulatory guide will be used in the evaluation of applications for construction permits, operating licenses, combined licenses, or design certifications submitted after the effective date of Appendix S to 10 CFR Part 50 (the regulatory positions will not be backfit). Therefore, for the reasons cited above a general option that

would allow that the containment basemat location could be used in the same manner as a free-field station for plants founded on rock sites will not be included. However, applicants have proposed alternative methods for complying with specific portions of the Commission's regulations that were accepted by the NRC staff. Recognizing the NRC staff's concerns about criteria for classifying a site as rock, an application submitted pursuant to Part 50 could propose the stated option with their submittal.

- C6. Page 8, lines 1-8. EPRI NP-5930 recommends a confirmatory check when only a single spike exceeds one of the three earthquake component response spectra. In order to minimize of the likelihood of a spurious signal indicating falsely that the OBE has been exceeded a confirmation check should also be allowed consistent with the provisions in EPRI NP-5930. (Reference 9)

Response. The recommendations in EPRI NP-5930 were developed in part, based on the data that would be available from the seismic instrumentation in the currently operating nuclear power plants. For the response spectrum check EPRI NP-5930 recommends that spectral ordinates, computed at a minimum of 8 frequency points approximately evenly spaced on a logarithmic scale, are compared to the criterion values. The response spectrum check is considered to have been exceeded if one spectral ordinate from any of the three directions exceeds the criterion value and one additional spectral ordinate, from a different frequency of the same direction or any frequency of a different direction, exceeds two-thirds of the criterion value. For instruments such as Engdahl recorders which rely on light indicators (i.e., amber and red) one red light with at least one additional indicator (red or amber) from a different oscillator must light for the response spectrum check to have been exceeded.

The recommendations stated above were intended to minimize the likelihood of a spurious signal (a single narrow frequency spectral acceleration spike) as being interpreted as a damaging earthquake motion. The solid-state digital instrumentation recommended in Regulatory Guide 1.12, "Nuclear Power Plant Instrumentation for Earthquakes," Revision 2 (Draft was DG-1033) will provide spectra data as a continuum, and not be limited to a preselected number of

frequencies. All frequencies between 1 and 10 hertz should be used to determine if the response spectrum check was exceeded. Upon evaluation of the data the appearance of a spurious signal would be evident.

The regulatory position was not changed.

- C7. Page 8, lines 1-8. Item 4.1.2 in this section provides three criteria for exceeding the OBE spectra: first, the OBE spectra; second, $1/3$ of the SSE; and third, .2g or 6 inches per second as appropriate. Historically, the criteria for the OBE is $1/2$ the SSE. Why the change? Does the definition of the OBE as $1/3$ of the SSE preclude the need for any OBE design analysis? Also, does the .2g or 6 inches per second criteria correlate in any way to an MMI VI within 5 km of the plant? The number of options available in this section is confusing. Why is the criteria not limited to exceeding $1/2$ the SSE spectra? From a design perspective, it seems prudent for licensees to design only for the SSE spectra. Then the OBE (either $1/3$ or $1/2$ the SSE spectra) becomes simply a trigger for a shutdown and inspection. (Reference 8)

Response. Historically, the criteria for the OBE was $1/2$ the SSE. Appendix S to 10 CFR Part 50 now states that the value of the OBE can be set at (i) one-third or less of the SSE, where OBE requirements are satisfied without an explicit response or design analyses being performed, or (ii) a value greater than one-third of the SSE, where analysis and design are required.

The 0.2g spectral acceleration was recommended in the EPRI NP-5930, "A Criterion for Determining Exceedance of the Operating Basis Earthquake." The 6 inches per second spectral velocity threshold was also recommended by EPRI since some structures have fundamental frequencies below the range specified in EPRI NP-5930. However, the NRC staff recommends 1.0 to 2.0 Hz for the range of the spectral velocity limit (EPRI recommended 1.5 to 2.0 Hz) since some structures have fundamental frequencies below 1.5 Hz. The 0.2g and 6 inches per second criteria were established from the real earthquakes used to establish the OBE exceedance criteria as discussed in EPRI NP-5930.

- C8. Page 9, line 2. Define significant plant damage. Isn't it better defined and actually already addressed by the Plant Technical Specifications action statements? (Reference 8)

Response. Significant damage is defined in EPRI NP-6695, "Guidelines for Nuclear Plant Response to an Earthquake."

- C9. Page 9, lines 6-8. Regulatory Position 4.4 which addresses inoperable instrumentation should be referenced in this Section. (Reference 9)

Response. Agreed. The sentence that started at the end of line 9 was expanded to: "If only one limit can be checked, the other limit is assumed to be exceeded; if neither limit can be checked see Regulatory Position 4.4."

- C10. Page 9, line 14. What triggers the walkdown inspection? The criteria for these inspections should be as explicitly defined as the criteria for OBE exceedance. (Reference 8)

Response. Actions are triggered by a felt earthquake at a nuclear power plant. EPRI NP-6695 defines a felt earthquake as: "An earthquake of sufficient intensity such that: (a) the vibratory ground motion is felt at the nuclear power plant site and is recognized as an earthquake based on a consensus of the control room operators on duty at the time, and (b) for plants with operable seismic instrumentation, the seismic switches installed at the plant are activated. For most plants with seismic instrumentation, the seismic switches are set at an acceleration of about 0.01g.

- C11. Page 9, line 15. Define damage. Does this include papers on the floor, overturned coffee cups, easily repairable items? Isn't this better addressed through compliance with Technical Specification action statements? (Reference 8)

Response. Damage (functional, physical, and significant) is defined in EPRI NP-6695, "Guidelines for Nuclear Plant Response to an Earthquake."

APPENDIX A

- AA1. Page A-1, lines 8-20. For plants on rock sites the OBE exceedance instrumentation should be allowed to be located at either a free-field site or at the top of the containment basemat. The limits of 0.2g or 6 inches per second should not be eliminated from the response spectrum check. Significant additional conservatism is provided by eliminating the CAV check. (Reference 9)

Response. The criteria in the Appendix are used to determine if the OBE has been exceeded because the free-field seismic instrumentation is inoperable, data from the seismic instrumentation are destroyed, or the data processing hardware or software is inoperable. Also, see response to Comment C5.

- AA2. Page A-1, lines 29-30. Criteria 2 appears to apply to earthquakes of Richter magnitude 6.0 or greater that occur more than 200 km from the plant and are "felt" at the plant. Define "felt" since it is subjective. Better yet, delete this criteria. Also suggest deleting criteria 3 since it is not directly related to any damage at the plant. (Reference 13)

Response. Refer to the response to Comment C10. The NRC staff would use the "(a)" portion of the definition in EPRI NP-6695; the "(b)" portion is not applicable because the seismic instrumentation is inoperable

Criteria 2 and 3 will be retained, they are based on information that would be readily available to the NRC staff and would require shutdowns when they are consistent with the intent of the regulations, and avoid shutdowns when they are not. Reference 11 has additional information pertaining to these criteria.

- AA3. Page A-2, lines 3-4. Delete this paragraph since they are better addressed in DG-1035. (Reference 8)

Response. This postearthquake walkdown is recommended after any felt earthquake ground motion as an added assurance that no damage has occurred.

REFERENCES

1. Yankee Atomic Electric Company, D.W. Edwards, March 23, 1993
2. Nuclear Management and Resources Council, (now Nuclear Energy Institute), William H. Ras'in, March 24, 1993
3. South Carolina Electric and Gas Company, John L. Skolds, March 24, 1993
4. Delaware Geological Survey, Thomas F. Pickett, March 10, 1993
5. Illinois State Geological Survey, Morris W. Leighton, March 23, 1993
6. Sargent and Lundy Engineers, B.A. Erler, March 23, 1993
7. State of Vermont, Laurence R. Becker, March 23, 1993
8. Wais and Associates, Inc., Royce M. Keinecke, April 4, 1995, (Comments on Draft Regulatory Guides DG-1033, DG-1034, and DG-1035)
9. Nuclear Energy Institute, William H. Raisin, May 12, 1995
10. Tsai, Y.B. et al., "A Study of Local Ground Motion Site Response at the Lucerne Valley Acceleration Site," Presented at 1995 EERI Annual Meeting, San Francisco, CA, February 10, 1995.
11. Proceedings of the Third Symposium on Current Issues Related to Nuclear Power Plant Structures, Equipment and Piping, December 1990, Paper XII/3

SECTION 4

RESOLUTION OF PUBLIC COMMENTS REGULATORY GUIDE 1.167

COMMENT RESOLUTION

Regulatory Guide 1.167 Restart of a Nuclear Power Plant Shut Down by an Earthquake (Draft was DG-1035)

BACKGROUND

The first proposed revision of the Reactor Site Criteria Including Seismic and Earthquake Engineering Criteria for Nuclear Power Plants (10 CFR Parts 50, 52 and 100) was published for public comment on October 20, 1992, (57 FR 47802). The availability of the draft regulatory guides and standard review plan section that were developed to provide guidance on meeting the proposed regulations was published on November 25, 1992, (57 FR 55601). Because of the substantive nature of the changes to be made in response to public comments the proposed regulations and draft guidance documents were withdrawn and replaced with the second proposed revision of the regulations published for public comment on October 17, 1994, (59 FR 52255). The availability of the draft guidance documents was published on February 28, 1995, (60 FR 10810).

Three letters (References 1 through 3) contained comments on Draft Regulatory Guide DG-1018, "Restart of a Nuclear Power Plant Shut Down by an Earthquake," November 1992. Draft Regulatory Guide DG-1035, "Restart of a Nuclear Power Plant Shut Down by an Earthquake," February 1995 reflects the only documentation pertaining to NRC staff evaluation and implementation of all comments provided in References 1 to 3.

Three letters (References 4-6) contained comments on Draft Regulatory Guide DG-1035, "Restart of a Nuclear Power Plant Shut Down by an Earthquake." A synopsis of the comments and the NRC staff response follows.

A. INTRODUCTION

- A1. DG 1034 does not provide guidance on what is significant plant damage. Suggest defining significant plant damage as requiring entry into a Plant Technical Specification action statement. (Reference 4)

Response. Significant damage is defined in EPRI NP-6695, "Guidelines for Nuclear Plant Response to an Earthquake."

C. REGULATORY POSITION

- C1. The statement in Regulatory Position 1.1 is vague relative to its applicability. The limitation does not apply to piping, because Regulatory Position 1.3 states that reanalysis of safety-related piping is unnecessary. Reanalysis of components designed to ASME Section II [Section III] Class MC or ASME Division II should be unnecessary following an OBE exceedance, because they are designed within ASME stress limitations for an SSE and demonstrated to have functionality at seismic margin levels above the OBE. It appears that the evaluations for potential fatigue considerations should be limited in this paragraph to ASME vessels and components. Revise to clarify to what vessels and components the evaluation of limitations of ASME Code Service Level C apply. (Reference 5)

Response. Regulatory Position 1.3 is withdrawn. The NRC staff does not take exception to the last paragraph in Section 6.3.4.1 of EPRI NP-6695, which states "For piping, seismic reanalysis should be limited to ASME Code Class 1 piping and/or piping which shows evidence of large displacement or distress. Complete seismic reanalysis of all piping is not considered necessary. Experience has shown"

- C2. Given that the earthquake has occurred and restart deliberations are in progress, a more liberal acceptance criterion in Regulatory Position 1.2 would be appropriate. More specific guidance is needed as to what constitutes an acceptance criterion. (Reference 5)

Response. In general, restart deliberations are not in progress because Regulatory Position 1.2 pertains to the long-term evaluation that are performed after the nuclear power plant has restarted (EPRI Damage Intensity 3 is the exception), see Figure 3-2 of EPRI NP-6695. Also, more liberal acceptance criteria are not warranted because the acceptability consideration noted in the regulatory guide and the others noted in Section 6.3.4.1, Item (3), of EPRI NP-6695 are used only if the calculated stresses are greater than allowables for faulted conditions.

- C3. This is in reference to calculated stresses from a seismic event if these exceed the allowables used for the faulted condition (e.g., ASME Code Level D service limits). The draft guide DG-1035 adds a sentence in Regulatory Position 1.2 for functionality: "This evaluation should address all locations where stresses exceed faulted allowables and should include fatigue analysis."

- (a) Historically, seismic events have not produced enough strong motion cycles to make fatigue an issue for structures, systems and components. This is especially true for low amplitude, high-

cycle, fatigue evaluations. The computed peak stress would have to be a significant fraction of the ultimate tensile strain to initiate a high-amplitude, low-cycle, fatigue failure. For engineered systems, structures and components to be susceptible to low-cycle fatigue effects, the recorded seismic event would have to exceed the Safe Shutdown Earthquake Ground Motion (SSE) spectrum by a significant margin.

- (b) The ASME Code currently only requires Code Class 1 components to perform fatigue analyses that account for thermal and pressure cycles. The plant computer system is monitoring these systems to more accurately assess the effect of operating cycles on the fatigue life of piping components. To do a fatigue analysis for ASME Code Class 2 and 3 piping systems, it would be necessary to use estimated values for thermal and pressure cycles. The amount of conservatism or error introduced by using estimated operating cycles would be more significant than the computed seismic stresses.

Based on the above discussion, the requirement for fatigue analysis should be limited to ASME Code Class 1 components and systems.
(Reference 6)

Response. Agreed.

- C4. In Regulatory Position 1.3, if reanalysis of piping systems is not considered necessary unless there is observed damage, then why is reanalysis to be conducted on a sampling basis? A better position is to require reanalysis of damaged piping and a generic implications study to determine if other, non-damaged lines, also need to be evaluated.
(Reference 4)

Response. Regulatory Position 1.3 is withdrawn (see response to Comment C1). However, it should be noted that Section 6.3.3, Seismic Re-Evaluations, of EPRI NP-6695, describes considerations that should be used in the selection of items for seismic re-evaluation.

- C5. The exception in Regulatory Position 1.3 infers that all piping showing evidence of distress be evaluated, since the draft regulatory guide did not identify that evaluation be limited to only ASME Code Class 1 piping and/or structures that show evidence of large displacements or distress.

The draft regulatory guide suggests that piping should be evaluated based on a sampling program. However, the parameters for the design of a sampling program are not depicted anywhere.

It appears that the draft guideline is requiring also an analytical evaluation of non-nuclear safety related components that exhibit signs of damage. Most non-nuclear safety components do not have deterministic evaluations to the level of detail of nuclear safety related components,

which is particularly true for systems in the turbine buildings. As a result, generating analysis for the non-nuclear safety related systems and components would be very time consuming and expensive with no benefit with respect to nuclear safety.

Based on the above, we suggest to clarify in the Regulatory Guide exclusion of the analysis requirement for non-nuclear safety related systems and components. (Reference 6)

Response. Regulatory Position 1.3 is withdrawn. See response to Comments C1, C2 and C4.

REFERENCES

1. Nuclear Management and Resources Council (now Nuclear Energy Institute), William H. Rasin, March 24, 1993
2. Sargent and Lundy Engineers, B.A. Erler, March 23, 1993
3. Letter from G. Slagis to N. Chokshi (NRC), dated October 26, 1993, Subject: Comments on EPRI NP-6695.
4. Wais and Associates, Inc., Royce M. Reinecke, April 4, 1995, (Comments on Draft Regulatory Guides DG-1033, DG-1034, and DG-1035)
5. Nuclear Energy Institute, William H. Rasin, May 12, 1995
6. TU Electric, J.S. Marshall, May 11, 1995