



IN REPLY REFER TO:  
Docket No. 50-29

COMPLEMENT  
FILE COPY  
UNITED STATES  
ATOMIC ENERGY COMMISSION  
WASHINGTON, D.C. 20545

JUL 16 1965

Distribution  
Document Room  
Formal  
Supplemental  
R&PRSE Reading  
DRL Reading

Originator: PNorian  
bcc: H. J. McAlduff, OROO  
E. G. Case  
H. Shapar  
L. Kornblith (2)  
E. Tremmel  
R. Huard  
G. Page  
P. Travelstead  
N. Stoner  
Change No. 65  
N. D. Mason  
D. Skovholt

Yankee Atomic Electric Company  
441 Stuart Street  
Boston 16, Massachusetts

Attention: Mr. Roger J. Coe  
Vice President

Gentlemen:

This refers to your request dated June 23, 1965, for AEC authorization of Proposed Change No. 65 in the Technical Specifications of Facility License No. DPR-3 pursuant to the provisions of Section 50.59, 10 CFR 50. The proposed change would authorize the use of two stainless steel clad silver-indium-cadmium control rods to evaluate the corrosion resistance of the cladding in the borated primary coolant environment.

We have reviewed the proposed change and have found that it does not present significant hazards considerations not described or implicit in the hazards summary report, and that there is reasonable assurance that the health and safety of the public will not be endangered. A copy of our related safety evaluation is enclosed.

In view of the foregoing, pursuant to Section 50.59, 10 CFR 50, Change No. 65 is hereby authorized as proposed.

Sincerely yours,

Original signed by  
E. G. Case

*for* R. L. Doan, Director  
Division of Reactor Licensing

Enclosure:  
Safety Evaluation

RL  
PNorian:jms  
7/12/65

*abc*  
7/14/65

RL  
RSBoye  
7/16/65

RL  
EGCase  
7/16/65

RL  
RLDoan  
7/16/65

8011110612

*P*

Change No. 65