

## YANKEE ATOMIC ELECTRIC COMPANY



20 Turnpike Road Westborough, Massachusetts 01581

November 30, 1977



United States Nuclear Regulatory Commission  
Region 1  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Attention: Office of Inspection and Enforcement

Reference: 1. License No. DPR-3 (Docket No. 50-29)  
2. USNRC Letter to YAEC dated November 22, 1977  
3. IE Bulletin No. 77-06

Dear Sir:

Subject: Containment Electrical Penetration Assemblies

We have reviewed IE Bulletin No. 77-06 and have the following response to the questions stated therein:

1.0 We do not have containment electrical penetrations that are of the GE Series 100, or are otherwise similar in that they depend upon an epoxy sealant and a dry nitrogen pressure environment to maintain integrity.

1.1. 2.0, 2.1, 2.2, 2.3, 3.0, 3.1 and 3.2 not applicable.

We trust that this information is satisfactory; however, if you require additional information, please contact us.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

R. H. Groce  
Licensing Engineer

FDB/js

8011110 813

773390075

DISTRIBUTION AFTER ISSUANCE OF PERMITTING LICENSE

NRC FORM 195  
(2-76)

U.S. NUCLEAR REGULATORY COMMISSION

DOCKET NUMBER

*HL* 50-29

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:  
N. R. C.

FROM:  
Yankee Atomic Elec. Company  
Westborough, Mass.  
R. H. Groce

DATE OF DOCUMENT  
11/30/77

DATE RECEIVED  
12/5/77

LETTER  
 ORIGINAL  
 COPY

NOTORIZED  
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1 CC

DESCRIPTION

ENCLOSURE

Consists of response to IE Bulletin No. 77-06 "Containment Electrical Penetration Assemblies".....

PLANT NAME: Yankee Rowe  
RJL 12/5/77 (1-P)

SAFETY FOR ACTION/INFORMATION

BRANCH CHIEF: (7) *SCHWENGER*

INTERNAL DISTRIBUTION

- REG FILE
- NRC PDR
- I & E (2)
- OELD
- HANAUER
- CHECK
- EISENHIT
- SHAO
- BAER
- BUTLER
- GRIMES
- J. COLLINS
- J. MCGOUGH

EXTERNAL DISTRIBUTION

CONTROL NUMBER

OPER: *GREENFIELD MASS.*

TIC

NEIC

ACRS to CYS SENT CATEGORY *B*

**POOR ORIGINAL**

*AC 2*

773390075