



UNITED STATES
ATOMIC ENERGY COMMISSION

WASHINGTON, D.C. 20540

DISTRIBUTION

Original
Doc. Room
Formal
Suppl.
R&PRSB:DL&R Reading
DL&R Reading
Originator

Docket No. 50-29

cc: H. J. McAlduff, OROO
E. G. Case
H. Shapar
L. Kornblith-2
E. Travelstead
E. Tremmel
H. Steele
G. Page
R. Huard

SEP 1 1963

Change No. 41

Yankee Atomic Electric Company
441 Stuart Street
Boston 16, Massachusetts

Attention: Mr. Roger J. Coe
Vice President

Gentlemen:

This refers to your request dated July 23, 1963, for AEC authorization of Proposed Change No. 41 in the Technical Specifications of Facility License No. DPR-3 pursuant to the provisions of Section 50.59, 10 CFR 50. The Proposed Change would authorize the installation of a one-inch valve and vent line in the Low Pressure Surge Tank safety valve discharge header.

We have reviewed the Proposed Change and have found that it does not present significant hazards considerations not described or implicit in the hazards summary report, and that there is reasonable assurance that the health and safety of the public will not be endangered. A copy of our related hazards analysis is enclosed. In view of the foregoing, Proposed Change No. 41 is hereby authorized pursuant to Section 50.59, 10 CFR 50.

Sincerely yours,

By _____
Director

Director
Division of Licensing and Regulation

Enclosure:
Hazards Analysis

R&PRSB:DL&R
JMK
9/5/63

R&PRSB:DL&R
MGaske
9/6/63

R&PRSB:DL&R
RHH
9/6/63

OCB
9/6/63

FL:DL&R
ZCCase
9/6/63

DL&R
Director
9/6/63

8011170010

P

POOR ORIGINAL

Change No. 41