



Supplemental  
FILE COPY

UNITED STATES  
ATOMIC ENERGY COMMISSION  
WASHINGTON, D.C. 20545

Distribution

Doc. Room  
Suppl.   
Formal

DRL Reading  
R&PRSB Reading  
Originator: P. Norian  
bcc: H. J. McAlduff, OROO  
E. G. Case  
H. Shapar  
L. Kornblith (2)  
E. Tremmel  
R. Huard  
G. Page  
P. Travelstead  
H. Steele  
N. Mason  
Change No. 53

IN REPLY REFER TO:

Docket No. 50-29

JUL 24 1964

Yankee Atomic Electric Company  
441 Stuart Street  
Boston, Massachusetts

Attention: Mr. Roger J. Coe  
Vice President

Gentlemen:

This refers to your request dated April 24, 1964, for AEC authorization of Proposed Change No. 53 in the Technical Specifications of Facility License No. DPR-3 pursuant to the provisions of Section 50.59, 10 CFR 50. The proposed change would permit operation of the primary system pressurizer with the solenoid relief valve line sealed off. Operation would be permitted in this manner if the solenoid relief valve cannot be repaired during the outage for installation of Core IV.

We have reviewed the Proposed Change and have found that it does not present significant hazards considerations not described or implicit in the hazards summary report, and that there is reasonable assurance that the health and safety of the public will not be endangered. A copy of our related hazards analysis is enclosed.

In view of the foregoing, Change No. 53 is hereby authorized as proposed pursuant to Section 50.59, 10 CFR 50.

Sincerely yours,

Original Signed By  
R.L. Doan

R. L. Doan, Director  
Division of Reactor Licensing

Enclosure:  
Hazards Analysis

RL  
PNorian  
7/23/64

OGC  
7/24/64

RB  
BOYD  
7/24/64

RL  
EGCase  
7/24/64

RL  
RLDoan  
7/27/64

8011170 024

P

Change No. 53