



LONG ISLAND LIGHTING COMPANY

SHOREHAM NUCLEAR POWER STATION

P.O. BOX 518, NORTH COUNTRY ROAD • WADING RIVER, N.Y. 11792

SNRC-510

October 10, 1980

Mr. Boyce Grier, Director
Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa 19406

RECEIVED
GENERAL SERVICES
ADMINISTRATION

NOV 7 11 09 50

IE BULLETIN 80-20
SHOREHAM NUCLEAR POWER STATION - UNIT 1
DOCKET NO. 50-322

Dear Mr. Grier:

IE Bulletin 80-20 describes the malfunctioning of Westinghouse Type W-2 three position, spring return to neutral position, control switches. Contact closure was intermittent with these switches in the neutral (or spring returned) position.

As directed by the Bulletin, a review has been conducted of all safety-related systems to determine if this type of Westinghouse switch has been used. No Westinghouse Type W-2, spring return to neutral position, control switches have been used in safety-related applications at Shoreham.

In response to your request for information to assist in evaluating the value/impact of each Bulletin, we estimate that approximately 8 engineering manhours have been expended in responding to this Bulletin.

We trust that the above information has been responsive to your request. Should you require additional information, please do not hesitate to contact us.

Very truly yours,

J. P. Noyarro
J. P. Noyarro
Project Manager
Shoreham Nuclear Power Station

TJS:mc

cc: Victor Stello, Director
Jim Higgins, Site