

BWR PLANT TRANSIENT ANALYSIS PROGRAM  
AT BROOKHAVEN NATIONAL LABORATORY

PREPARED FOR PRESENTATION TO THE  
COMMISSION ON NOVEMBER 10, 1980

T. P. SPEIS

801 1210 223

## BNL PROGRAM SCOPE

- MODEL A BWR-4 PLANT FOR VARIOUS ATWS CONSEQUENCE ANALYSES INCLUDING THE BROWNS FERRY-3 PARTIAL SCRAM EVENT ACCOMPANIED BY A LIMITING ANTICIPATED TRANSIENT SUCH AS MSIV CLOSURE
- PREPARE GENERIC PLANT MODELS FOR A TYPICAL BWR-3, BWR-5 AND BWR-6 FOR ATWS AND OTHER TRANSIENT CONSEQUENCE ANALYSES
- PERFORM AUDIT ANALYSES INVOLVING A SERIES OF LOSS OF FEEDWATER TRANSIENTS FOR A BWR-4 PLANT DESCRIBED IN GE'S REPORT NEDO-24708

## BNL PROGRAM OBJECTIVES

- DEVELOP CAPABILITY TO AUDIT VENDOR / LICENSEE ANALYSES
- DEVELOP CAPABILITY TO PERFORM RAPID ANALYSES OF ALL BWRS (OPERATING AND TO BE LICENSED) TO DETERMINE SAFETY IMPACT OF OPERATING TRANSIENTS AND TO PROVIDE BETTER BASES FOR DECISIONS INVOLVING OPERATING REACTORS
- DEVELOP BETTER UNDERSTANDING OF THE TRANSIENT/ACCIDENT BEHAVIOR/RESPONSE OF BWRS FOR DEVELOPING EMERGENCY GUIDELINES AND PLANT OPERATING PROCEDURES
- INDEPENDENT AUDIT(S)/ASSESSMENT(S) OF ADEQUACY OF SAFETY FEATURES

MSIV CLOSURE PLUS BF-3 PARTIAL SCRAM

TRANSIENT ANALYZED

- o PEACH BOTTOM UNIT 2 - GENERIC BWR/4 (EOC CONDITIONS)
- o INITIAL POWER - 104% OF RATED
- o MAIN STEAM ISOLATION VALVE CLOSURE
- o BF-3 PARTIAL SCRAM CONFIGURATION
- o POWER LEVEL AFTER INSERTION 10% (NOMINAL)
- o AUTOMATIC RECIRCULATION PUMP TRIP
- o HIGH PRESSURE COOLANT INJECTION (HPCI) + (RCIC)
- o MANUAL INITIATION OF RESIDUAL HEAT REMOVAL (RHR) SYSTEM (POOL COOLING MODE)
- o MANUAL INITIATION OF BORON INJECTION (SLCS)

MSIV CLOSURE PLUS BF-3 PARTIAL SCRAM

BASIS OF RELAP-3B INPUT


DATA OBTAINED FROM FSAR AND BNL ANALYSES

- BASIC PEACH BOTTOM UNIT 2 MODEL GEOMETRY AND INITIAL CONDITIONS OBTAINED FROM DESIGN INFORMATION
- REACTIVITY FEEDBACK MODELS OBTAINED FROM PREVIOUS BNL LICENSING CALCULATIONS (VOID, DOPPLER, MODERATOR TEMPERATURE)
- HPCI INITIATION AND TERMINATION BASED ON DOWNCOMER COOLANT MASS
- AIR CHARACTERISTICS AND POOL VOLUME

DATA OBTAINED FROM GE ANALYSIS

- AVERAGE POWER LEVEL AFTER SCRAM 10% (RATED) INCLUDING DECAY HEAT
- FEEDWATER TRANSIENT
- BORON REACTIVITY WORTH AND SOURCE CONCENTRATION

MSIV CLOSURE PLUS BF-3 PARTIAL SCRAM  
SUPPRESSION POOL TEMPERATURE



BF-3 Scram Configuration  
Scram from 104% Power to 10%  
Peach Bottom-2 Model

RAMONA CODE

CODE DESCRIPTION --

THERMAL HYDRAULICS

MULTI-CHANNEL CORE  
NON-EQUILIBRIUM  
STEAM SUPPLY SYSTEM

CORE PHYSICS

THREE SPACE DIMENSIONS  
FEEDBACK  
1½ ENERGY GROUPS

CODE USAGE

STEADY STATE

DETERMINATION OF CONTROL AND SCRAM WORTH  
(IN PROGRESS FOR BF3 CONFIGURATION)

TRANSIENT

LICENSING BASIS TRANSIENTS (TURBINE TRIP  
WITHOUT BYPASS)  
SMALL BREAK (FUTURE)



✓

(26)

ANTICIPATED TRANSIENTS

WITHOUT SCRAM

NUCLEAR SAFETY

JULY/AUGUST 1980

TEST FREQUENCY

TRANSIENT FREQUENCY

REDUCTION IN SAFETY

RELATIVE RISK

WM  
11/7/80



RECTIFICATION

HAS KAHL FAILURE BEEN FIXED ?

- EPRI:

FAILED AT T = 1/20

IF NOT FIXED

$$P(\text{NO FAIL, } 19T) \leq 0.02$$

NO FAILURE

THEREFORE FIXED

- STAFF

IF NOT FIXED

$$P(\text{NO FAIL, } 19T) \leq 0.39$$

INCONCLUSIVE

WM  
11/10/80

RECTIFICATION  
EFFECT ON P( ATWS )

1. CONSTANT FAILURE RATE

CONF	FAILURES		RATIO
	ONE	NONE	
95%	$3.0 \times 10^{-4}$	$2.0 \times 10^{-4}$	1.5
50%	$1.1 \times 10^{-4}$	$4.6 \times 10^{-5}$	2.4
STAFF	$1.1 \times 10^{-4}$	$3.0 \times 10^{-5}$	3.6

2. MULTIPLE FAILURE MODES  
( 10 MODES, EACH  $10^{-5}$  )

MODES	10	9	1.1
P(ATWS)	$10^{-4}$	$9 \times 10^{-5}$	1.1

TEST FREQUENCY

• EFFECTIVE TEST FREQUENCY

RPS TESTED IN PARTS  
DIFFERENT FREQUENCIES  
HOW COMBINE ?

• VALIDITY OF TESTS

PART = WHOLE ?  
CONDITIONS  
TEST = CHALLENGE ?

• ONLY REACTOR TRIP ( ELECTRICAL )

SINGLE ROD SCRAMS

• CONSIDERED BY STAFF

<u>TESTS/YEAR</u>	<u>UNAVAILABILITY</u>	
	<u>ELECTRICAL</u>	<u>MECHANICAL</u>
12	$8.0 \times 10^{-5}$	$3.0 \times 10^{-5}$
50	$1.9 \times 10^{-5}$	---
100	$1.0 \times 10^{-5}$	---
STAFF	$1.5 \times 10^{-5}$	$1.5 \times 10^{-5}$

TRANSIENT FREQUENCY

	<u>STAFF</u>	<u>EPRI</u>	<u>RATIO</u>
BWR	8	3.5	2.3
PWR	5	1.2	4

EPRI EXCLUDED

SOME TRANSIENTS

TRANSIENTS BELOW 25% POWER

EPRI EXTRAPOLATED

STAFF - AVERAGE FIRST 5 YEARS

EPRI - AVERAGE 40 YEARS

REDUCTION IN SAFETY  
(NUCLEAR SAFETY ARTICLE)

• EPRI

COMPARE PROB. LOCA GIVEN AT S

- VALVE STICK OPEN = TKQ
- VALVE STICK CLOSED = TKP
- TOO FEW VALVES = TK(PMTC)

	<u>UC (FAILURE/DEMAND )</u>	
# VALVES	3	4
Q	$1.0 \times 10^{-2}$	$1.3 \times 10^{-2}$
P	$3.0 \times 10^{-5}$	0
PMTC	0	0

• STAFF

	<u>UC (FAILURE/DEMAND )</u>	
# VALVES	1	2
Q	$3.0 \times 10^{-3}$	$6.0 \times 10^{-3}$
P	$3.0 \times 10^{-5}$	0
PMTC	$4.0 \times 10^{-1}$	$1.0 \times 10^{-2}$
	<hr/> $4.0 \times 10^{-1}$	<hr/> $1.6 \times 10^{-2}$

ADDING VALVES DECREASES P(LOCA) ( IF ATWS UNMITIGATED

REDUCTION IN SAFETY  
(EPRI PRESENTATION)

• EPRI

<u>EVENT</u>	<u>FREQ</u>	<u>ESF</u>	<u>MELT</u>
PORV (TQ)	$3 \times 10^{-2}$	$1.7 \times 10^{-2}$	$5 \times 10^{-4}$
ATWS (TK)	$2 \times 10^{-4}$	1.0	$2 \times 10^{-4}$

STUCK VALVE DOMINATES HENCE ADDITIONAL VALVES  
INCREASE RISK

COMPARE MITIGATED VERSUS UNMITIGATED ATWS

1. PORV DOMINATES
2. ATWS DOMINATES

REDUCTION IN SAFETY

A. PORV DOMINATES

1. ATWS UNMITIGATED

#	SYS	TRANS	U	ESF	MELT
1	PORV	10	$3 \times 10^{-3}$	$1.7 \times 10^{-2}$	$5 \times 10^{-4}$
1	S/V	1	$1 \times 10^{-3}$	$1.7 \times 10^{-2}$	$2 \times 10^{-5}$
	RPS	6	$3 \times 10^{-5}$	$4 \times 10^{-1}$	$7 \times 10^{-5}$
					$5.9 \times 10^{-4}$

2. ATWS MITIGATED

1	PORV	10	$3 \times 10^{-3}$	$1.7 \times 10^{-2}$	$5 \times 10^{-4}$
1	S/V	1	$1 \times 10^{-3}$	$1.7 \times 10^{-2}$	$2 \times 10^{-5}$
1	S/V	0.1	$1 \times 10^{-3}$	$1.7 \times 10^{-2}$	$2 \times 10^{-6}$
	RPS	6	$3 \times 10^{-5}$	$1.0 \times 10^{-2}$	$2 \times 10^{-6}$
					$5.2 \times 10^{-4}$

IF OTHER SEQUENCES DOMINATE, ATWS HAS SMALL EFFECT,  
BUT STILL A REDUCTION IN RISK



RELATIVE RISK

RISK = P( MELT ) P( RELEASE ) DOSE

CONSEQUENCES = P( RELEASE ) DOSE

- EPRI

$$\frac{\text{COMPETING}}{\text{ATWS}} = \frac{6.6 \times 10^{-5}}{6.4 \times 10^{-5}} \times 5000$$

- STAFF

CONSEQUENCES

ATWS

LOCA

UNMITIGATED  
ATWS

>

MITIGATED  
LOCA

POOR ORIGINAL

REDUCTION IN SAFETY

B. ATWS DOMINATES

1. ATWS UNMITIGATED


<u>SYS</u>	<u>TRANS</u>	<u>U</u>	<u>ESF</u>	<u>MELT</u>
ALL RSS	--	--	---	$3 \times 10^{-5}$
RPS .	6	$3 \times 10^{-5}$	$4 \times 10^{-1}$	$7 \times 10^{-5}$
				<hr/> $10 \times 10^{-5}$

2. ATWS MITIGATED

				$-5$
RPS	6	$3 \times 10^{-3}$	$1.0 \times 10^{-2}$	$2 \times 10^{-5}$
1 S/V	0.1	$1 \times 10^{-3}$	$1.7 \times 10^{-2}$	$2 \times 10^{-6}$
				<hr/> $3 \times 10^{-5}$

VG

1. CORE INLET
2. CORE OUTLET
3. SEPARATOR OUTLET (STEAM DOM.)
4. STEAM LINE (2ND ISOLATION VALVE)
5. FEEDWATER INLET (INCLUDES RETURN FLOW)
6. RECIRC PUMP SUCTION
7. RECIRC PUMP DISCHARGE



A-4  
POOR ORIGINAL

Figure A-3 Jet Pump BWR

REACTOR POWER LEVEL  
AND  
TOTAL PRIMARY COOLANT INJECTION

BF-3 Scram Configuration  
Scram from 104% Power to 10%  
Peach Bottom-2 Model

