NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N E C P R 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 0 (3) | 4 1 1 1 1 (4) | | (5)

LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T 0 1 REPORT SOURCE | L (6) | 0 5 0 0 0 2 9 8 (7) | 1 0 2 1 8 0 (8) | 1 1 2 0 8 0 (9)

DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During Surveillance Test, SP 6.3.20.1, motor operated valve SW-MO-89B failed to open.

0 3 This valve is controlling flow when RHR service water pump 1B or 1D is running.

0 4 (T.S. 3.5.B.2) This event had no effect upon public health and safety. Redundant

0 5 systems were available. This event is not repetitive.

0 6

0 7

0 8

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
W A (11)	E (12)	A (13)	V A L V O P (14)	X (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 0	—	0 4 3	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	H (19)	Z (20)	Z (21)	0 0 0 0 0	N (23)	(24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 One of the 3 wires connected to a OHMITE 1000 ohm variable resistor mounted inside

1 1 the valve operator was broken. The broken lead was resoldered and the circuit check-

1 2 ed. The valve was retested and its operation verified. Valve SW-MO-89A which is in

1 3 the second loop was also checked. The exact cause of the broken lead is not known.

1 4 This failure is considered one of a kind and unique.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	0 9 7 (29)	NA	B (31)	Surveillance Test

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

NAME OF PREPARER Ladislav F. Bednar PHONE 402-825-3811

8101070353