NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

UPDATE REPORT: PREVIOUS REPORT DATE 9-22-80

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 LICENSEE CODE: I L Q A D 1 (2) LICENSE NUMBER: 0 0 0 - 0 0 0 - 0 0 0 (3) LICENSE TYPE: 4 1 1 1 1 (4) CAT (5)

CON'T 01 REPORT SOURCE: L (6) DOCKET NUMBER: 0 5 0 0 0 2 5 4 (7) EVENT DATE: 0 9 0 6 8 0 (8) REPORT DATE: 1 2 1 9 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While performing the feedwater check valve Local Leak Rate Test, the leakage through
03 feedwater check valve 1-220-62B was found to be excessive. The subvolume could not
04 be pressurized. Consequently a leakage cannot be calculated but leakage is in excess
05 of the allowable limit of 18.36 scfh as specified by Technical Specification
06 4.7.A.2.i.2. Check valve 1-220-62B will be repaired and tested before unit startup.
07 In-line check valve 1-220-58B was found to have leakage within the allowable limit.
08

09	
SYSTEM CODE	C H (11)
CAUSE CODE	E (12)
CAUSE SUBCODE	B (13)
COMPONENT CODE	V A L V E X (14)
COMP. SUBCODE	C (15)
VALVE SUBCODE	D (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
8 0	—	0 2 1	/	0 3	L	—	1

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
B (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	N (25)	C 6 6 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Upon disassembly the cause of excessive leakage was found to be a worn valve seat
11 and a pivot that was dirty. The valve was relapped, cleaned and successfully
12 retested. The final leakage was measured at 17.76 scfh which is less than the
13 allowable leakage.
14

15	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	H (28)	0 0 0 (29)	NA	B (31)	Local Leak Rate Test

16	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

17	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

18	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

19	TYPE	DESCRIPTION
	Z (42)	NA

PUBLICITY

20	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	NA	

NAME OF PREPARER Dale Wykoff PHONE: 309-654-2241, ext. 180

8101090096