

BWR OWNERS' GROUP

D.B. Waters, Chairman

P.O. Box 1551 • Raleigh, North Carolina 27602 • (919) 836-6584

BWROG-80-12

December 29, 1980

U.S. Nuclear Regulatory Commission
Division of Licensing
Office of Nuclear Reactor Regulation
Washington, D. C. 20555

Attention: Darrell G. Eisenhut, Director

Subject: BWR OWNERS' GROUP EVALUATION OF NUREG-0737 REQUIREMENTS

Gentlemen:

This letter transmits on behalf of the BWR Owners' Group the General Electric evaluation of the following NUREG-0737 requirements:

- 1) RCIC automatic restart (II.K.3.13)
- 2) Core spray/LPCI automatic restart following manual termination (II.K.3.21)
- 3) Common reference level for vessel level instrumentation (II.K.3.27)
- 4) Evaluation of anticipated transients with single failure (II.K.3.44)
- 5) Evaluation of depressurization with other than the Automatic Depressurization System (II.K.3.45).

HPCI/RCIC setpoint separation, part of Requirement II.K.3.13, has been documented previously in a letter from R. H. Buchholz (GE) to D. G. Eisenhut (NRC) dated October 1, 1980 and titled "NUREG-0660 Requirement II.K.3.13". There is a statement of individual plant applicability included with each position.

General Electric will provide sixty (60) additional copies of the attachment in a separate mailing.

Please contact R. H. Buchholz (GE), (408) 925-5722 if you have any questions concerning the enclosed information.

Sincerely,

David B. Waters

D. B. Waters, Chairman
BWR Owners' Group
DBW:RHB:na

Enclosures

cc: BWR Owners' Group J. A. Olshinski (NRC)
P. W. Marriott (GE) M. W. Hodges (NRC)
S. J. Stark (GE) R. H. Buchholz (GE)

XG01
S
1/1
ADD:
LIST

8101090487A