



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

May 4, 1972

Docket No. 50-155

Consumers Power Company
ATTN: Mr. Ralph B. Sewell
Nuclear Licensing Administrator
212 West Michigan Avenue
Jackson, Michigan 49201

Change No. 30
License No. DPR-6

Gentlemen:

Your letter dated April 21, 1972, proposed changes to the Technical Specifications of Provisional Operating License No. DPR-6 that would establish requirements for an inservice inspection program for the Big Rock Point reactor.

We have reviewed the proposed inservice inspection program and determined that the inspection methods and inspection intervals according to the requirements of Table 9.3(a) conform to the requirements of Section XI of the ASME Boiler and Pressure Vessel Code, 1971 edition. We have concluded, considering radiation levels and accessibility, that the proposed technical specification is acceptable and that it does not present significant hazards considerations not described or implicit in the Big Rock Point Safety Analysis Report, as amended, and that there is reasonable assurance that the health and safety of the public will not be endangered.


Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specifications of Facility License No. DPR-6 are hereby changed as indicated in Attachment A to this letter. Although your Technical

~~duplicate of~~
~~previous document~~
810 1100684

May 4, 1972

Specifications do not include "bases", we have included a "basis" as part of the enclosed change. This is not to be considered a part of the Technical Specifications for your facility, but rather a summary of the justification for the requested change.

Sincerely,


Donald J. Skubolt
Assistant Director for
Operating Factors
Directorate of Licensing

Enclosure:
Attachment A - Changes to
Technical Specifications

cc w/enclosure:
George F. Trowbridge, Esquire
Snaw, Pittman, Potts, Trowbridge & Madden
910 - 17th Street, N. W.
Washington, D. C. 20006

MAY 4 1972

Docket No. 50-155

Consumers Power Company
ATTN: Mr. Ralph B. Sewell
Nuclear Licensing Administrator
212 West Michigan Avenue
Jackson, Michigan 49201

Change No. 30
License No. DPR-6

Gentlemen.

Your letter dated April 21, 1972, proposed changes to the Technical Specifications of Provisional Operating License No. DPR 6 that would establish requirements for an inservice inspection program for the Big Rock Point reactor.

We have reviewed the proposed inservice inspection program and determined that the inspection methods and inspection intervals according to the requirements of Table 9.3(a) conform to the requirements of Section XI of the ASME Boiler and Pressure Vessel Code, 1971 edition. We have concluded, considering radiation levels and accessibility, that the proposed technical specification is acceptable and that it does not present significant hazards considerations not described or implicit in the Big Rock Point Safety Analysis Report, as amended, and that there is reasonable assurance that the health and safety of the public will not be endangered.

Accordingly, pursuant to Section 50.59 of 10 CFR Part 50, the Technical Specifications of Facility License No. DPR-6 are hereby changed as indicated in Attachment A to this letter. Although your Technical

dupe

8101100684

POOR ORIGINAL

L:

MAY 4 1972

Specifications do not include "bases", we have included a "basis" as part of the enclosed change. This is not to be considered a part of the Technical Specifications for your facility, but rather a summary of the justification for the requested change.

Sincerely,

151

Donald J. Skovholt
 Assistant Director for
 Operating Reactors
 Directorate of Licensing

Enclosure.
 Attachment A - Changes to
 Technical Specifications

cc w/enclosure.
 George F. Trowbridge, Esquire
 Shaw, Pittman, Potts, Trowbridge & Madden
 910 - 17th Street, N. W.
 Washington, D. C. 20006

Distribution
 WDooly, DR
 Compliance (3)
 HShapar, OGC
 NDube, DRL (5)
 JRBuchanan, ORNL
 TWLaughlin, DTIE
 PDR
 Docket File
 DRL Reading
 Branch Reading
 ACRS (16)
 DJSkovholt, DRL
 TJCarter, DRL
 DLZiemann, DRL
 JJShea, DRL
 RMDiggs, DRL
 RBoyd, DRL
 RDeYoung, DRL
 RVollmer, DRL
 CRoberts, EPA

OFFICE ▶	DL	DL	DL	DL		
SURNAME ▶	<i>Joenea:sjh</i>	<i>RMDiggs</i>	<i>DLZiemann</i>	<i>DJSkovholt</i>		
DATE ▶	5/2/72	5/2/72	5/2/72	5/4/72		